



PM 0.3 FILTER EFFICIENCY ≥ 99%

CERTIFICATE FDA/CE

LAB TEST REPORT : KN95/FFP2/N95


MANUFACTURE : 95 PLUS SG (SINGAPORE)

HONGKONG

FACTORY: CHINA, VIETNAM, MALAYSIA,

Product

# Preview



95 Plus Sg Pte Ltd









1 x 1 Adult Size



95 Plus School S


Color Box

Carton Size:
10bags/1000pcs, 40box
66cmx42cmx52cm
15kg

Certificate - Certificat - 증명서 - ध्राकृ

Form QAT\_10-M04, version 00, effective since March 6th, 2020 Certificate of Compliance 3(200) B26G.PSP0U31 95 Plus SG Pte. Ltd #14-06, 101 Cecil Street, Tong Eng Building, Singapore 069533 Certification EQ (R) Mark: Type Approved Air Pollution Mask Product: Model(s): Verification to: adard: 149)2001+A1: 2009 related to CF Directive(s): R 2016/425 (Personal Protective Equipment) opinion that the technical documentation received from the manufacturer is satisfactory for the requirements of the ECM Certification Mark. The conformity mark above can be affixed on the products accordingly to the ECM regulation about its release and its use. Additional information and clarification about the Marking The manufacturer is responsible for the CF Marking process. This document has been issued on the basis of the regulation on ECM Voluntary Mark for the certification of products. RG01\_ECM rev.3 available at: www.entererma.it Issuance date: 26 March 2020 Expiry date: 25 March 2025 Reviewer Technical expert ce Director Amanda Payne **Ente Certificazione Macchine Srl** Via Ca' Bella, 243 – Loc. Castello di Serravalle – 40053 Valsamoggia (BO) - ITALY 🕿 +39 051 6705141 🖶 +39 051 6705156 🖂 info@entecerma.it 🐔 www.entecerma.it

ficate – Сертификат – 證明書




**FDA Registration Certificate** 

Report

est Report

Test



14/03/2020~15/01/202

Comply with standard requirements

NIOSH 42 CFR Part 84 Subpart

The detailed test results are shown on page 2.

Sample information is provided by the applicant;

the sample provided by the applicant.

Test

Technical requirement

Unit

The test report of this certification is responsible only for

Reviewer:

Result

Filter efficiency

Test site

The test item complies with NIOSH 42 CFR Part & Suppart K requirements:

Testing room

Issue date: 2020.3.23

Page 2 of 2

result

Test

99.6% 99.8% 99.6% 99.7% 99.6% 99.5% Single Item

decision

Page 1 of 15

Non-Powered Air-Purifying Particulate Respirators

Test date

Sample state

Test standard(s)

Test conclusion

Note


[2020] WSZ FHL NO.2125


Test item

Number

Test

items





Personal Protective Equipment Regulation (EU) 2016/425

Personal Protective Equipment Regulation: (EU) 2016/425

#14-06, 101 Cecil Street, Tong Eng Building, Singapore 069533

MADE IN CHINA

Standard Applied: EN 149: 2001+A1:2009

See Manual 2.2 Classification

Regulations

Model: 9511

2.3 Device Labeling

95 Plus SG Pte. Ltd

2.0 General description

2.1 Overview our product

RISK CATEGORIES: Category

Product name: Air Pollution Mask

Manufactured date: March. 2020

EN 149:2001+A1:2009 FFP2 NR D

95 Plus SG Pte. Ltd

File No: 3P200326G.PSP0U31

Address: #14-06, 101 Cecil Street, Tong Eng Building, Singapore 069533

Page 3 of 15

File No: 3P200326G.PSP0U31 Symbol for "AUTHORISED REPRESENTATIVE IN THE EUROPEAN COMMUNITY" Symbol for "CE Symbol for "K Symbol for "KEE Please see detailed wark on the product and package. Label sample and instruction manual in English Quality control system In order to ensure the conformity of the series production, Our company has taken the related procedures mentioned below: (1)The complete technical construction file CF) have been established before applying for the CE marking certificate. Carry out the inspection for parts and components according to the TCF Before the assemblies of the series production, the QC engineers has to check and inspect the technical specifications and intended functions of parts and components to ensure the correct use of them according to the contents of TCF and principle described in the related technical information. Carry out the inspection & testing for the products before packing Before packing the products, the QC engineers have to do the necessary inspection and testing to ensure the conformity of related requirements. In particular, they should do the testing and inspection of electrical characteristics and outer feature. Carry out the inspection for the package. After finishing the necessary inspection and testing for the products, an inspection for the packing has to be done to ensure the necessary elements being included in this packing before shipment. (5) Provision for the change of design Any change of the products described in this TCF must be checked in detail and written down again in the TCF by the designer if the change may effects the related characteristics of product.

95 Plus SG Pte. Ltd

Address: #14-06, 101 Cecil Street, Tong Eng Building, Singapore 069533

before use 7.4 The visual inspection is carried out where appropriate by the test house prior to laboratory or practical performance tests 95 Plus SG Pte. Ltd. Address: #14-06, 101 Cecil Street, Tong Eng Building, Singapore 069533 File No: 3P200326G.PSP0U31 EN 149:2001+A1:2009 Clause Requirement - Test Result - Remark A breathing machine is adjusted to 25 cycles/min and Melt blown 2.0 I stroke. The particle filtering half mask is filter mounted on a Sheffield dummy head. For testing, a saturator is incorporated in the exhalation line between the breathing machine and the dummy head the saturator being set at a temperature in excess of 37 °C to allow for the cooling of the air before it reaches the mouth of the dummy head. The air shall be saturated at (37±2) °C at the mouth of the dummy head. In order to prevent excess water spilling out of the dummy's mouth and contaminating the particle fittering half mask the head shall be 7.5 inclined so that the water runs away from the mouth and is collected in a trap. Expose the particle filtering half masks to the following thermal tyde a) for 24 h to a dry atmosphere of (70±3) °C; b) for 24 h to a temperature of (-30±3)°C; and allow to return to room temperature for at least 4

h between exposures and prior to subsequent

The conditioning shall be carried out in a manner which ensures that no thermal shock occurs. If the particle filtering half mask is designed to be

re-usable, the materials used shall withstand the cleaning and disinfecting agents and procedures to

With reference to 7.9.2, after cleaning and

Testing shall be done in accordance with 8.11

Testing shall be done in accordance with 8.4 and 8.5.

disinfecting the re-usable particle filtering half shall satisfy the penetration requirement of the

be specified by the manufacturer.

relevant class.

7.6

95 Plus SG Pte. Ltd

Clause

7.9.1

7.10

95 Plus SG Pte. Ltd

Clause

File No: 3P200326G.PSP0U31

Requirement - Test

where

File No: 3P200326G.PSP0U31

Requirement - Test

Address: #14-06, 101 Cecil Street, Tong Eng Building, Singapore 069533

EN 149:2001+A1:2009

1) walking for 2 min without head movement or talking;

if communicating with a colleague for 2 min; 5) walking for 2 min without head movement or talking. The leakage Pshall be calculated from

from one exercise to the other.

C 1 is the challenge concentration

breathing zone of the test subject tIN is the total duration of inhalation EX is the total duration of exhalation

2) turning head from side to side (approx. 15 times), as if inspecting the walls of a tunnel for 2 min;

3) moving the head up and down (approx. 15 times), as if inspecting the roof and floor for 2 min; 4) reciting the alphabet or an agreed text out loud as

measurements made over the last 100s of each of the exercise periods to avoid carry over of results

C 2 is the measured mean concentration in the

a suitable adaptor and subjected to the test(s)

harness attachment points are exposed to the

The device shall be mounted in a leaktight manner on

ensuring that components of the device that could affect filter penetration values such as valves and

challenge aerosol. Testing of penetration, exposure

Ρ

Page 7 of 15

95 Plus SG Pte. Ltd Address: #14-06, 101 Cecil Street, Tong Eng Building, Singapore 069533 File No: 3P200326G.PSP0U31 EN 149:2001+A1:2009 Result - Remark Verdict Clause Requirement – Test Walking test Ρ The particle The subjects wearing normal working clothes and filtering half wearing the particle filtering half mask shall walk at a mask could regular rate of 6 km/h on a level course. The test shall be continuous, without removal of the particle filtering undergo half mask, for a period of 10 min. practical Work simulation test performance The individual activities shall be arranged so that sufficient time is left for the comments prescribed. tests under a) walking on the level with headroom of  $(1,3 \pm 0,2)$ realistic m for 5 min; b) crawling on the level with headroom of (0,70 ± conditions 0,05) m for 5 min; 7.7 c) filling a small basket (see Figure 1, approximate volume = 8 l) with chippings or other suitable material from a popular which stands 1,5 m high and has an opening at the bottom to allow the contents to be shovelled out and a further opening at the top where the basket relivor chippings is returned The subject shall stoop or kneed as he wishes and fill the basket with chippings. He shall then lift the basket and empty the contents back into the hopper. This shall be done 20 times in 10 min Parts of the device likely to come into contact with the No sharp Ρ 7.8 edges and wearer shall have no sharp edges or burrs. Testing shall be done in accordance with 8. burrs

Verdict

Result - Remark

Total inward leakage is 9%

The

is 4 %

penetration of

paraffin oil test

Inner and out

Nonwoven pet

Result - Remark

Page 9 of 15

Verdict

Ρ

layer:

fabric

Page 8 of 15

The and storage shall be done in accordance with penatration of EN13274-7. The penetration of the filter of the particle filtering sodium 7.9.2 half mask shall meet the requirements of Table 1. chloride test is Maximum penetration of test aerosol Classificati Sodium Paraffin oil test on chloride test 95 95 I/min % max. I/min % max. 20 FFP1 20 FFP2 6 6 FFP3 1 1

Materials that may come into contact with the

irritation or any other adverse effect to health.

Address: #14-06, 101 Cecil Street, Tong Eng Building, Singapore 069533

wearer's skin shall not be known to be likely to cause

EN 149:2001+A1:2009

The facepiece is put on a metallic dummy head which

The particle is motorized such that it describes a horizontal filtering half circle with a linear speed, measured at the tip of the nose, of (60 ± 5) mm/s mask does not The head is arranged to pass over a propane burner to continue to the position of which can be adjusted. By means of a burn for more suitable gauge, the distance between the top of the than 5 s after burner, and the lowest part of the facepiece (when positioned directly over the burner) shall be set to (20 removal from ± 2) mm. the flame. With the head turned away from the area adjacent to the burner, the propage gas is turned on, the pressure adjusted to between 0,2 bar and 0,3 bar and 7.11 the gas ignited. By means of a needle valve and fine adjustments to the supply pressure, the flame heigt shall be set to (40 ± 4) min This is measured with a suitable gauge. The temperature of the flame measured at a height of (20 ± 2) mm above the burner tip by means of a 1,5 mm diarbeter mineral insulated thermocouple probe, shall be  $(800 \pm 50)$  °C The head is set in motion and the effect of passing the facepiece once through the flame shall be noted. The test shall be repeated to enable ap assessment to be made of all materials on the exterior of the device. Any one component shall be passed inrough the flame once only 95 Plus SG Pte. Ltd Address: #14-06, 101 Cecil Street, Tong Eng Building, Singapore 069533 File No: 3P200326G.PSP0U31 EN 149:2001+A1:2009 Clause Requirement - Test Result - Remark Verdict For this test the particle filtering half mask shall be Р The carbon fitted securely in a leak-tight manner but without dioxide deformation to a Sheffield dummy head (see Figure content of the

Page 10 of 15 Air shall be supplied to it from a breathing machine inhalation air adjusted to 25 cycles/min and 2,0 l/stroke and the (dead exhaled air shall have a carbon dioxide content of 5 space).does % by volume The CO is fed into the breathing machine via a not exceed an control valve, a flowmeter, a compensating bag and average of two-non-return vaives. Immediately before the solenoid valve a small quantity of exhaled air is preferably continuously 1,0% 7.12 withdrawn through a sampling line and then fed into the exhaled air va a CO<sub>2</sub> analyser. To measure the CO 2 content of the ir haled air, 5 % of the stroke volume of the inhalation phase of the breathing machine is drawn off at the marked place by an auxiliary lung and fed to a CO 2 analyser. The total dead space of the gas path (excluding the breathing machine) of the test installation should not exceed 2000 ml Measure the carbon dioxide pontent of the inhaled air and record continuously. The head harness shall be designed so that the particle filtering half mask can be donned and removed easily. The head harness shall be adjustable or 7.13 self-adjusting and shall be sufficiently robust to hold the particle filtering half mask firmly in position and be capable of maintaining total inward leakage requirements for the device The field of vision is acceptable if determined so in N/A 7.14 practical performance tests A particle filtering half mask may have one or more Ρ exhalation valve(s), which shall function correctly in all orientations Exhalation valve(s), if fitted, shall continue to operate correctly after a continuous exhalation flow of 300 7.15 I/min over a period of 30 s. When the exhalation valve housing is attached to the faceblank, it shall withstand axially a tensile force of 10 N applied for 10 s Page 11 of 15 95 Plus SG Pte. Ltd Address: #14-06, 101 Cecil Street, Tong Eng Building, Singapore 069533 File No: 3P200326G.PSP0U31 EN 149:2001+A1:2009 Clause Requirement – Test Result - Remark Verdict Sear the particle filtering half mask on the Sheffield Ρ Inhalation dummy head Measure the exhalation resistance at resistance at the opening for mouth of the dummy head using the 30 adapter shown in Figure 6 and a breathing machine adjusted to 25 cycles/min and 2.0 l/stroke or a 1/min:<0.7mb continous flow 160 l/min. Use a suitable pressure ar.Inhalation transducer. resistance at Measure the exhalation resistance with the dummy head successively placed in 5 defined positions: facing directly anead min:<2.4mbar. - facing vertically upwards Exhalation - facing vertically downwards - lying on the left side resistance at - lying on the right side 160 1/min: 7.16 Test the inhalation resistance at 30 I/min and 95 I/min <3.0mbar. continuous flow The breathing resistances apply to valved and valveless particle filtering half masks and shall meet the requirements of Table 2. Maximum permitted resistance (mbar Classificati exhalati inhalation on on 30 95 160 I/min l/min I/min FFP1 0.6 2.1 3.0 FFP2 0.7 2.4 3.0 FFP3 1.0 3.0 3.0 Convey dust from the distributor to the dust chamber N/A where it is dispersed into the air stream of 60 m  $^3$  /h. Fit the sample particle filtering half mask in a leaktight manner to a dummy head or a suitable filter holder located in the dust chamber. Connect the breathing machine and humidifier to the sample and operate for the specified testing time The concentration of dust in the test chamber may be 7.17 measured by drawing air at 2 l/min through a sampling probe equipped with a pre-weighed, high efficiency filter (open face, diameter 37 mm) located near the test sample, as shown in Figure 10 Calculate the dust concentration from the weight of dust collected, the flow rate through the filter and the time of collection Page 12 of 15

EN 149:2001+A1:2009 Clause Requirement - Test Result - Remark Verdict Andemountable parts (if fitted) shall be readily N/A 7.18 convected and secured, where possible by hand 9.1 Packaging
The following information shall be clearly and durably nacked on the smallest commercially available Ρ FFP2 NR D packaging or legible through it if the packaging is transparent.

9.1.1 The name trademark or other means of identification of the manufacturer or supplier.


9.1.2 Type-identifying marking. 9.1.3 Classification The appropriate class (FFP1, FFP2 or FFP3) followed by a single space and then: "NR" if the particle filtering baff mask is limited to single shift use only. Example: FFF3 NR or "R" if the particle filtering half mask is re-usable 9.1.4 The number and year of publication of this European Standard 9.1.5 At least the year ol end of shelf life. The end of shelf life may be informed by a pictogram as 9.1 shown in Figure 12a, where y yymn indicates the year and month 9.1.6 The sentence 'see information supplied by the manufacturer', at least in the official language(s) of the country of destination, or by using the pictogram as shown in Figure 12b. 9.1.7 The manufacturer's recommended conditions of storage (at least the temperature and humidity) or equivalent pictogram, as shown in Figures 12c and 12d. 9.1.8 The packaging of those particle filtering half masks passing the dolomite clogging test shall be additionally marked with the letter "D". ! This letter shall follow the classification marking preceded by a single space.

Page 13 of 15

Address: #14-06, 101 Cecil Street, Tong Eng Building, Singapore 069533

95 Plus SG Pte. Ltd


File No: 3P200326G.PSP0U31



**Production Photos** 

**CNAS L7901** 

Page 14 of 15



021110579

EC DECLARATION OF CONFORMITY

The undersigned Company certifies under its sole responsibility that the item of equipment specified

#14-06, 101 Cecil Street, Tong Eng Building, Singapore 069533

95 Plus SG Pte. Ltd

below satisfies the requirements of the 2016/425/EU which is apply to it.

MANUFACTURER



Trust Unit

Manufacturer

Sample

Quantity

**Test Category** 

Samples

Conditions

Document and Decide

Accordance

1

PLUS SG PTE.LED.

Entrusted sample inspection

Compliance with test requirements

Trademark

Tel

Sample Grade

Sample Receiving

Date

Serial Number

GB 2626-2006 [Respiratory protective equipment--Non-powered air-purifying particle respirator]

95+

18621799048

KN95

2020-03-03

The samples have been tested and the items inspected meet the KN95 requirements of GB 2626-2006. Test Date of issue: 2020-03-06 Conclusion The client requires the sample to be filtered without pretreatment. The inspection conclusions of this report are only drawn for the inspected items, and do not mean that Remarks the untested items or functions meet the requirements. This report is only responsible for incoming samples 审核: 批准: Examiner Approver **Testing Results** STFWT20202728 Page 2 of 2 Uni Individual Serial Results Test Items Requirement Judgment 实测值 试样编号 Initial 99.9 Loading 99.2 Initial 99.8 Loading 99.1 Initial 99.8 Loading 99.2 Initial 99.7 Loading 99.0 Filtration Initial 99.7 efficienc Without /%(NaCl N95: ≥95.0 合格 particula Loading 99.1 pretreatme matter) Initial 99.8 nt Loading 99.2 Initial 99.8 Loading 99.0 Initial 99.8 Loading 99.1 Initial 99.8

The product picture

Following blank-

Loading

Initial

Loading


99.0


99.8

99.1

# Gallery

Factory







## Stock Hollon

Global






### France



# 



#### 120 2000 91 2000 1000 91 2000 1000 110 00 1000



#### also passed the N95 filter standard test. PM0.3 has a filtration efficiency of >95%, which is completely suitable for COVID-19 for epidemic prevention.

China's Kn95 test, passed the Europan Union's

En149 test, meet the FFP2 filter standard, and

• Suitable, 95PLUS 9511 masks have passed

COVID-19 defenses:

Can 95PLUS 9511 masks be used in hospitals?
 Can be used in a non-operating room environment, but not suitable for use in an operating room.
 According to the KN95 and N95 test report data of 95PLUS 9511 masks, the PM0.3 filtration

efficiency of this model is  $\geq$ 99%, which has

with deep patient contact, such as nurses,

sterilized, and it is not spray-proof, it is not

consultation doctors, logistic staff, etc.

• However, because the 9511 mask is not

reached the levels of KN100 and FFP3. It has a

particularly suitable for follow-up Use in groups

suitable for use in the operating room of a hospital