











CREAZZO VICENZA ITALIA

Via Poma n.20. 36051
Tel +39 0444/396111-R.A
Fax +39 0444/396166



TYPE	ECC 40-1S/4		N.	0001083660		PHASE	3
KVA	400	BR	480	BR	COSPHI	0.8	INS. Q. H
R.P.M.	1500				Hz	50/60	
V	115/200/230/400				AMBIENT TEMPERATURE 40°C		
A	2008/1155/1004/577		D=Δ S=Y		IP.	21	
CONNECTION	DD/SS/D/S		V.exc.		35.0	I.exc.	3.64
SERV.	S1	J	5.8	DATE	2004		
KG	1024		631B.2RS1		ECC401S		

10% OVERLOAD FOR 2 h IN A 24 h PERIOD
 ALTERNATORE AUTOREGOLATO-SELF REGULATED ALTERNATOR-ALTERNATEUR AUTOREGULE
 EN 60034-1 CEI 2-3 - IEC 34-1 - VDE 0530 - BS4999-5000 - NF S1.111
 MADE IN ITALY