



















Fault Shutdown

Genset Data (1/2)

Alt Voltage	0V
Total KVA	0.0kVA
KVA Rating	330.0kVA
Line Freq	0.00Hz
Eng Hrs	6614.50hrs



Generators

Plot No. B-2, SEZ Industrial area, Nandal, Dist-satara, India 415523.

Generating Set ISO 8528	G3	SPEC-F		
Model Number	C330D5			
Serial Number	K181805679			
Manufacturing Order Number	A048T878			
Year of Manufacture	11-2018			
Generating Set Max Mass-Wet kg	4325			
Controller	PC1.2			
Declared Rating	ESP	PRP	COP	LTP
Rated Power (KVA)	330	300		
Rated Power(KW)	264	240		
Rated Current (A)	476.3	433		
Rated Voltage (V)	400	400		
Rated Frequency (Hz)	50	50		
Rated Power Factor	0.8	0.8		
Declared Rating: Enclosed Noise	Stand by		Prime	
Average @ 1m dB(A)	-		77	
Average @ 7m dB(A)	-		69	
Average @ 15m dB(A)	-		64	