


TurboCare[®]

TG50D5 – Std
GT Serial Number - 358

I P S A

(EX GR. “E”- TURBIGO POWER PLANT)

Major Overhaul



TECHNICAL REPORT
TR012-08

TORINO 03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5	Sheet: 2 of 83	

Issued by
Operations – Field Service

Document
I-TLE/TG50D5-358/TR012-08

Title: TG50D5 STD S/N: 358 GR. E – MAJOR OVERHAUL

Author/s
M. PANETTA/V. PALMIERI


Approved by
F.FRANCESCHINI

SUMMARY

1. FOREWORD
2. COMPRESSOR INSPECTION
3. COMBUSTION SYSTEM INSPECTION
4. TURBINE INSPECTION
5. GT ROTOR INSPECTION
6. BEARINGS INSPECTION
7. AIR & OIL SEALS INSPECTION
8. DIFFUSER BODY AND EXHAUST MANIFOLD FRONT END
9. CONCLUSION
10. LIST OF ATTACHMENTS FOR TG50D5 MAJOR OVERHAUL

Customer Distribution	Circulation List	Sign	Date
	Ing. Merola		

Circulation copy to return back to: Operations – Field Service

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5	Sheet: 3 of 83	

1.0 - FOREWORD

The gas turbine TG50D5 S/N 358, Unit GR "E" at Turbigio Power Plant, was definitively stopped on 03/05/2006. Major overhaul was started on 22/08/2007 and finished on 25/01/2008 in Porto Marghera (VE). All the activities have been done without removal the rotor, by TurboCare employees. The turbine was running on gas fuel, and at the time of the stoppage, it had cumulated the following running data:

BHG:	Firing hours on fuel gas base	23545
PHG:	Firing hours on gas peak load	6
BHO:	Firing hours on liquid fuel base	71
PHO:	Firing hours on liquid peak load	16
NS:	Number of start	959
ET:	Number of emergency trip	95
LR:	Number of load rejection	57
EH:	Equivalent hours	40113


2.0 COMPRESSOR INSPECTION

2.1 COMPRESSOR BODIES

All the Compressor Bodies and Air Inlet Casing upper part were removed and all the compressor diaphragms disassembled. The upper and lower part of the compressor bodies were found in good condition, only cleaning has been done. IGV system and blades, on AIR INLET CASING, was checked and found in good condition. Only lubrication with grease was required, done after assembly.

2.2 COMPRESSOR DIAPHRAGMS

All the diaphragms, after disassembly, have been cleaned by steam, and inspected according to the Field Inspection and Repair Guidelines F I 028/94e. Some of them were found with rubbing marks and air seal surface corrosion, slight dent and small limited area without coating on vane coated surface. The corrosion was removed by grinding and polishing, and all the diaphragms have been reassembled in the same position. See pages from 29 to 33, 46 and 47 for assembly clearances. Additionally to the FI prescriptions, on outer shroud tenon weld of the diaphragms, from the first to the fifth compressor stage ULTRASONIC TEST was performed. No indications have been found.

<i>TurboCare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5	Sheet: 4 of 83	

3.0 - COMBUSTION SYSTEM INSPECTION

All the components of the combustion system have been disassembled and sent to TurboCare factory for inspections and repair if any. Combustion System components ready to be reassembled, Transitions Pieces, Combustor Baskets, Cylinders, Cross-Flame Tubes etc, have been received in Marghera and consequently assembled. Assembly activities have been performed according to the procedures mentioned on the TG50D5 Instruction & Maintenance Manual. For assembly data and clearances, can you see pages from 49 to 55.

Note: The Dual Fuel Injectors have been put in preservation, and therefore they have not been reassembled. In place of the Injectors, temporarily steel blind flanges have been installed for turbine protection and preservation.

3.1 - ROTOR COOLING FLEXIBLE PIPES

The four flexible pipes, have been removed from the inside combustor body, cleaned by steam and inspected. A visual inspection, and dye penetrant test on welded joints have been carried out on the pipes. No indications or damaged have been found, and the components have been reassembled in the same positions.

3.2 - DIFFUSER COMPRESSOR BODY AND INTERMEDIATE SHAFT GUARD

The upper parts of the two pieces, have been removed from the inside combustor body, cleaned and inspected. The teen honeycomb seal segments assembled in the lower part of the intermediate shaft guard, were found damaged. The teen segments have been replaced with new ones. No other problems have been found on remain air seals. For assembling data see page 38.

4.0 - TURBINE INSPECTION


The Turbine Body upper part has been removed, thoroughly cleaned and visually inspected. No problems were reported.

4.1 - BLADE RINGS

The Blade Rings 1st, 2nd, 3rd and 4th stage upper and lower part have been removed, disassembled, cleaned and inspected. Spacer ring segments have been visually inspected reporting no particular problems. Only on the 1st and the 2nd stage spacer ring segments, have been found with a light corrosion. The corrosion has been eliminated through sandblast, and after the final inspection all the components have been reassembled. See pages from 74 to 81.

4.2 - 1st AND 2nd STAGE VANE SEGMENTS

The components have been removed from the blade ring and sent to TurboCare factory for inspections and repair. Two complete set of components ready to be reassembled, have been received in Marghera and consequently assembled. For the general information and assembling data of the components, you see pages from 56 to 57.

<i>TurboCare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. “E”	
Customer: I P S A	Turbine Type: TG50D5	Sheet: 5 of 83	

4.3 – 3rd STAGE VANE SEGMENTS

All the components have been removed, cleaned and inspected, according the prescriptions of the Field Inspection and Repair Guidelines F I 013/94e. During the inspection, some cracks have been found on vane segments assembled in positions 14, 15. The dimensions and the positions of the defects, are acceptable without repair, according to the Acceptance Limits mentioned in the F I 013/94e. All the components have been reassembled in the same position. For the general information and assembling data of the components, can you see pages from 56 to 59.

4.4 – 4th STAGE VANE SEGMENTS

All the components have been removed, cleaned and inspected, according the prescriptions of the Field Inspection and Repair Guidelines F I 013/94e. The whole set of the vane segments, has been sent to TurboCare factory for replacement of all air cooling tubes found damaged or with excessive wear on the extremity. After the replacement of the tubes damaged, all the components have been reassembled in the same position. For the general information and assembling data of the components, can you see pages from 56 to 57.

4.5 – TURBINE AIR LABYRINTH SEAL HOLDER

Turbine Air Labyrinth Seal Holder 2nd, 3rd and 4th stage have been removed from the blade ring and sent to TurboCare factory for inspections and repair. After repair, have been received at Marghera and reassembled. For assembling data see page 43.

5.0 GT ROTOR INSPECTION

Before removed turbine bodies upper part, first stage compressor blades and fourth stage turbine blades radial clearances have been checked out. After reassembly of the Inlet Casing and Diffuser Body, with the shaft pushed toward the exhaust, all the radial and axial clearances of the compressor and turbine rotor have been recorded. See pages from 25 to 42.


5.1 COMPRESSOR SHAFT - DISKS AND BLADES INSPECTION

The Compressor Shaft, Disks and Rotating Blades, have been cleaned by diesel oil and steam, and compressor blades inspected according to the Field Inspection and Repair Guidelines F I 014/94e. No problems have been found on the shaft and on the disks. Few and slight dents on the tip, have been found on some Rotating Blades from the 14th to 17th stage. All damaged Blades, have been field repaired according to specifications, as per FI above mentioned.

5.2 TURBINE ROTOR INSPECTION

5.2.1 - TURBINE ROTOR DISKS

The turbine rotor disks have been thoroughly cleaned and inspected. N.D.E. (dye penetrant) was performed on the disks surface and grooves. No indications have been detected on the four disks. The three Air Baffles installed between the turbine disks 1st and 2nd, 2nd and 3rd, 3rd and 4th stage, have been found excessively worn. According to Air Baffles Replacement Procedure FI 001-03e, three new set Air Baffle Plates have been field replaced between the Turbine Disks.

<i>TurboCare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. “E”	
Customer: I P S A	Turbine Type: TG50D5	Sheet: 6 of 83	

5.2.2 - TURBINE ROTATING BLADES

5.2.2.1 - 1ST STAGE BLADES

The 1st stage Turbine Rotating Blades have been removed from the disks and sent to TurboCare factory for inspections and repair. One complete set of components ready to be reassembled, have been received in Marghera and consequently assembled. The Lock Plates and Seal Pins have been cleaned by sandblast and inspected according to the Field Inspection and Repair Guidelines FI 007/85e. No defects were detected, and the total wear was found inside acceptable limits. All components have been reassembled. For the general information and assembling data, see pages 60 and 64.

5.2.2 - 2ND STAGE BLADES


The 2nd stage Turbine Rotating Blades have been removed from the disks and sent to TurboCare factory for inspections and repair. One complete set of components ready to be reassembled, have been received in Marghera and consequently assembled. The Lock Plates inlet and exhaust side, and Seal Pins have been cleaned by sandblast and inspected according to the Field Inspection and Repair Guidelines FI 007/85e. No defects were detected, and the total wear was found inside acceptable limits. All components have been reassembled. For the general information and assembling data, see pages 61 and 65.

5.2.2.2 - 3RD STAGE BLADES

The 3rd stage Turbine Rotating Blades, have been removed from the disks, cleaned by sandblast and inspected according to the Field Inspection and Repair Guidelines F I 014/94e. Dye penetrant test has been performed on the components, and on the Blades assembled in position 25, 59, 60, 63 have been found slightly damaged on the tip. Furthermore, on the Blade position 68, one crack has been detected. No indications were detected on the remaining Blades. According to the instructions as per FI above mentioned, the slightly damaged Blades have been field repaired, and reassembled in the same position. Defect on the 68 position Blade was out of acceptability limits, and the blade have been rejected and replaced with new one. For the general information and assembling data of the components, can you see pages 66 and 67. The Lock Plates inlet and exhaust side, and Seal Pins have been cleaned by sandblast and inspected according to the Field Inspection and Repair Guidelines FI 007/85e. On the Lock Plates exhaust side, the total wear on the Tab, was found out of acceptable limits. All the components have been replaced with new ones. For the general information and assembling data, see page 62.

5.2.2.3 - 4TH STAGE BLADES

The 4th stage Turbine Rotating Blades, have been removed from the disks, cleaned by sandblast and inspected according to the Field Inspection and Repair Guidelines F I 014/94e. Dye penetrant has been performed on the components and no indications or problems were detected. All the Blades have been reassembled in the same positions. For the general information and assembling data of the components, see page 69. The Lock Plates inlet and exhaust side, and Seal Pins have been cleaned by sandblast and inspected according to the Field Inspection and Repair Guidelines FI 007/85e. No defects were found on Lock Plates inlet side. All components have been reassembled. On the Lock Plates exhaust side, the total wear

<i>TurboCare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5	Sheet: 7 of 83	

on the Tab, was found out of acceptable limits. All the components have been replaced with new ones. For the general information and assembling data, see page 63.

6.0 - BEARINGS INSPECTION

6.1 - JOURNAL BEARING

Compressor and turbine side Bearings, have been removed, cleaned and inspected. N.D.T. (Ultrasonic Test and Dye Penetrant) were carried out on the Journal Bearing Pads surface and Oil Seal Ring. No indication or defects were detected on the Pads. The Oil Seal Ring on compressor side bearing, have been found with some zones of the Babbitt metal detachment. The Two Oil Seal Rings have been replaced with new one. Visual and dimensional checks were performed on Leveling Blocks e recorded. For the general information and assembling data, see pages from 16 to 18.

6.2 - THRUST BEARING

Both parts turbine and generator side have been removed, completely dismantled cleaned and inspected. Dimensional and N.D.T. (Ultrasonic Test and Dye Penetrant) were carried out on the Thrust Pad and found in good condition. No problems have been found on Leveling Link and Ring Pads Holder. All components have been reinstalled in the same positions. The two Oil Seal Rings left and right groove have been replaced. For the general information and assembling data, see pages from 19 to 24.

7. AIR & OIL SEALS INSPECTION

All air and oil seals assembled on Inlet Casing and Diffuser Body have been removed, cleaned and inspected. The seals on Inlet Casing have been found damaged and replaced with the new ones. No other problems have been found on remain seals on Diffuser Body.


8. DIFFUSER BODY AND EXHAUST MANIFOLD FRONT END

The upper parts of the Diffuser Body and Exhaust Manifold have been removed, cleaned and inspected according to the Field Inspection and Repair Guidelines FI 009/85e. Dye penetrant test has been performed on the Exhaust Diffuser Strut Shield and Exhaust Manifold Access Airfoil. Some cracks have been found and field repaired by welding, as per FI above mentioned.

9. CONCLUSION

All the maintenance activities on Gas Turbine have been performed according to the Field Inspection and Repair Guidelines applicable, and procedures and instructions mentioned on the TG50D5 Instruction & Maintenance Manual. After the completion of the major overhaul activities, the internal and external preservation process, required to protect against environmental attack during shipping and storage, have been performed.

Note: The check of the axial clearance on Thrust Bearing must be repeated after relocation of the Gas Turbine, with the GT supports fixed on the GT base plate and the base plate to the foundations.


<i>TurboCare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. “E”	
Customer: I P S A	Turbine Type: TG50D5	Sheet: 8 of 83	

Form Ref. No.: D5TR0000D


12. LIST OF ATTACHMENTS FOR TG50D5 MAJOR OVERHAUL

Form Reference	TITLE	From page	To page
Form Ref. No.: D5TR0001	TURBINE INFORMATION	11	
Form Ref. No.: D5TR0002	REPLACED PARTS LIST	12	15
Form Ref. No.: D5TR0005	JOURNAL BEARINGS	16	
Form Ref. No.: D5TR0006	WHITE METAL	17	
Form Ref. No.: D5TR0007	JOURNAL BEARINGS – LEVELLING BLOCKS	18	
Form Ref. No.: D5TR0010	THRUST BEARING	19	
Form Ref. No.: D5TR0011	THRUST BEARING	20	
Form Ref. No.: D5TR0012	THRUST BEARING – AXIAL CLEARANCE	21	
Form Ref. No.: D5TR0013	THRUST BEARING PADS	22	
Form Ref. No.: D5TR0014	THRUST BEARING COMPRESSOR SIDE – ULTRASONIC INSPECTION	23	
Form Ref. No.: D5TR0014A	THRUST BEARING GENERATOR SIDE– ULTRASONIC INSPECTION	24	
Form Ref. No.: D5TR0020	1 st STAGE COMPRESSOR AND 4 th STAGE TURBINE BLADES CLEARANCES	25	
Form Ref. No.: D5TR0021	COMPRESSOR ROTOR CLEARANCES - BEFORE OVERHAUL	26	
Form Ref. No.: D5TR0021-A	COMPRESSOR ROTOR CLEARANCES - AFTER OVERHAUL	27	
Form Ref. No.: D5TR0022	INLET CASING LABYRINTH SEALS - DETAIL “A”	28	
Form Ref. No.: D5TR0023	COMPRESSOR ROTOR CLEARANCES - DETAIL “B” - BEFORE OVERHAUL	29	
Form Ref. No.: D5TR0023-A	COMPRESSOR ROTOR CLEARANCES - DETAIL “B” - AFTER OVERHAUL	30	
Form Ref. No.: D5TR0024	COMPRESSOR ROTOR CLEARANCES – DETAIL “C” – BEFORE OVERHAUL	31	
Form Ref. No.: D5TR0024-A	COMPRESSOR ROTOR CLEARANCES – DETAIL “C” – AFTER OVERHAUL	32	
Form Ref. No.: D5TR0025	COMPRESSOR VANES / RETAINING SCREWS CLEARANCES	33	
Form Ref. No.: D5TR0026	TURBINE ROTOR CLEARANCES – RIGHT SIDE – BEFORE OVERHAUL	34	
Form Ref. No.: D5TR0026-A	TURBINE ROTOR CLEARANCES – RIGHT SIDE – AFTER OVERHAUL	35	

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008


TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5	Sheet: 9 of 83	

Form Reference	TITLE	From page	To page
Form Ref. No.: D5TR0026-B	TURBINE ROTOR CLEARANCES – LEFT SIDE – BEFORE OVERHAUL	36	
Form Ref. No.: D5TR0026-C	TURBINE ROTOR CLEARANCES – LEFT SIDE – AFTER OVERHAUL	37	
Form Ref. No.: D5TR0026-D	INTERMEDIATE SHAFT GUARD LABYRINTH SEALS – DETAIL "F"	38	
Form Ref. No.: D5TR0026-E	TURBINE ROTOR CLEARANCES – "DETAIL G" RIGHT SIDE – BEFORE OVERHAUL	39	
Form Ref. No.: D5TR0026-F	TURBINE ROTOR CLEARANCES – "DETAIL G" RIGHT SIDE – AFTER OVERHAUL	40	
Form Ref. No.: D5TR0026-G	TURBINE ROTOR CLEARANCES – "DETAIL G" LEFT SIDE – BEFORE OVERHAUL	41	
Form Ref. No.: D5TR0026-H	TURBINE ROTOR CLEARANCES – "DETAIL G" LEFT SIDE – AFTER OVERHAUL	42	
Form Ref. No.: D5TR0027	2 nd , 3 rd & 4 th STAGE AIR SEAL RING CENTERING	43	
Form Ref. No.: D5TR0028	BLADE RING CENTERING - with blade tip used only one blade	44	
Form Ref. No.: D5TR0030	TURBINE SUPPORTS – INSPECTION	45	
Form Ref. No.: D5TR0031	COMPRESSOR VANES – DEFECTS AND REPAIRS	46	47
Form Ref. No.: D5TR0032	COMPRESSOR SEALS AND DISCS – VISUAL INSPECTION	48	
Form Ref. No.: D5TR0040	STANDARD COMBUSTOR BASKET – IDENTIFICATION OF COMPONENTS	49	
Form Ref. No.: D5TR0041-A	COMBUSTOR BASKET – ASSEMBLY	50	
Form Ref. No.: D5TR0045-A	TRANSITION PIECES – AT REASSEMBLY	51	
Form Ref. No.: D5TR0047	TRANSITION PIECE LATERAL SEALS – CLEARANCES	52	
Form Ref. No.: D5TR0048	TRANSITION PIECES – ALIGNMENT CHECK	53	
Form Ref. No.: D5TR0050	TRANSITION PIECES – INNER AND OUTER SEALS CLEARANCES	54	
Form Ref. No.: D5TR0051	TRANSITION PIECES – "C" SUPPORTS ASSEMBLY CLEARANCES	55	
Form Ref. No.: D5TR0061	TURBINE VANES – CLEARANCES	56	
Form Ref. No.: D5TR0062	TURBINE VANES – SERIAL NUMBERS	57	
Form Ref. No.: D5TR0065	TURBINE 3 RD STAGE VANES – INSPECTION	58	59
Form Ref. No.: D5TR0070	TURBINE 1 ST STAGE BLADES – SEALING PLATES INSPECTION	60	
Form Ref. No.: D5TR0070-A	TURBINE 2 ND STAGE BLADES – SEALING PLATES INSPECTION	61	
Form Ref. No.: D5TR0070-B	TURBINE 3 RD STAGE BLADES – SEALING PLATES INSPECTION	62	

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5	Sheet: 10 of 83	

Form Reference	TITLE	From page	To page
Form Ref. No.: D5TR0070-C	TURBINE 4 TH STAGE BLADES – SEALING PLATES INSPECTION	63	
Form Ref. No.: D5TR0075	TURBINE 1 ST STAGE BLADES – GENERAL INFORMATION	64	
Form Ref. No.: D5TR0075-A	TURBINE 2 ND STAGE BLADES – GENERAL INFORMATION	65	
Form Ref. No.: D5TR0075-B	TURBINE 3 RD STAGE BLADES – GENERAL INFORMATION	66	67
Form Ref. No.: D5TR0075-C	TURBINE 4 TH STAGE BLADES – GENERAL INFORMATION	68	
Form Ref. No.: D5TR0082-B	TURBINE 3 RD STAGE BLADES – INSPECTION	69	73
Form Ref. No.: D5TR0085	TURBINE 1 ST STAGE VANE HOLDER – SPACERS AND SEALS	74	
Form Ref. No.: D5TR0085-A	TURBINE 2 ST STAGE VANE HOLDER – SPACERS AND SEALS	75	
Form Ref. No.: D5TR0085-B	TURBINE 3 ST STAGE VANE HOLDER – SPACERS AND SEALS	76	
Form Ref. No.: D5TR0085-C	TURBINE 4 ST STAGE VANE HOLDER – SPACERS AND SEALS	77	
Form Ref. No.: D5TR0090	TURBINE 1 ST STAGE VANE HOLDER (BLADE RING) – GENERAL INFORMATION	78	
Form Ref. No.: D5TR0090-A	TURBINE 2 ND STAGE VANE HOLDER (BLADE RING) – GENERAL INFORMATION	79	
Form Ref. No.: D5TR0090-B	TURBINE 3 RD STAGE VANE HOLDER (BLADE RING) – SPACERS AND SEALS	80	
Form Ref. No.: D5TR0090-C	TURBINE 4 TH STAGE VANE HOLDER (BLADE RING) – GENERAL INFORMATION	81	
Form Ref. No.: D5TR0091	ROTOR COOLING FLEXIBLE PIPES – INSPECTION	82	
Form Ref. No.: D5TR0096	TURBINE DISKS – INSPECTION	83	

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 11 of 83	

Form Ref. No.: D5TR0001

YEAR:

POWER PLANT: I P S A (EX TURBIGO GR "E")

UNIT S/N°: 358

DATE OF 1st. SYNCHRONISATION:

CONSTRUCTION YEAR:

DATE LAST C.I.: 18/07/2003

DATE LAST H.P.I.: 11/12/2001

DATE LAST M.O.: 25/01/2008

GAS FIRING HOURS AT BASE LOAD: 23545

GAS FIRING HOURS AT PEAK LOAD: 6

DISTILLATE FIRING HOURS AT BASE LOAD: 71

DISTILLATE FIRING HOURS AT PEAK LOAD: 16

TOTAL CUMULATED FIRING HOURS: 23638

TOTAL EQUIVALENT HOURS: 40113

TOTAL NUMBER OF STARTS: 959

TOTAL LOAD REJECTION: 57

TOTAL EMERGENCY TRIP: 95

TOTAL FIRING HOURS FROM LAST C.I.: 20752


TOTAL NUMBER OF STARTS FROM LAST C.I.: 209

TOTAL FIRING HOURS FROM LAST H.P.I.: 15963

TOTAL NUMBER OF STARTS FROM LAST H.P.I.: 476

TOTAL FIRING HOURS FROM LAST M.O.: 0

TOTAL NUMBER OF STARTS FROM LAST M.O.: 0

<i>TurboCare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008



TECHNICAL
REPORT

Rev. Date: 29/01/08

Rev.13

Power Plant: EX TURBIGO

GT S/N: 358 – GR. "E"

Customer: I P S A

Turbine Type: TG50D5std

Sheet: 12 of 83


Form Ref. No.: D5TR0002

REPLACED PARTS LIST

GROUP	ITEM	DESCRIPTION	QT.Y	DWG
1A	46	Washer diam 10,5x17x2	12	4212T72001
1A	48	Elastic ring	12	41T0461018
1A	49	Special plug	6	4275T54001
1B	13	Split pin diam 4x32	8	41T0138032
1C	2	Oil seal ring	1	4213T35001
1C	3	Oil seal ring	1	4213T33001
1D	5	Oil seal ring	2	4213T66001
1E	1	Cylindrical pin 3 x 12	4	41T0206012
1E	2	Oil seal ring, right-side helix	1	4213T59001
1E	3	Screw M5 x 25	2	42T0604025
1E	5	Oil seal ring, left-side helix	1	4213T58001
3A	1	Cap nut 2½ - 8UN x 130	2	4214T18001
3A	2	Washer 2"	2	4214T20064
3A	3	Conical tie rod 2½ - 8UN x 460	1	4214T23001
3A	19	Cap nut 3 - 8N x 143	1	4214T25001
3A	20	Washer 3"	1	4214T20076
3A	21	Tie rod with bored hole 3 - 8N x 490	1	4214T24001
3A	22	Nut with bored hole M42	4	4214T00042
3A	23	Washer M42	4	4214T33001
3A	24	Taper pin diam. 44 x 350 x 130	4	4214T27001
3A	25	Nut 2" – 8UN x 111	8	4214T16001
3A	26	Washer 3"	8	4214T20048
3A	27	Tie rod 2 - 8N x 350	4	4214T17001
3A	38	Plug M30	1	4272T74001

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

GROUP	ITEM	DESCRIPTION	QT.Y	DWG
3A	48	Allen screw M24 x 58	1	4214T61001
3A	62	Plug M30	1	4272T74001
3C	19	Screw M12	72	4216T21001
3C	20	Safety plate	36	4216T22001
3C	21	Safety plate	36	4216T23001
3C	22	Nut M12 x 1,75	72	4214T43001
3D	3	Special screw M24 x 50	1	4212T55001
3D	4	Allen screw M24 x 70	2	41T0060570
3D	6	Self locking nut M10 X 1,5	48	4275T81001
3D	7	Allen screw M10 X 45	48	41T0054545
3D	25	Sealing sector	10	4215T37001
3D	26	Allen screw M10 X 14	10	42T0174514
5A	22	Taper pin diam 13x80	2	41T0011080
5A	32	Tie-rod M18X110	4	4214T81001
5A	33	Nut M18	8	4214T82018
5A	60	Allen screw 1 3/4-8N X 230	1	4212T10001
5A	61	Nut 1 3/4 - 8 UN - 2B	1	4212T17001
5A	62	Allen screw 1 1/2"- 8N X 220	1	4212T13001
5A	63	Nut 1/2 - 8UN	1	4212T11001
6	0-2	Exhaust manifold	2	4270T03001
6	0-1	Exhaust manifold	2	4270T03002
6	0-3	Exhaust manifold	1	4270T03003
6	0-1	Exhaust manifold	5	4272T22001
6	0-2	Exhaust manifold	2	4272T28001
6	2	Hexagonal-head bolt M16 x 70	15	42T0018570
6	3	Nut with bored hole M16	15	4214T02016
4A	56	Cap nut M52 x 3 x 120	4	4214T91001

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008



TECHNICAL
REPORT

Rev. Date: 29/01/08

Rev.13

Power Plant: EX TURBIGO

GT S/N: 358 – GR. “E”

Customer: I P S A

Turbine Type: TG50D5std

Sheet: 14 of 83

GROUP	ITEM	DESCRIPTION	QT.Y	DWG
4A	57	Washer nitride hardened 2 1/4	6	4214T20057
4A	58	Allen screw M52 x 3 x 380	4	41T0256880
4B	14	Allen screw M20 x 60	1	41T0247560
4B	22	Countersunk head slotted screw M12	14	4288T02001
4D	1	Seal for Spacer ring sector 2nd stage	5 (2)	4229T89001
4D	40	Countersunk head slotted screw M12	4	4088T02001
4D	45	Countersunk head slotted screw M10	2	4088T07001
4D	29	Safety washer	8	4214T87001
4D	30	Screw M10	8	4277T58001
4D	31	Locking plate	8	4277T60001
4D	32	Alignment bushing	8	4277T56001
4F	29	Safety washer	8	4214T87001
4F	30	Special screw M 10	8	4277T57001
4F	31	Locking plate	4	4277T59001
4F	32	Alignment bushing	4	4277T56001
4G	29	Safety washer	8	4214T87001
4G	30	Special screw M 10	8	4277T57001
4G	31	Locking plate	4	4277T59001
4G	32	Alignment bushing	4	4277T56001
7D	4	Screw for plate 1st stage	4	4216T03001
7D	5	Washer	16	4216T05001
7D	7	Washer	16	4216T04001
7D	12	Screw for plate 1st, 2nd, 3rd, 4th stage	16	4216T01001
7D	17	Sealing pin for 2nd stage inlet side plate	28	4223T39001
7D	18	Washer	78	4216T06001
7D	19	Screw for plate	78	4216T00001
7D	20	Normal 3rd stage rotating blade	1	4215T78001

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008



TECHNICAL
REPORT

Rev. Date: 29/01/08

Rev.13

Power Plant: EX TURBIGO

GT S/N: 358 – GR. "E"

Customer: I P S A

Turbine Type: TG50D5std

Sheet: 15 of 83

GROUP	ITEM	DESCRIPTION	QT.Y	DWG
7D	23	Sealing plate for 3rd stage blades - Inlet side	2 (1)	4223T44001
7D	25	Screw for plate 2nd, 3rd, 4th stage	12	4216T02001
7D	32	Sealing plate for 3rd stage blades - Exhaust side (interm.)	2	4223T46001
7D	33	Sealing plate for 4th stage blades - Exhaust side (interm.)	2	4223T50001
7D	34	Sealing plate for 3rd stage blade - Exhaust side (last)	2	4223T47001
7D	35	Sealing plate for 4th stage blades - Exhaust side (last)	2	4223T51001
7D	36	Sealing plate for 3rd stage blades - Exhaust side (standard)	67	4223T45001
7D	37	Sealing plate for 4th stage blades - Exhaust side (standard)	64	4223T49001
16	2	Thermocouples for rotor cooling	2	4217T38001
20	27	Cap nut M52 x 3 x 120	8	4214T91001
20	28	Washer M52	10	4212T84052
20	29	Screw M52 x 3 x 260	8	41T0256260
20	30	Washer M48	3	4212T84148
20	31	Screw M48 x 3 x 256	3	4212T42001
20	32	Washer M48	3	4212T84048
20	33	Nut M48 x 3	3	4212T83148
20	40	Hexagonal-head bolt M42 x 3 x 240	10	42T0190240
20	42	Nut M42 x 3	10	4212T83142
20	43	Washer M42	6	4212T84142
20	51	Hexagonal-head bolt M16 x 80	11	42T0177580
20	52	Washer M16	11	4212T70001
20	53	Nut M16	15	4214T82016
20	54	Hexagonal-head bolt M16 x 35	4	42T0177535
20	55	Hexagonal-head bolt M16 x 75	10	42T0177575
20	56	Allen screw M12	6	4228T51018
20	57	Hexagonal-head bolt M16 x 65	32	42T0177565

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 16 of 83	
Form Ref. No.: D5TR0005			


JOURNAL BEARINGS

1. GENERALITY

The turbine is provided with two bearings, located on the compressor side and on the turbine side. The anomalies must be described according to bearing location.

BEARINGS	
COMPR. SIDE	TURB. SIDE

1.1	Drawing	4278T07	4278T07
1.2	Running hours	23638	23638
1.3	Running hours from last inspection	0	0
1.4	Running malfunction recorded		
1.5	Previous anomalies recorded		
1.6	Abnormal temperatures recorded		

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev. 13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 17 of 83	

Form Ref. No.: D5TR0006


JOURNAL BEARINGS INSPECTION

	BEARINGS	
	COMP. SIDE	TURB. SIDE
2.1 No anomalies	X	X
2.2 Fretting		
2.3 Foreign object damages		
2.4 Overheating		
2.5 White metal melting		
2.6 Presence of water deposits		
2.7 White metal pitted		
2.8 White metal detachment		
2.9 White metal cracks		
2.10 Contact area regular / non regular		
2.11 Excessive wear		
2.12 Non destructive test carried out	X	X
2.13 White metal re-casting required		
2.14 Cleaning only required	X	X
2.15 Various		

FURTHER INFORMATION AT RE-STARTING

	BEARINGS	
	COMP. SIDE	TURB. SIDE
3.1 WHITE METAL TEMPERATURE	NA	NA
3.2 VIBRATIONS	NA	NA

Note: U. T. - No indications have been detected on Pads surface


<i>TurboCare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 18 of 83	

Form Ref. No.: D5TR0007

JOURNAL BEARINGS – LEVELLING BLOCKS

LEVELLING BLOCKS




LEVELLING BLOCKS CONDITIONS				
BLOCK POSITION	1	2	3	4
COMPRESSOR SIDE	38,02	37,98	37,98	38,03
TURBINE SIDE	37,98	37,98	37,98	37,98

Notes:

<i>TurboCare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

THRUST BEARING



NOMENCLATURE

1. Rotor shaft
2. Thrust collar
3. Thrust pads
4. Adjustable shims
5. Levelling plate
6. Ring pads holder

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: <i>IP S A</i>	Turbine Type: <i>TG50D5std</i>	Sheet: 20 of 83	

Form Ref. No.: D5TR0011

THRUST BEARING

1.0 GENERALITY

	GEN. SIDE	COMP. SIDE
1.1 Drawings:	4278T08	4278T08
1.2 Running hours:	23638	23638
1.3 Running hours from last inspection:		
1.4 Running malfunction recorded:		
1.5 Previous anomalies recorded:		
1.6 Abnormal temperatures recorded:		


2.0 PADS AND ADJUSTMENT SHIMS

	GEN. SIDE	COMP. SIDE
2.1 No anomalies	X	X
2.2 Deposits / Others		
2.3 White metal fretting scratched / scored		
2.4 Overheating		
2.5 White metal melting		
2.6 White metal pitted		
2.7 Presence of water deposit		
2.8 White metal detachment / cracks		
2.9 White metal excessive wear		
2.10 Non destructive tests carried out	X	X
2.11 Adjustment shims replacement		

3.0 SEAL RINGS LEFT AND RIGHT GROOVE


	GEN. SIDE	COMP. SIDE
3.1 No anomalies		
3.2 Excessive wear	X	X
3.3 Foreign object damages		
3.4 Anti-rotation pin damage		
3.5 Coupling screws damage		
3.6 Discolouration due to seal fretting	X	X
3.7 Cleaning only required		

Notes: The two Oil Seal Rings have been rejected and replaced with the new ones.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 22 of 83	
Form Ref. No.: D5TR0013			



THRUST BEARING PADS



N°	GENERATOR SIDE					N°	TURBINE SIDE				
	A	B1	B2	B3	B4		A	B1	B2	B3	B4
1	40,00	36,59	36,60	36,59	36,60	1	39,92	36,65	36,65	36,65	36,65
2	39,94	36,63	36,57	36,60	36,57	2	40,00	36,69	36,69	36,68	36,68
3	40,04	36,56	36,57	36,56	36,57	3	40,00	36,63	36,63	36,63	36,63
4	40,00	36,60	36,57	36,57	36,58	4	40,02	36,64	36,64	36,64	36,63
5	40,00	36,59	36,60	36,60	36,60	5	40,10	36,69	36,68	36,68	36,67
6	40,12	36,62	36,62	36,63	36,62	6	40,02	36,70	36,70	36,69	36,69
7	40,10	36,57	36,57	36,58	36,57	7	40,04	36,73	36,73	36,73	36,73
8	40,10	36,68	36,67	36,68	36,68	8	40,04	36,69	36,69	36,69	36,69
9	40,10	36,61	36,58	36,60	36,58	9	40,18	36,68	36,68	36,68	36,68
10	39,94	36,59	36,59	36,59	36,58	10	40,00	36,65	36,63	36,66	36,64
Adjustment shim thickness = 13.0 mm.						Adjustment shim thickness = 11.55mm.					

Notes: The numbers of thrust bearings pads with thermocouple are 9 and 10 (turbine side).
The numbers of thrust bearings pads with thermocouple are 9 and 10 (generator side).

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

THRUST BEARING PADS TURBINE SIDE – ULTRASONIC INSPECTION**TURBINE
SIDE****TOP****BOTTOM****Notes: No indications have been detected on Pads surface**

<i>TurboCare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008


TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 24 of 83	

Form Ref. No.: D5TR0014A


THRUST BEARING PADS GENERATOR SIDE – ULTRASONIC INSPECTION

**GENERATOR
SIDE**

TOP



BOTTOM




Notes: No indications have been detected on Pads surface

<i>TurboCare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
M. PANETTA/V. PALMIERI	<i>[Handwritten Signature]</i>	I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 25 of 83	

Form Ref. No.: D5TR0020

1st STAGE COMPRESSOR AND 4th STAGE TURBINE BLADES CLEARANCES




BEFORE DISASSEMBLY				
Measuring point \ Stage	1	2	3	4
First stage compressor	2,20	2,90	1,90	2,60
Fourth stage turbine	8,60	7,75	8,50	5,10

AFTER REASSEMBLY				
Measuring point \ Stage	1	2	3	4
First stage compressor	2,00	2,60	2,30	2,50
Fourth stage turbine	8,30	8,10	8,30	8,30

Notes: READINGS MUST BE TAKEN ON COMPRESSOR FIRST STAGE BLADES AND TURBINE FOURTH STAGE BLADES, BETWEEN BLADES TIP AND CASINGS. THE TURBINE MUST BE COMPLETELY ASSEMBLED; ONLY THE INLET AND THE EXHAUST DUCTS UPPER PARTS, CAN BE MISSING.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

COMPRESSOR ROTOR CLEARANCES - BEFORE OVERHAUL




LEFT											
Position	F	G	H	L	M	N	P	Q	R	S	
Readings	1,70	1,80	0,30	0,28	0,50	1,00	1,00	25,30	6,30	12,10	
Permitted Clearances (diameter)	Min.	1,28	1,28	0,16	0,16	0,35	0,97	0,97	23,8	5,50	11,17
	Max	1,44	1,44	0,22	0,22	0,61	1,07	1,07	26,32	7,65	(Ref.)

RIGHT											
Position	F	G	H	L	M	N	P	Q	R	S	
Readings	1,50	1,40	0,29	0,23	0,50	1,00	1,00	25,20	6,40	11,70	
Permitted Clearances (diameter)	Min.	1,28	1,28	0,16	0,16	0,35	0,97	0,97	23,8	5,50	11,17
	Max	1,44	1,44	0,22	0,22	0,61	1,07	1,07	26,32	7,65	(Ref.)

Notes: Values different from those listed in the table, must be submitted to TurboCare for approval.
All the readings must be taken with the rotor pushed against the thrust bearing (exhaust side).

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

COMPRESSOR ROTOR CLEARANCES - AFTER OVERHAUL



LEFT											
Position	F	G	H	L	M	N	P	Q	R	S	
Readings	1,30	1,30	0,15	0,15	0,50	1,00	1,00	25,30	6,30	11,80	
Permitted Clearances	Min.	1,28	1,28	0,16	0,16	0,35	0,97	0,97	23,8	5,50	11,17
	Max	1,44	1,44	0,22	0,22	0,61	1,07	1,07	26,32	7,65	(Ref.)


RIGHT											
Position	F	G	H	L	M	N	P	Q	R	S	
Readings	1,30	1,30	0,15	0,16	0,50	1,00	1,00	25,10	6,40	11,60	
Permitted Clearances	Min.	1,28	1,28	0,16	0,16	0,35	0,97	0,97	23,8	5,50	11,17
	Max	1,44	1,44	0,22	0,22	0,61	1,07	1,07	26,32	7,65	(Ref.)

Notes: Values different from those listed in the table, must be submitted to TurboCare for approval.
All the readings must be taken with the rotor pushed against the thrust bearing (exhaust side).

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008


INLET CASING LABYRINTH SEALS - DETAIL “A”

1. Readings must be taken looking downstream, left and right side
2. Defects must be specified (i.e. inlet and outlet side looking downstream)
3. Values different from those listed in the table below must be submitted to TurboCare



CLEARANCES						Admitted clearances	SHAFT VISUAL INSPECTION
Detail “A”	Pos.	Before overhaul		After overhaul			
		Left	Right	Left	Right		
	A1	1,30	1,30	1,30	1,30	1,25 – 1,38	
	A2	1,60	1,60	1,60	1,60	1,55 – 1,78	
	A3	3,80	3,90	3,80	3,90	2,10 – 5,85	
	A4	5,30	5,40	5,30	5,40	2,55 – 6,05	
	A5	1,90	1,80	1,90	1,80	1,55 – 2,05	


COMPRESSOR OGV LABYRINTH SEAL - DETAIL “E”



CLEARANCES						Admitted clearances	SHAFT VISUAL INSPECTION
Detail “E”	Pos.	Before overhaul		After overhaul			
		left	right	left	right		
	E1	6,70	6,40	6,90	6,30	6,15	
	E2	6,70	6,60	6,70	6,50	6,50	
	E3	10,20	10,10	10,20	10,00	10,90	
	E4	2,30	2,25	2,20	2,30	2,05 – 4,62	
	E5	n.a.	n.a.	n.a.	n.a.	10,20	
	E6	2,60	2,70	2,80	2,70	1,00 - 3,75	
	E7	2,10	2,20	2,20	2,30	1,60 – 2,70	

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

COMPRESSOR ROTOR CLEARANCES - DETAIL “B” - BEFORE OVERHAUL



Sketches enclosed: yes **no**


Photo enclosed: yes **no**

Stage	left				Right				Admitted values			
	B1	B2	B3	B4	B1	B2	B3	B4	B1	B2	B3	B4
S1	11,40	7,20	1,50	1,50	11,60	7,10	1,60	1,65	10,47 12,77	6,68 - 8,28	1,32 - 1,72	1,32 - 1,72
S2	7,40	6,10	1,00	1,00	7,00	7,00	1,30	1,30	5,55 - 7,96	6,46 - 8,06	1,32 - 1,72	1,32 - 1,72
S3	6,30	10,50	1,20	1,20	5,80	10,50	1,30	1,30	5,55 - 7,93	10,1 - 11,74	1,37 - 1,77	1,53 - 1,93
S4	8,80	7,90	1,10	1,10	8,40	8,40	1,60	1,60	8,5 - 10,93	7,14 - 8,74	1,38 - 1,78	1,51 - 1,91
S5	6,30	7,40	1,10	1,10	5,50	7,90	1,60	1,60	5,53 - 7,93	7,15 - 8,75	1,63 - 2,03	1,53 - 1,93
S6	6,80	6,80	1,00	1,00	6,20	7,30	1,70	1,70	5,53 - 7,93	7,16 - 8,76	1,62 - 2,02	1,54 - 1,94
S7	6,40	6,80	1,00	1,00	6,10	8,00	1,60	1,60	5,53 - 7,93	7,15 - 8,75	1,66 - 2,06	1,75 - 2,15
S8	6,40	8,00	0,90	0,90	5,80	9,40	1,60	1,60	5,53 - 7,93	8,32 - 9,92	1,70 - 2,10	1,73 - 2,13
S9	6,80	8,80	1,20	1,20	6,80	8,80	1,60	1,60	6,72 - 9,10	8,36 - 9,96	1,68 - 2,08	1,70 - 2,10
S10	7,50	7,00	1,20	1,20	7,00	7,90	1,60	1,60	6,7 - 9,08	7,19 - 8,79	1,90 - 2,30	1,90 - 2,30
S11	6,00	7,40	1,20	1,20	5,30	8,40	1,70	1,70	5,38 - 7,68	7,31 - 8,91	1,94 - 2,34	1,87 - 2,27
S12	6,70	7,80	1,30	1,30	6,40	7,90	1,70	1,70	5,47 - 7,87	8,5 - 10,11	1,90 - 2,30	1,90 - 2,30
S13	6,90	7,90	1,30	1,30	5,80	8,80	1,80	1,80	5,33 - 7,73	8,9 - 10,51	2,23 - 2,63	2,23 - 2,63
S14	6,50	8,00	1,30	1,30	6,40	8,40	1,80	1,80	5,34 - 7,74	9,2 - 10,65	2,21 - 2,61	2,23 - 2,63
S15	6,60	7,90	1,30	1,30	5,40	8,80	1,80	1,80	5,34 - 7,74	8,32 - 9,92	2,03 - 2,43	2,03 - 2,43
S16	6,50	9,20	1,30	1,30	5,70	9,90	2,00	2,00	5,33 - 7,73	10,3 - 11,9	2,03 - 2,43	2,03 - 2,43
S17	6,90	8,90	1,20	1,20	5,50	9,80	2,00	2,00	5,33 - 7,73	10,3 - 11,9	2,03 - 2,43	2,03 - 2,43
S18	7,60	8,80	1,20	1,20	7,00	9,50	1,90	1,90	5,33 - 7,73	10,3 - 11,9	2,03 - 2,43	2,03 - 2,43
S19	6,40	---	---	---	6,50	---	---	---	5,34 - 7,74	---	---	---

Notes: Values different from those listed in the table must be submitted to TurboCare for evaluation.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

COMPRESSOR ROTOR CLEARANCES - DETAIL “B” - AFTER OVERHAUL



Sketches enclosed: yes **no**

Photo enclosed: yes **no**

Stage	left				right				Admitted values			
	B1	B2	B3	B4	B1	B2	B3	B4	B1	B2	B3	B4
S1	11,20	7,40	1,40	1,40	11,30	7,30	1,50	1,50	10,47 12,77	6,68 - 8,28	1,32 - 1,72	1,32 - 1,72
S2	5,60	8,00	1,40	1,45	6,60	7,20	1,65	1,60	5,55 - 7,96	6,46 - 8,06	1,32 - 1,72	1,32 - 1,72
S3	7,60	10,40	1,45	1,45	6,50	10,60	1,70	1,80	5,55 - 7,93	10,1 - 11,74	1,37 - 1,77	1,53 - 1,93
S4	9,50	7,45	1,50	1,60	9,50	7,30	1,90	1,90	8,5 - 10,93	7,14 - 8,74	1,38 - 1,78	1,51 - 1,91
S5	5,80	7,30	1,70	1,80	5,80	7,40	1,70	1,70	5,53 - 7,93	7,15 - 8,75	1,63 - 2,03	1,53 - 1,93
S6	5,80	7,30	1,80	1,80	5,80	7,20	1,70	1,70	5,53 - 7,93	7,16 - 8,76	1,62 - 2,02	1,54 - 1,94
S7	6,30	7,80	1,70	1,90	6,20	7,45	1,70	1,80	5,53 - 7,93	7,15 - 8,75	1,66 - 2,06	1,75 - 2,15
S8	7,00	8,60	1,90	1,90	6,30	9,20	1,80	1,80	5,53 - 7,93	8,32 - 9,92	1,70 - 2,10	1,73 - 2,13
S9	7,00	8,60	1,85	1,80	7,20	8,50	1,80	1,80	6,72 - 9,10	8,36 - 9,96	1,68 - 2,08	1,70 - 2,10
S10	7,20	8,40	2,00	2,10	7,30	8,50	2,10	2,10	6,7 - 9,08	7,19 - 8,79	1,90 - 2,30	1,90 - 2,30
S11	6,30	7,40	2,20	2,10	6,40	7,50	2,20	1,95	5,38 - 7,68	7,31 - 8,91	1,94 - 2,34	1,87 - 2,27
S12	7,60	8,90	2,10	2,10	7,80	8,60	1,95	1,95	5,47 - 7,87	8,5 - 10,11	1,90 - 2,30	1,90 - 2,30
S13	7,20	9,10	2,30	2,30	6,65	9,00	2,45	2,40	5,33 - 7,73	8,9 - 10,51	2,23 - 2,63	2,23 - 2,63
S14	6,95	9,40	2,30	2,30	6,60	9,30	2,30	2,30	5,34 - 7,74	9,2 - 10,65	2,21 - 2,61	2,23 - 2,63
S15	7,25	8,60	2,20	2,10	5,60	8,50	2,10	2,10	5,34 - 7,74	8,32 - 9,92	2,03 - 2,43	2,03 - 2,43
S16	6,90	9,80	2,10	2,10	6,35	10,55	2,10	2,10	5,33 - 7,73	10,3 - 11,9	2,03 - 2,43	2,03 - 2,43
S17	7,20	10,20	2,30	2,25	6,40	9,80	2,20	2,30	5,33 - 7,73	10,3 - 11,9	2,03 - 2,43	2,03 - 2,43
S18	7,60	10,40	2,10	2,20	7,50	10,60	2,20	2,30	5,33 - 7,73	10,3 - 11,9	2,03 - 2,43	2,03 - 2,43
S19	6,50	---	---	---	6,60	---	---	---	5,34 - 7,74	---	---	---


Notes: Values different from those listed in the table must be submitted to TurboCare for evaluation.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. “E”	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 31 of 83	

Form Ref. No.: D5TR0024

COMPRESSOR ROTOR CLEARANCES – DETAIL “C” – BEFORE OVERHAUL



Stage	Right		Left		Permitted Values	
	Horinz. CL	Upper CL	Horinz. CL	Upper CL	Horinz. CL	Upper CL
S1	2,90		2,50		2,25 – 3,02	2,05
S2	3,20		2,50		2,46 – 3,22	
S3	3,20		2,70		2,62 – 3,38	
S4	3,00		2,30		2,62 – 3,38	
S5	3,00		2,55		2,62 – 3,38	
S6	3,00		2,40		2,62 – 3,38	
S7	3,10		2,50		2,89 – 3,65	
S8	3,30		2,50		2,89 – 3,65	
S9	3,50		2,50		2,89 – 3,65	
S10	3,40		3,20		3,39 – 4,15	2,90
S11	3,40		3,40		3,39 – 4,15	
S12	3,50		2,55		3,39 – 4,15	
S13	3,40		3,20		3,64 – 4,4	
S14	3,50		3,50		3,64 – 4,4	
S15	3,50		3,40		3,64 – 4,4	
S16	3,40		2,55		3,64 – 4,4	
S17	3,40		2,80		3,64 – 4,4	
S18	3,50		3,20		3,64 – 4,4	
S19	3,40		2,55		3,64 – 4,4	2,80


Notes: Values different from those listed in the table must be submitted to TurboCare for evaluation.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. “E”	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 32 of 83	

Form Ref. No.: D5TR0024-A

COMPRESSOR ROTOR CLEARANCES – DETAIL “C” – AFTER OVERHAUL



Stage	Right		Left		Permitted Values	
	Horinz. CL	Upper CL	Horinz. CL	Upper CL	Horinz. CL	Upper CL
S1	2,60	2,00	2,50	2,00	2,25 – 3,02	2,05
S2	2,70		2,60		2,46 – 3,22	
S3	2,85		2,60		2,62 – 3,38	
S4	2,80		2,70		2,62 – 3,38	
S5	2,70		2,80		2,62 – 3,38	
S6	2,90		2,70		2,62 – 3,38	
S7	3,10		3,20		2,89 – 3,65	
S8	2,90		3,20		2,89 – 3,65	
S9	3,30		3,40		2,89 – 3,65	
S10	3,80	2,80	3,70	2,80	3,39 – 4,15	2,90
S11	3,70		3,50		3,39 – 4,15	
S12	3,90		3,60		3,39 – 4,15	
S13	3,70		3,80		3,64 – 4,4	
S14	4,00		3,90		3,64 – 4,4	
S15	3,95		3,80		3,64 – 4,4	
S16	4,10		3,90		3,64 – 4,4	
S17	3,80		4,00		3,64 – 4,4	
S18	3,90		3,80		3,64 – 4,4	
S19	3,80	2,90	3,80	2,90	3,64 – 4,4	2,80

Notes: Values different from those listed in the table must be submitted to TurboCare for evaluation.


TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 33 of 83	

Form Ref. N°: D5TR0025

COMPRESSOR VANES / RETAINING SCREWS CLEARANCES

STAGE	"J"	"S"
1÷2	0,45 – 0,85	0,50 – 0,80
3÷18	1,05 – 1,45	1,50 – 1,80
19	1,95 – 2,35	2,00 – 2,30




Stage	"S"		"J"	
	UPPER VANES	LOWER VANES	UPPER RETAINING SCREW	LOWER RETAINING SCREW
S1	0,60	0,70	0,60	0,70
S2	0,75	0,70	0,55	0,65
S3	1,60	1,70	1,20	1,30
S4	1,60	1,60	1,40	1,20
S5	1,70	1,80	1,30	1,20
S6	1,60	1,60	1,20	1,30
S7	1,60	1,55	1,30	1,35
S8	1,70	1,60	1,10	1,20
S9	1,80	1,70	1,20	1,40
S10	1,70	1,70	1,30	1,25
S11	1,55	1,60	1,40	1,30
S12	1,60	1,60	1,30	1,40
S13	1,65	1,70	1,35	1,20
S14	1,70	1,70	1,40	1,30
S15	1,60	1,60	1,40	1,30
S16	1,75	1,70	1,35	1,20
S17	1,50	1,60	1,30	1,40
S18	1,70	1,70	1,40	1,30
S19	2,20	2,10	2,10	2,20

Notes:

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE ROTOR CLEARANCES – RIGHT SIDE - BEFORE OVERHAUL




STAGE (“B” value)	1 ST	2 ND	3 RD	4 TH	POSITION	1	2	3	4	5	6	7	
Horizontal centerline readings	3,00	4,20	6,20	7,75	Readings	11,5	26,7	6,9	1,0	1,0	26,1	23,8	
Horizontal centerline permitted values	Min	3,30	4,50	6,35	Permitted values (diameter)	Min	11,4	19,4	6,60	1,0	1,0	26,0	23,6
	Max	3,80	5,35	7,20		8,70	Max	12,8	27,1	7,0	1,1	1,1	ref
Upper centerline readings	5,70	6,10	7,90	8,60	Notes:								
Upper centerline permitted values	Min	3,40	5,05	7,30		7,90							
	Max	4,00	5,90	8,15		8,75							
Lower centerline reading	3,60			8,50									
Lower centerline permitted values	Min	3,20				7,80							
	Max	3,70				8,65							

Notes: All the clearances must be taken with rotor and blade rings pushed toward the exhaust side.
Values not complying with those listed in the table, must be submitted to TurboCare for evaluation.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE ROTOR CLEARANCES – RIGHT SIDE - AFTER OVERHAUL




STAGE ("B" value)	1 ST	2 ND	3 RD	4 TH	POSITION	1	2	3	4	5	6	7	
Horizontal centerline readings	3,40	4,80	6,70	8,10	Readings	11,6	26,8	6,8	1,0	1,0	26,4	23,7	
Horizontal centerline permitted values	Min	3,30	4,50	6,35	Permitted values (diameter)	Min	11,4	19,4	6,60	1,0	1,0	26,0	23,6
	Max	3,80	5,35	7,20		8,70	Max	12,8	27,1	7,0	1,1	1,1	ref
Upper centerline readings	3,80	5,60	7,90	8,30	Notes:								
Upper centerline permitted values	Min	3,40	5,05	7,30		7,90							
	Max	4,00	5,90	8,15		8,75							
Lower centerline reading	3,40			8,30									
Lower centerline permitted values	Min	3,20		7,80									
	Max	3,70		8,65									

Notes: All the clearances must be taken with rotor and blade rings pushed toward the exhaust side.
Values not complying with those listed in the table, must be submitted to TurboCare for evaluation.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE ROTOR CLEARANCES – LEFT SIDE - BEFORE OVERHAUL




STAGE ("B" value)	1 ST	2 ND	3 RD	4 TH	POSITION	1	2	3	4	5	6	7	
Horizontal centerline readings	3,20	4,30	6,90	8,10	Readings	11,6	23,5	6,8	1,0	1,0	26,3	23,7	
Horizontal centerline permitted values	Min	3,30	4,50	6,35	Permitted values (diameter)	Min	11,4	19,4	6,60	1,0	1,0	26,0	23,6
	Max	3,80	5,35	7,20		8,70	Max	12,8	27,1	7,0	1,1	1,1	ref
Upper centerline readings	3,70	5,80	7,80	8,20	Notes:								
Upper centerline permitted values	Min	3,40	5,05	7,30		7,90							
	Max	4,00	5,90	8,15		8,75							
Lower centerline reading	3,60			8,40									
Lower centerline permitted values	Min	3,20		7,80									
	Max	3,70		8,65									

Notes: All the clearances must be taken with rotor and blade rings pushed toward the exhaust side.
Values not complying with those listed in the table must be submitted to TurboCare for evaluation.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE ROTOR CLEARANCES – LEFT SIDE - AFTER OVERHAUL




STAGE ("B" value)	1 ST	2 ND	3 RD	4 TH	POSITION	1	2	3	4	5	6	7	
Horizontal centerline readings	3,40	4,80	6,90	8,10		11,9	25,6	6,8	1,0	1,0	26,2	23,5	
Horizontal centerline permitted values	Min	3,30	4,50	6,35	Permitted values (diameter)	Min	11,4	19,4	6,60	1,0	1,0	26,0	23,6
	Max	3,80	5,35	7,20		8,70	Max	12,8	27,1	7,0	1,1	1,1	ref
Upper centerline readings	3,80	5,60	7,90	8,30	Notes:								
Upper centerline permitted values	Min	3,40	5,05	7,30									7,90
	Max	4,00	5,90	8,15									8,75
Lower centerline reading	3,40			8,30									
Lower centerline permitted values	Min	3,20			7,80								
	Max	3,70			8,65								

Notes: All the clearances must be taken with rotor and blade rings pushed toward the exhaust side.
Values not complying with those listed in the table must be submitted to TurboCare for evaluation.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008


INTERMEDIATE SHAFT GUARD LABYRINTH SEALS - DETAIL “F”

- 1 Readings must be taken looking downstream, left and right side
- 2 Defects must be specified (i.e. inlet and outlet side looking downstream)
- 3 Values different from those indicated in the table must be submitted to TurboCare for approval.



DETAIL “F”	CLEARANCES				Permitted clearances	SHAFT VISUAL INSPECTION	
	Pos.	Before overhaul		After overhaul			
		left	right	left			Right
F1	15,00	15,20	15,10	15,20	12,95 – 18,90		
F2	14,80	15,50	14,70	15,40	12,85 – 18,15		
F3	3,00	3,10	3,00	3,10	2,95 – 3,95		
F4	3,20	3,00	3,20	3,10	2,95 – 3,95		
F5	3,90	4,00	4,00	4,10	3,80 – 4,35		


DIFFUSER BODY LABYRINTH SEALS -DETAIL “H”



DETAIL “H”	CLEARANCES				Permitted clearances	SHAFT VISUAL INSPECTION	
	Pos.	Before overhaul		After overhaul			
		left	Right	Left			right
H1	1,70	1,90	1,70	1,85	1,80 – 2,02		
H2	1,40	1,35	1,45	1,35	1,35 – 1,51		
H3	1,55	1,40	1,50	1,45	1,40 – 1,63		

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE ROTOR CLEARANCES – “DETAIL G” RIGHT SIDE - BEFORE OVERHAUL




Location	1	2	3	4	5	6	7	8	9	10	11	12	13	14	
Readings	13,60	11,90	0,10	15,80	21,40	3,50	13,50	14,80	2,00	2,30	16,90	2,10	2,20	9,80	
Permitted values	Min	11,35	11,85	0,00	14,00	18,51	3,06	10,10	12,95	2,40	2,40	17,30	2,40	2,40	8,35
	Max	15,7	ref.	0,20	18,40	23,40	3,62	17,65	19,75	2,95	2,60	22,30	2,95	2,60	15,25
Location	15	16	17	18	19	20	21	22	23	24	25	26	27		
Readings	11,40	20,30	15,80	15,10	1,90	2,10	17,90	11,45	20,10	17,40	18,50	4,90	11,90		
Permitted values	Min	7,85	19,65	10,50	8,75	2,40	2,40	19,50	14,82	20,30	20,55	14,30	5,30	9,00	
	Max	15,60	24,70	19,45	15,80	2,60	2,95	24,65	19,84	25,94	26,50	23,45	14,50	18,75	

Notes: All the clearances must be taken with rotor and blade rings pushed toward the exhaust side.
 Values not complying with those listed in the table must be submitted to Turbocare for evaluation.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE ROTOR CLEARANCES – “DETAIL G” RIGHT SIDE - AFTER OVERHAUL




Location	1	2	3	4	5	6	7	8	9	10	11	12	13	14	
Readings	13,70	12,30	0,10	16,80	19,90	3,45	14,50	16,00	2,70	2,70	20,40	2,40	2,40	11,90	
Permitted values	Min	11,35	11,85	0,00	14,00	18,51	3,06	10,10	12,95	2,40	2,40	17,30	2,40	2,40	8,35
	Max	15,7	ref.	0,20	18,40	23,40	3,62	17,65	19,75	2,95	2,60	22,30	2,95	2,60	15,25
Location	15	16	17	18	19	20	21	22	23	24	25	26	27		
Readings	12,80	21,00	16,30	15,30	2,60	2,70	19,50	14,50	21,00	20,60	15,90	9,60	10,40		
Permitted values	Min	7,85	19,65	10,50	8,75	2,40	2,40	19,50	14,82	20,30	20,55	14,30	5,30	9,00	
	Max	15,60	24,70	19,45	15,80	2,60	2,95	24,65	19,84	25,94	26,50	23,45	14,50	18,75	

Notes: All the clearances must be taken with rotor and blade rings pushed toward the exhaust side.
 Values not complying with those listed in the table must be submitted to Turbocare for evaluation.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE ROTOR CLEARANCES – "DETAIL G" LEFT SIDE - BEFORE OVERHAUL




Location	1	2	3	4	5	6	7	8	9	10	11	12	13	14
Readings	10,50	11,20	0,40	14,60	18,60	3,60	10,90	14,80	2,75	2,50	17,40	2,30	2,50	9,40
Permitted values	Min	11,35	11,85	0,00	14,00	18,51	3,06	10,10	12,95	2,40	2,40	17,30	2,40	8,35
	Max	15,7	ref.	0,20	18,40	23,40	3,62	17,65	19,75	2,95	2,60	22,30	2,95	15,25
Location	15	16	17	18	19	20	21	22	23	24	25	26	27	
Readings	11,30	23,70	16,80	13,40	2,20	2,40	18,70	14,90	22,45	22,80	13,70	8,60	15,40	
Permitted values	Min	7,85	19,65	10,50	8,75	2,40	2,40	19,50	14,82	20,30	20,55	14,30	5,30	9,00
	Max	15,60	24,70	19,45	15,80	2,60	2,95	24,65	19,84	25,94	26,50	23,45	14,50	18,75

Notes: All the clearances must be taken with rotor and blade rings pushed toward the exhaust side.
 Values not complying with those listed in the table must be submitted to Turbocare for evaluation.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE ROTOR CLEARANCES – “DETAIL G” LEFT SIDE - AFTER OVERHAUL




Location	1	2	3	4	5	6	7	8	9	10	11	12	13	14	
Readings	12,40	11,90	0,10	15,60	20,10	3,40	14,50	16,00	2,70	2,50	20,60	2,90	2,50	12,40	
Permitted values	Min	11,35	11,85	0,00	14,00	18,51	3,06	10,10	12,95	2,40	2,40	17,30	2,40	2,40	8,35
	Max	15,7	ref.	0,20	18,40	23,40	3,62	17,65	19,75	2,95	2,60	22,30	2,95	2,60	15,25
Location	15	16	17	18	19	20	21	22	23	24	25	26	27		
Readings	13,20	21,30	16,50	15,50	2,40	2,80	19,60	14,90	21,00	20,70	15,70	8,60	10,90		
Permitted values	Min	7,85	19,65	10,50	8,75	2,40	2,40	19,50	14,82	20,30	20,55	14,30	5,30	9,00	
	Max	15,60	24,70	19,45	15,80	2,60	2,95	24,65	19,84	25,94	26,50	23,45	14,50	18,75	

Notes: All the clearances must be taken with rotor and blade rings pushed toward the exhaust side.
 Values not complying with those listed in the table must be submitted to Turbocare for evaluation.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

2nd, 3rd & 4th STAGE AIR SEAL RING CENTERING




STAGE	ANGLE POS.	0° 360°	45°	90°	135°	180°	225°	270°	315°
2 nd STAGE		- 0,05		- 0,40		0,00		- 0,45	
3 rd STAGE		- 0,08		- 0,65		0,00		- 0,58	
4 th STAGE		- 0,06		- 0,35		0,00		- 0,32	

NOTES:

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

BLADE RING CENTERING - with blade tip used only one blade





STAGE	ANGLE POS.	0° - 360°	90°	180°	270°
1 st STAGE		3,40	3,50	3,80	3,40
2 nd STAGE			4,90	5,60	4,80
3 rd STAGE			6,60	7,90	6,70
4 th STAGE		8,30	8,40	8,30	8,10

NOTES:

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE SUPPORTS – INSPECTION



- 1.1 Bushes clearances check:
- 1.2 Check for seizure:
- 1.3 Bushes cleaning / greasing:
- 1.4 Torsional bar check:


Notes:

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 46 of 83	

Form Ref. N°: D5TR0031

COMPRESSOR VANES – DEFECTS AND REPAIRS




Stage No.	Serial N°	Position (vane n°)	Defect description	Repair description
1		TOP		
2		TOP	Slight dent	
3		TOP	Slight dent	
4		TOP	Slight dent	
5		TOP		
6		TOP		
7		TOP		
8		TOP		
9		TOP		
10		TOP		
11		TOP		
12		TOP		
13		TOP	Rubbing mark and air seal corrosion	Grinding and polishing
14		TOP	Rubbing mark and air seal corrosion	Grinding and polishing
15		TOP	Rubbing mark and air seal corrosion	Grinding and polishing
16		TOP	Rubbing mark and air seal corrosion	Grinding and polishing

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 47 of 83	


17		TOP	Rubbing mark and air seal corrosion	Grinding and polishing
18		TOP		
19		TOP		
1		BOTTOM		
2		BOTTOM	Slight dent	
3		BOTTOM	Slight dent	
4		BOTTOM	Slight dent	
5		BOTTOM		
6		BOTTOM		
7		BOTTOM		
8		BOTTOM		
9		BOTTOM		
10		BOTTOM		
11		BOTTOM		
12		BOTTOM		
13		BOTTOM	Rubbing mark and air seal corrosion	Grinding and polishing
14		BOTTOM	Rubbing mark and air seal corrosion	Grinding and polishing
15		BOTTOM	Rubbing mark and air seal corrosion	Grinding and polishing
16		BOTTOM	Rubbing mark and air seal corrosion	Grinding and polishing
17		BOTTOM	Rubbing mark and air seal corrosion	Grinding and polishing
18		BOTTOM		
19		BOTTOM		

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 48 of 83	

Form Ref. N°: D5TR0032

COMPRESSOR SEALS AND DISCS – VISUAL INSPECTION



CONDITION

M = material loss
W = worn
CR = cracked
D = no anomalies

ACTIONS

N = to be replaced with a new seal
R = repairable
RN = no action required
CR = only cleaning required

ROW	SEALS VISUAL INSPECTION		DISCS VISUAL INSPECTION	
	CONDITIONS	ACTIONS	CONDITIONS	ACTIONS
1	D	CR	D	CR
2	D	CR	D	CR
3	D	CR	D	CR
4	D	CR	D	CR
5	D	CR	D	CR
6	D	CR	D	CR
7	D	CR	D	CR
8	D	CR	D	CR
9	D	CR	D	CR
10	D	CR	D	CR
11	D	CR	D	CR
12	D	CR	D	CR
13	D	CR	D	CR
14	D	CR	D	CR
15	D	CR	D	CR
16	D	CR	D	CR
17	D	CR	D	CR
18	D	CR	D	CR
19	D	CR	D	CR

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008




STANDARD COMBUSTOR BASKET – IDENTIFICATION OF COMPONENTS

Enclosed sketches: yes no

Enclosed photos: yes no

NOMENCLATURE CODE

- Corrugated ring C
- Ring R
- Dome D
- Spring S
- Cross flame tube connection TC
- Cross flame tube junction TJ
- Air scoop SC



TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008



TECHNICAL
REPORT

Rev. Date: 29/01/08

Rev.13

Power Plant: EX TURBIGO

GT S/N: 358 – GR. "E"

Customer: I P S A

Turbine Type: TG50D5std

Sheet: 50 of 83

Form Ref. N°: D5TR0041-A

COMBUSTOR BASKET – ASSEMBLY

POS	BASKETS		FROM THE FIRST INSTALLATION		FROM THE LAST INSPECTION			COMING FROM			
	S/N	DRAWING	DATE	STARTS NO.	FIRING HRS.	DATE	STARTS NO.	FIRING HRS.	GR	STARTS NO.	FIRING HRS.
1	ILL03955 8	STD 4219T92				03/09/08	0	0			
2	ILT12968 5	STD 4219T92				03/09/08	0	0			
3	ILL12916 1	STD 4219T92				03/09/08	0	0			
4	ILL12917 2	STD 4219T92				03/09/08	0	0			
5	ILL03956 9	STD 4219T92				03/09/08	0	0			
6	ILL03956 2	STD 4219T92				03/09/08	0	0			
7	ILT11968 0	STD 4219T92				03/09/08	0	0			
8	ILL11951 35	4219T94				03/09/08	0	0			
9	ILL05959 9	4219T94				03/09/08	0	0			
10	ILT01971 11	STD 4219T92				03/09/08	0	0			
11	ILT00031 0	STD 4219T92				03/09/08	0	0			
12	091K014 M	STD 4219T92				03/09/08	0	0			
13	ILT11967 1	STD 4219T92				03/09/08	0	0			
14	ILL11951 28	STD 4219T92				03/09/08	0	0			
15	ILL05958 7	STD 4219T92				03/09/08	0	0			
16	ILL03955 7	STD 4219T92				03/09/08	0	0			
17	ILL11951 36	4219T93				03/09/08	0	0			
18	ILL12916 2	4219T93				03/09/08	0	0			

Notes:

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008


TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 51 of 83	

Form Ref. N°: D5TR0045-A


TRANSITION PIECES – AT REASSEMBLY

TRANSITION PIECES			FROM THE FIRST INSTALLATION			FROM THE LAST INSPECTION			COMING FROM		
POS	S/N	DRAWING	DATE	STARTS NO.	FIRING HRS.	DATE	STARTS NO.	FIRING HRS.	GR	STARTS NO.	FIRING HRS.
1	059	4220T99				03/09/08	0	0			
2	498	4220T99				03/09/08	0	0			
3	060	4220T99				03/09/08	0	0			
4	071	4220T99				03/09/08	0	0			
5	055	4220T99				03/09/08	0	0			
6	064	4220T99				03/09/08	0	0			
7	063	4220T99				03/09/08	0	0			
8	057	4220T99				03/09/08	0	0			
9	494	4220T99				03/09/08	0	0			
10	502	4220T99				03/09/08	0	0			
11	058	4220T99				03/09/08	0	0			
12	070	4220T99				03/09/08	0	0			
13	499	4220T99				03/09/08	0	0			
14	062	4220T99				03/09/08	0	0			
15	015GRE	4220T99				03/09/08	0	0			
16	ILT021251	4220T99				03/09/08	0	0			
17	ILT030338	4220T99				03/09/08	0	0			
18	ILT021259	4220T99				03/09/08	0	0			

Notes:

<i>TurboCare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TRANSITION PIECE LATERAL SEALS – CLEARANCES




TRANSITION	AT DISASSEMBLY			AT RE-ASSEMBLY	
	PRESENCE OF CRACKS ON LATERAL SEALS	VALUE "A"	VALUE "B"	VALUE "A"	VALUE "B"
1 – 2				8,00	2,5
2 – 3				8,00	3,10
3 – 4				8,50	2,80
4 – 5				6,10	4,20
5 – 6				7,00	3,50
6 – 7				6,00	2,90
7 – 8				7,00	3,20
8 – 9				6,80	3,80
9 – 10				6,80	3,70
10 – 11				7,00	3,00
11 – 12				7,00	4,10
12 – 13				6,00	3,90
13 – 14				7,00	3,40
14 – 15				7,00	4,30
15 – 16				7,00	4,50
16 – 17				6,50	3,90
17 – 18				6,00	2,80
18 – 1				7,00	2,90

Notes:

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TRANSITION PIECES – ALIGNMENT CHECK




NUMBERING IS REFERRED TO TURBINE CENTERLINE (i.e.: position 2 is always toward the internal support)

POSITION	GAP READING “A”				DIFFERENCE		NOTES
	A1	A2	A3	A4	A1-A2	A3-A4	
1	3,90	3,60	3,80	3,80	0,30	0,00	
2	3,10	3,30	4,00	4,20	0,20	0,20	
3	3,40	3,50	4,70	4,60	0,10	0,10	
4	4,50	4,20	4,50	4,30	0,30	0,20	
5	3,80	3,70	3,60	4,10	0,10	0,50	
6	3,50	3,30	4,50	4,40	0,20	0,10	
7	3,20	3,40	4,10	3,60	0,20	0,50	
8	4,00	3,70	4,00	4,00	0,30	0,00	
9	3,40	3,20	4,10	3,70	0,20	0,40	
10	3,30	3,30	4,30	4,10	0,00	0,20	
11	3,50	3,70	3,40	3,60	0,20	0,20	
12	3,30	3,40	3,50	3,30	0,10	0,20	
13	3,60	3,60	3,40	3,70	0,00	0,30	
14	3,60	3,90	3,90	4,00	0,30	0,10	
15	4,70	4,30	4,60	4,90	0,40	0,30	
16	2,80	3,10	4,50	4,30	0,30	0,20	
17	3,50	3,80	3,80	3,90	0,30	0,10	
18	3,40	3,40	4,20	4,70	0,00	0,50	

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008


TRANSITION PIECES – INNER AND OUTER SEALS CLEARANCES



TRANSITION PIECE	OUTER SEALS CLEARANCE	INNER SEAL CLEARANCE	NOTES
1 - 2	5,50	6,70	
2 - 3	6,50	7,10	
3 - 4	6,40	6,30	
4 - 5	5,60	6,00	
5 - 6	6,30	7,40	
6 - 7	6,80	7,20	
7 - 8	6,40	7,00	
8 - 9	7,10	6,60	
9 - 10	6,30	6,10	
10 - 11	6,50	5,90	
11 - 12	6,00	6,80	
12 - 13	7,00	7,20	
13 - 14	7,10	6,00	
14 - 15	6,50	7,30	
15 - 16	6,60	6,50	
16 - 17	7,00	5,60	
17 - 18	6,50	6,00	
18 - 1	7,00	6,20	

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TRANSITION PIECES – “C” SUPPORTS ASSEMBLY CLEARANCES



POS N°	Clearance A		Clearance B		Clearance C		Clearance D		POS. N°	Clearance A		Clearance B		Clearance C		Clearance D	
	I	II	I	II	I	II	I	II		I	II	I	II	I	II	I	II
1	0,60	0,80	0,40	0,60	0,30	0,50	0,20	0,40	10	0,70	1,00	0,60	0,40	0,40	0,50	0,25	0,30
2	0,50	0,50	0,50	0,35	0,50	0,45	0,15	0,15	11	0,80	0,60	0,40	0,55	0,35	0,60	0,50	0,50
3	0,70	0,60	0,50	0,40	0,70	0,50	0,10	0,10	12	0,50	0,50	0,65	0,60	0,70	0,35	0,40	0,40
4	0,60	0,50	0,60	0,50	0,60	0,45	0,30	0,25	13	0,50	0,70	0,45	0,60	0,65	0,40	0,20	0,10
5	0,60	0,70	0,45	0,60	0,40	0,50	0,10	0,10	14	0,50	0,50	0,70	0,40	0,60	0,30	0,20	0,15
6	0,60	0,80	0,40	0,50	0,60	0,70	0,40	0,40	15	0,60	0,70	0,60	0,45	0,55	0,50	0,35	0,20
7	0,90	1,00	0,35	0,55	0,50	0,40	0,10	0,25	16	0,80	0,60	0,40	0,50	0,45	0,60	0,10	0,10
8	0,80	0,50	0,60	0,50	0,65	0,30	0,55	0,60	17	0,70	0,65	0,55	0,60	0,60	0,40	0,20	0,10
9	0,70	0,80	0,55	0,70	0,45	0,60	0,15	0,15	18	0,60	0,70	0,35	0,65	0,40	0,70	0,15	0,10

Notes:

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008


TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 56 of 83	

Form Ref. N°: D5TR0061

TURBINE VANES – CLEARANCES

1 ST STAGE				2 ND STAGE		3 RD STAGE		4 TH STAGE	
POS.	GAP (mm.)	POS.	GAP (mm.)	POS.	GAP (mm.)	POS.	GAP (mm.)	POS.	GAP (mm.)
1-2	2,10	31-32	2,10	1-2	5,20	1-2	4,60	1-2	5,40
2-3	1,90	32-33	2,25	2-3	6,30	2-3	4,90	2-3	5,80
3-4	2,40	33-34	2,40	3-4	5,40	3-4	5,10	3-4	5,30
4-5	2,30	34-35	2,60	4-5	6,10	4-5	4,55	4-5	5,60
5-6	2,20	35-36	2,55	5-6	5,90	5-6	5,20	5-6	5,40
6-7	2,45	36-37	2,30	6-7	5,80	6-7	5,00	6-7	6,00
7-8	1,80	37-38	1,90	7-8	5,10	7-8	5,30	7-8	5,10
8-9	2,00	38-39	2,45	8-9	5,25	8-9	4,70	8-9	5,90
9-10	2,60	39-40	2,20	9-10	6,10	9-10	4,85	9-10	5,70
10-11	2,50	40-41	2,40	10-11	5,40	10-11	5,20	10-11	5,65
11-12	2,60	41-42	2,60	11-12	5,70	11-12	4,40	11-12	5,30
12-13	2,55	42-43	2,45	12-13	6,30	12-13	4,65	12-13	5,45
13-14	2,40	43-44	2,50	13-14	5,80	13-14	5,40	13-14	5,60
14-15	2,35	44-45	2,40	14-15	5,65	14-15	5,25	14-15	5,70
15-16	2,10	45-46	2,10	15-16	5,90	15-16	4,70	15-16	5,65
16-17	2,25	46-47	2,20	16-17	5,35	16-17	5,10	16-1	5,40
17-18	2,40	47-48	2,20	17-18	5,60	17-18	5,20		
18-19	2,60	48-49	2,30	18-19	5,75	18-1	4,90		
19-20	2,55	49-50	2,45	19-20	6,10				
20-21	2,30	50-51	2,60	20-1	5,70				
21-22	1,90	51-52	2,50						
22-23	2,45	52-53	2,25						
23-24	2,70	53-54	2,10						
24-25	2,45	54-55	2,65						
25-26	2,30	55-56	2,30						
26-27	2,20	56-57	2,40						
27-28	2,50	57-58	2,60						
28-29	2,45	58-58	1,90						
29-30	2,60	59-60	2,40						
30-31	2,55	60-1	2,00						

Notes:

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 57 of 83	


Form Ref. N°: D5TR0062

TURBINE VANES – SERIAL NUMBERS

DISASSEMBLY


ASSEMBLY

1 ST STAGE				2 ND STAGE		3 RD STAGE		4 TH STAGE	
POS.	S/N	POS.	S/N	POS.	S/N	POS.	S/N	POS.	S/N
1	039950027	31	946UB1860	1	U2T699	1	U3K582	1	U4T401
2	U39680020	32	946UB1876	2	U2T709	2	U3K589	2	U4T393
3	U45280113	33	946UB1875	3	U2T694	3	U3K593	3	U4T410
4	U40650047	34	946UB1839	4	U2T687	4	U3K588	4	U4T402
5	946UB1869	35	946UB1833	5	U2T695	5	U3K579	5	U4T409
6	946UB1845	36	946UB1830	6	U2T702	6	U3K580	6	U4T398
7	946UB1862	37	946UB1826	7	U2T712	7	U3K590	7	U4T408
8	946UB1874	38	U39630025	8	U2T700	8	U3K585	8	U4T406
9	U1K3220	39	946UB1861	9	U2T705	9	U3K594	9	U4T407
10	946UB1829	40	946UB1857	10	U2T706	10	U3K591	10	U4T403
11	946UB1850	41	946UB1849	11	U2T710	11	U3K584	11	U4T397
12	946UB1847	42	946UB1855	12	U2T698	12	U3K583	12	U4T417
13	946UB1866	43	946UB1858	13	U2T689	13	U3K595	13	U4T413
14	946UB1843	44	946UB1870	14	U2T692	14	U3K592	14	U4T405
15	U1K2637	45	946UB1846	15	U2T688	15	U3K578	15	U4T414
16	946UB1872	46	946UB1878	16	U2T701	16	U3K581	16	U4T404
17	946UB1859	47	946UB1838	17	U2T714	17	U3K586		
18	946UB1840	48	946UB1823	18	U2T697	18	U3K596		
19	946UB1880	49	946UB1864	19	U2T693				
20	946UB1825	50	946UB1852	20	U2T703				
21	946UB1856	51	U4159-0076						
22	946UB1834	52	946UB1837						
23	946UB1873	53	946UB1822						
24	946UB1836	54	946UB1841						
25	946UB1867	55	946UB1868						
26	946UB1844	56	946UB1848						
27	946UB1853	57	946UB1831						
28	946UB1865	58	946UB1828						
29	946UB1871	59	946UB1879						
30	U40690051	60	946UB1832						

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE 3RD STAGE VANES - INSPECTION

S/N: U3K592	DWG: 4282T81	POSITION : 14	FIRING HRS : 40113	STARTS NO.: 1019	TESTED: PT <input type="checkbox"/> VT <input checked="" type="checkbox"/>
-----------------------	------------------------	-------------------------	------------------------------	----------------------------	--





Position	Damage description	Position	Damage description
1	CRACK L = 30 mm	10	
2	CRACK L= 62 mm	11	
3		12	
4		13	
5		14	
6		15	
7		16	
8			
9			

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE 3RD STAGE VANES - INSPECTION


S/N: U3K578	DWG: 4282T81	POSITION : 15	FIRING HRS : 40113	STARTS NO.: 1019	TESTED: PT <input type="checkbox"/> VT <input checked="" type="checkbox"/>
-----------------------	------------------------	-------------------------	------------------------------	----------------------------	--



Position	Damage description	Position	Damage description
1	CRACK L = 30 mm	10	
2	CRACK L= 110 mm	11	
3		12	
4		13	
5		14	
6		15	
7		16	
8			
9			

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE 1ST STAGE BLADES – SEALING PLATES INSPECTION



MAX. ADMITTED VALUE


$$A + B = 3 \text{ mm}$$

N°	A	A + B	N°	A	A + B	N°	A	A + B	N°	A	A + B
1		1.0	29		1.0	57		1.0	85		1.0
2		1.0	30		1.0	58		1.0	86		1.0
3		1.0	31		1.0	59		1.0	87		1.0
4		1.0	32		1.0	60		1.0	88		1.0
5		1.0	33		1.0	61		1.0	89		1.0
6		1.0	34		1.0	62		1.0	90		1.0
7		1.0	35		1.0	63		1.0	91		1.0
8		1.0	36		1.0	64		1.0	92		1.0
9		1.0	37		1.0	65		1.0	93		1.0
10		1.0	38		1.0	66		1.0	94		1.0
11		1.0	39		1.0	67		1.0	95		1.0
12		1.0	40		1.0	68		1.0	96		1.0
13		1.0	41		1.0	69		1.0	97		1.0
14		1.0	42		1.0	70		1.0	98		1.0
15		1.0	43		1.0	71		1.0	99		1.0
16		1.0	44		1.0	72		1.0	100		1.0
17		1.0	45		1.0	73		1.0	101		1.0
18		1.0	46		1.0	74		1.0	102		1.0
19		1.0	47		1.0	75		1.0	103		1.0
20		1.0	48		1.0	76		1.0			
21		1.0	49		1.0	77		1.0			
22		1.0	50		1.0	78		1.0			
23		1.0	51		1.0	79		1.0			
24		1.0	52		1.0	80		1.0			
25		1.0	53		1.0	81		1.0			
26		1.0	54		1.0	82		1.0			
27		1.0	55		1.0	83		1.0			
28		1.0	56		1.0	84		1.0			

Notes: All sealing plates have been reassembled. Max wear measured about 1.0 mm

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE 2ND STAGE BLADES – SEALING PLATES INSPECTION



MAX. ADMITTED VALUE

A + B = 3 mm


N°	A	A + B	N°	A	A + B	N°	A	A + B	N°	A	A + B
1		1.0	29		1.0	57		1.0	85	1.0	
2		1.0	30		1.0	58		1.0	86	1.0	
3		1.0	31		1.0	59		1.0	87	1.0	
4		1.0	32		1.0	60		1.0	88	1.0	
5		1.0	33		1.0	61		1.0	89	1.0	
6		1.0	34		1.0	62		1.0	90	1.0	
7		1.0	35		1.0	63		1.0	91	1.0	
8		1.0	36		1.0	64		1.0	92	1.0	
9		1.0	37		1.0	65		1.0	93	1.0	
10		1.0	38		1.0	66		1.0			
11		1.0	39		1.0	67		1.0			
12		1.0	40		1.0	68		1.0			
13		1.0	41		1.0	69		1.0			
14		1.0	42		1.0	70		1.0			
15		1.0	43		1.0	71		1.0			
16		1.0	44		1.0	72		1.0			
17		1.0	45		1.0	73		1.0			
18		1.0	46		1.0	74		1.0			
19		1.0	47		1.0	75		1.0			
20		1.0	48		1.0	76		1.0			
21		1.0	49		1.0	77		1.0			
22		1.0	50		1.0	78		1.0			
23		1.0	51		1.0	79		1.0			
24		1.0	52		1.0	80		1.0			
25		1.0	53		1.0	81		1.0			
26		1.0	54		1.0	82		1.0			
27		1.0	55		1.0	83		1.0			
28		1.0	56		1.0	84		1.0			

Notes: All sealing plates have been reassembled. Max wear measured about 1.0 mm

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: IP S A	Turbine Type: TG50D5std	Sheet: 62 of 83	
Form Ref. N°: D5TR0070-B			

TURBINE 3RD STAGE BLADES – SEALING PLATES INSPECTION



MAX. ADMITTED VALUE

$A + B = 3 \text{ mm}$

N°	A	A + B	N°	A	A + B	N°	A	A + B
1		4.0	26		4.0	51		4.0
2		4.0	27		4.0	52		4.0
3		4.0	28		4.0	53		4.0
4		4.0	29		4.0	54		4.0
5		4.0	30		4.0	55		4.0
6		4.0	31		4.0	56		4.0
7		4.0	32		4.0	57		4.0
8		4.0	33		4.0	58		4.0
9		4.0	34		4.0	59		4.0
10		4.0	35		4.0	60		4.0
11		4.0	36		4.0	61		4.0
12		4.0	37		4.0	62		4.0
13		4.0	38		4.0	63		4.0
14		4.0	39		4.0	64		4.0
15		4.0	40		4.0	65		4.0
16		4.0	41		4.0	66		4.0
17		4.0	42		4.0	67		4.0
18		4.0	43		4.0	68		4.0
19		4.0	44		4.0	69		4.0
20		4.0	45		4.0	70		4.0
21		4.0	46		4.0	71		4.0
22		4.0	47		4.0			
23		4.0	48		4.0			
24		4.0	49		4.0			
25		4.0	50		4.0			


Notes: All sealing plates have been replaced with new ones.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: IP S A	Turbine Type: TG50D5std	Sheet: 63 of 83	

Form Ref. N°: D5TR0070-C

TURBINE 4TH STAGE BLADES – SEALING PLATES INSPECTION



MAX. ADMITTED VALUE

$A + B = 3 \text{ mm}$

N°	A	A + B	N°	A	A + B	N°	A	A + B
1		4	26		4	51		4
2		4	27		4	52		4
3		4	28		4	53		4
4		4	29		4	54		4
5		4	30		4	55		4
6		4	31		4	56		4
7		4	32		4	57		4
8		4	33		4	58		4
9		4	34		4	59		4
10		4	35		4	60		4
11		4	36		4	61		4
12		4	37		4	62		4
13		4	38		4	63		4
14		4	39		4	64		4
15		4	40		4	65		4
16		4	41		4	66		4
17		4	42		4	67		4
18		4	43		4	68		4
19		4	44		4			
20		4	45		4			
21		4	46		4			
22		4	47		4			
23		4	48		4			
24		4	49		4			
25		4	50		4			

Notes: All sealing plates have been replaced with new ones.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. “E”	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 64 of 83	

Form Ref. N°: D5TR0075

TURBINE 1ST STAGE BLADES – GENERAL INFORMATION


DRAWING N°: 4227T80 - 4227T84

BLADES MATERIAL:

ASSEMBLY

Pos.	moment weight	serial number	Pos.	moment weight	serial number	Pos.	moment weight	serial number	Pos.	moment weight	serial number
1	5689	K07302	29	5727	K07346	57	5715	K07171	85	5690	K07268
2	5733	K07517	30	5703	K07208	58	5706	K07238	86	5715	K07435
3	5704	K07297	31	5700	K07255	59	5712	K07250	87	5672	K07257
4	5705	K07282	32	5725	K07389	60	5726	K07499	88	5686	K07408
5	5697	K07256	33	5707	K07360	61	5711	K07450	89	5733	K07494
6	5714	K07202	34	5719	K07379	62	5718	K07340	90	5738	K07399
7	5689	K07279	35	5693	K07263	63	5734	K07315	91	5719	K07354
8	5711	K07430	36	5725	K07515	64	5708	K07258	92	5705	K07262
9	5735	K07432	37	5720	K07513	65	5727	K07505	93	5719	K07504
10	5723	K07229	38	5711	K07243	66	5711	K07409	94	5701	K07248
11	5712	K07213	39	5721	K07394	67	5707	K07249	95	5722	K07363
12	5706	K07500	40	5696	K07295	68	5723	K07320	96	5711	K07458
13	5695	K07272	41	5709	K07167A	69	5718	K07348	97	5729	K07419
14	5732	K07503	42	5706	K07237	70	5708	K07299	98	5727	K07226
15	5719	K07193	43	5702	K07428	71	5698	K07270	99	5701	K07424
16	5713	K07177	44	5740	K07502	72	5742	K07188	100	5712	K07283
17	5704	K07197	45	5702	K07484	73	5734	K07342	101	5719	K07416
18	5716	K07244	46	5708	K07390	74	5708	K07395	102	5764	K0100115
19	5699	K07239	47	5720	K07325	75	5709	K07305	103	5701	K07440
20	5704	K07326	48	5685	K07298	76	5747	K07497			
21	5722	K07441	49	5703	K07167	77	5725	K07251			
22	5710	K07516	50	5710	K07264	78	5700	K07274			
23	5717	K07335	51	5733	K07356	79	5705	K07493			
24	5712	K07240	52	5711	K07405	80	5694	K07277			
25	5706	K07387	53	5702	K07267	81	5696	K07423			
26	5711	K07403	54	5698	K07203	82	5714	K07415			
27	5756	K07496	55	5712	K07223	83	5717	K07187			
28	5719	K07422	56	5714	K07380	84	5708	K07216			

Notes: The Moment weight is expressed in Kgm.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 65 of 83	

Form Ref. N°: D5TR0075-A

TURBINE 2ND STAGE BLADES – GENERAL INFORMATION


DRAWING N°: 4227T81 - 4227T86

BLADES MATERIAL:

ASSEMBLY

Pos.	moment weight	serial number	Pos.	moment weight	serial number	Pos.	moment weight	serial number	Pos.	moment weight	serial number
1	1535	900U2412	29	1511	900U2459	57	1427	900U2441	85	1521	900U2369
2	1474	900U2442	30	1484	900U2425	58	1529	900U2373	86	1494	900U2402
3	1501	900U2388	31	1542	900U2380	59	1526	900U2413	87	1522	900U2382
4	1498	900U2403	32	1522	900U2431	60	1516	900U2419	88	1462	900U2423
5	1577	900U2958	33	1509	900U2422	61	1511	900U2427	89	1520	900U2440
6	1514	900U2366	34	1515	900U2371	62	1505	900U2454	90	1492	900U2460
7	1512	900U2445	35	1536	900U2391	63	1511	900U2452	91	1500	900U2401
8	1516	900U2372	36	1513	900U2420	64	1516	900U2381	92	1493	900U2426
9	1508	900U2444	37	1518	900U2367	65	1519	900U2443	93	1508	900U2435
10	1496	900U2383	38	1512	900U2421	66	1511	900U2429			
11	1528	900U2394	39	1503	900U2400	67	1528	900U2415			
12	1483	900U2384	40	1502	900U2416	68	1498	900U2424			
13	1518	900U2397	41	1484	900U2390	69	1503	900U2461			
14	1518	900U2399	42	1486	900U2411	70	1508	900U2395			
15	1533	900U2450	43	1510	900U2417	71	1507	900U2414			
16	1500	900U2410	44	1527	900U2418	72	1521	900U2386			
17	1499	900U2456	45	1489	900U2408	73	1496	900U2432			
18	1500	900U2457	46	1534	900U2439	74	1515	900U2446			
19	1523	900U2437	47	1513	900U2428	75	1521	900U2404			
20	1495	900U2392	48	1500	900U2453	76	1491	900U2398			
21	1503	900U2448	49	1494	900U2447	77	1494	900U2374			
22	1502	900U2458	50	1515	900U2370	78	1525	900U2396			
23	1536	900U2451	51	1499	900U2368	79	1528	900U2455			
24	1514	900U2438	52	1524	900U2385	80	1520	900U2379			
25	1524	900U2405	53	1527	900U2375	81	1521	900U2449			
26	1499	900U2406	54	1540	900U2407	82	1512	900U2389			
27	1507	900U2393	55	1520	900U2365	83	1517	900U2430			
28	1496	900U2377	56	1506	900U2378	84	1526	900U2409			

Notes: The Moment weight is expressed in Kgm.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. “E”	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 66 of 83	

Form Ref. N°: D5TR0075-B

TURBINE 3RD STAGE BLADES – GENERAL INFORMATION


DRAWING N°: 4277T26 - 4227T82

BLADES MATERIAL:

DISASSEMBLY

Pos.	moment weight	serial number	Pos.	moment weight	serial number	Pos.	moment weight	serial number
1		900T3269	26		900T3281	51		900T3264
2		900T3286	27		900T3228	52		900T3233
3		900T3293	28		900T3258	53		900T3266
4		900T3232	29		900T3260	54		900T3271
5		900T3239	30		900T3290	55		900T3288
6		900T3272	31		900T3276	56		900T3238
7		900T3244	32		900T3267	57		900T3311
8		900T3303	33		900T3308	58		900T3242
9		900T3251	34		900T3241	59		900T3289
10		900T3236	35		900T3229	60		900T3106
11		900T3302	36		900T3249	61		900T3307
12		900T3282	37		900T3247	62		900T3262
13		900T3296	38		900T3246	63		900T3268
14		900T3256	39		900T3259	64		900T3300
15		900T3285	40		900T3500	65		900T3270
16		900T3243	41		900T3295	66		900T3235
17		900T3257	42		900T3273	67		900T3245
18		900T3299	43		900T3287	68		900T3352
19		900T3291	44		900T3261	69		900T3301
20		900T3283	45		900T3274	70		900T3277
21		900T3294	46		900T3234	71		900T3240
22		900T3375	47		900T3275			
23		900T3252	48		900T3304			
24		900T3263	49		900T3298			
25		900T3306	50		900T3284			

Notes: The Moment weight is expressed in Kgm.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. “E”	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 67 of 83	
Form Ref. N°: D5TR0075-B			

TURBINE 3RD STAGE BLADES – GENERAL INFORMATION

DRAWING N°: 4277T26 - 4227T82


BLADES MATERIAL:

ASSEMBLY

Pos.	moment weight	serial number	Pos.	moment weight	serial number	Pos.	moment weight	serial number
1		900T3269	26		900T3281	51		900T3264
2		900T3286	27		900T3228	52		900T3233
3		900T3293	28		900T3258	53		900T3266
4		900T3232	29		900T3260	54		900T3271
5		900T3239	30		900T3290	55		900T3288
6		900T3272	31		900T3276	56		900T3238
7		900T3244	32		900T3267	57		900T3311
8		900T3303	33		900T3308	58		900T3242
9		900T3251	34		900T3241	59		900T3289
10		900T3236	35		900T3229	60		900T3106
11		900T3302	36		900T3249	61		900T3307
12		900T3282	37		900T3247	62		900T3262
13		900T3296	38		900T3246	63		900T3268
14		900T3256	39		900T3259	64		900T3300
15		900T3285	40		900T3500	65		900T3270
16		900T3243	41		900T3295	66		900T3235
17		900T3257	42		900T3273	67		900T3245
18		900T3299	43		900T3287	68		*K07126
19		900T3291	44		900T3261	69		900T3301
20		900T3283	45		900T3274	70		900T3277
21		900T3294	46		900T3234	71		900T3240
22		900T3375	47		900T3275			
23		900T3252	48		900T3304			
24		900T3263	49		900T3298			
25		900T3306	50		900T3284			

Notes: The Moment weight is expressed in Kgm.

*The blade in position number 68 (S/N: 900T3352) has been replaced with blade S/N: K07126.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 68 of 83	

Form Ref. N°: D5TR0075-C

TURBINE 4TH STAGE BLADES – GENERAL INFORMATION


DRAWING N°: 4217T25 – 4275T94

BLADES MATERIAL:

ASSEMBLY


Pos.	moment weight	serial number	Pos.	moment Weight	serial number	Pos.	moment weight	serial number
1		900UA4231	26		900UA4257	51		900UA4239
2		900UA4232	27		900UA4248	52		900UA4228
3		900UA4246	28		900UA4256	53		900UA4242
4		900UA4223	29		900UA4290	54		900UA4255
5		900UA4277	30		900UA4259	55		900UA4285
6		900UA4278	31		900UA4263	56		900UA4224
7		900UA4225	32		900UA4261	57		900UA4271
8		900UA4237	33		900UA4250	58		900UA4268
9		900UA4289	34		900UA4279	59		900UA4273
10		900UA4262	35		900UA4222	60		900UA4234
11		900UA4241	36		900UA4270	61		900UA4284
12		900UA4240	37		900UA4226	62		900UA4258
13		900UA4280	38		900UA4249	63		900UA4233
14		900UA4236	39		900UA4230	64		900UA4272
15		900UA4220	40		900UA4288	65		900UA4266
16		900UA4275	41		900UA4265	66		900UA4252
17		900UA4235	42		900UA4229	67		900UA4281
18		900UA4287	43		900UA4227	68		900UA4282
19		900UA4286	44		900UA4243			
20		900UA4274	45		900UA4254			
21		900UA4245	46		900UA4253			
22		900UA4267	47		900UA4260			
23		900UA4264	48		900UA4238			
24		900UA4283	49		900UA4221			
25		900UA4251	50		900UA4247			

Notes: The Moment weight is expressed in Kgm.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE 3RD STAGE BLADES - INSPECTION

S/N: 900T3306	DWG: 4277T26	POSITION 25	MOM. WEIGHT	FIRING HRS 23638	STARTS NO 959
-------------------------	------------------------	-----------------------	--------------------	----------------------------	-------------------------




Position	Damage description	Position	Damage description
1	Dim. 10 x 3 mm	8	
2		9	
3		10	
4		11	
5		12	
6		13	
7		14	

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE 3RD STAGE BLADES – INSPECTION

S/N: 900T3289	DWG: 4277T26	POSITION 59	MOM. WEIGHT	FIRING HRS 23638	STARTS NO 959
-------------------------	------------------------	-----------------------	--------------------	----------------------------	-------------------------




Position	Damage description	Position	Damage description
1	Dim. 8 x 6 mm	8	
2		9	
3		10	
4		11	
5		12	
6		13	
7		14	

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI	<i>[Handwritten Signature]</i>	I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE 3RD STAGE BLADES - INSPECTION

S/N:	DWG:	POSITION	MOM. WEIGHT	FIRING HRS	STARTS NO
900T3106	4277T26	60		23638	959




Position	Damage description	Position	Damage description
1	Dim. 9 x 4 mm	8	
2		9	
3		10	
4		11	
5		12	
6		13	
7		14	

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE 3RD STAGE BLADES - INSPECTION

S/N:	DWG:	POSITION	MOM. WEIGHT	FIRING HRS	STARTS NO
900T3268	4277T26	63		23638	959




Position	Damage description	Position	Damage description
1	L=20 mm	8	
2		9	
3		10	
4		11	
5		12	
6		13	
7		14	

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE 3RD STAGE BLADES - INSPECTION



S/N:	DWG:	POSITION	MOM. WEIGHT	FIRING HRS	STARTS NO
900T3352	4277T26	68		23638	959



Position	Damage description	Position	Damage description
1	L= 35 mm	8	
2		9	
3		10	
4		11	
5		12	
6		13	
7		14	

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE 1ST STAGE VANE HOLDER – SPACERS AND SEALS



CONDITIONS:

I = Deposits
 B = Burned
 F = Fretted
 C = Cracked
 CS = Corrosion

ACTIONS:


N = No action required
 R = Repaired/Cleaned
 RN = Replaced by a new one

Pos n°	Segment		Seal between segments		Pos n°	Segment		Seal between segments		Pos n°	Segment		Seal between segments	
	Cond.	Action	Cond.	Action		Cond.	Action	Cond.	Action		Cond.	Action	Cond.	Action
1	CS	R			21	CS	R			41	CS	R		
2	CS	R			22	CS	R			42	CS	R		
3	CS	R			23	CS	R			43	CS	R		
4	CS	R			24	CS	R			44	CS	R		
5	CS	R			25	CS	R			45	CS	R		
6	CS	R			26	CS	R			46	CS	R		
7	CS	R			27	CS	R			47	CS	R		
8	CS	R			28	CS	R			48	CS	R		
9	CS	R			29	CS	R			49	CS	R		
10	CS	R			30	CS	R			50	CS	R		
11	CS	R			31	CS	R			51	CS	R		
12	CS	R			32	CS	R			52	CS	R		
13	CS	R			33	CS	R			53	CS	R		
14	CS	R			34	CS	R			54	CS	R		
15	CS	R			35	CS	R			55	CS	R		
16	CS	R			36	CS	R			56	CS	R		
17	CS	R			37	CS	R			57	CS	R		
18	CS	R			38	CS	R			58	CS	R		
19	CS	R			39	CS	R			59	CS	R		
20	CS	R			40	CS	R			60	CS	R		

Notes: Light corrosion and deposits eliminated through sandblast. All the seals have been found in good conditions.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE 2ND STAGE VANE HOLDER – SPACERS AND SEALS



CONDITIONS:

I = Deposits
 B = Burned
 F = Fretted
 C = Cracked
 CS = Corrosion

ACTIONS:

N = No action required
 R = Repaired/Cleaned
 RN = Replaced by a new one

Pos n°	Segment		Seal between segments		Pos n°	Segment		Seal between segments		Pos n°	Segment		Seal between segments	
	Cond.	Action	Cond.	Action		Cond.	Action	Cond.	Action		Cond.	Action	Cond.	Action
1	CS	R			21	CS	R			41	CS	R		
2	CS	R			22	CS	R			42	CS	R		
3	CS	R			23	CS	R			43	CS	R		
4	CS	R			24	CS	R			44	CS	R		
5	CS	R			25	CS	R			45	CS	R		
6	CS	R			26	CS	R			46	CS	R		
7	CS	R			27	CS	R			47	CS	R		
8	CS	R			28	CS	R			48	CS	R		
9	CS	R			29	CS	R			49	CS	R		
10	CS	R			30	CS	R			50	CS	R		
11	CS	R			31	CS	R			51	CS	R		
12	CS	R			32	CS	R			52	CS	R		
13	CS	R			33	CS	R			53	CS	R		
14	CS	R			34	CS	R			54	CS	R		
15	CS	R			35	CS	R			55	CS	R		
16	CS	R			36	CS	R			56	CS	R		
17	CS	R			37	CS	R			57	CS	R		
18	CS	R			38	CS	R			58	CS	R		
19	CS	R			39	CS	R			59	CS	R		
20	CS	R			40	CS	R			60	CS	R		


Notes: Light corrosion and deposits eliminated through sandblast. All the seals have been found in good conditions.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 76 of 83	

Form Ref. No.: D5TR0085-B

TURBINE 3RD STAGE VANE HOLDER – SPACERS AND SEALS



CONDITIONS:

- I = Deposits
- B = Burned
- F = Fretted
- C = Cracked

ACTIONS:



- N = No action required
- R = Repaired/Cleaned
- RN = Replaced by a new one

Pos n°	Segment		Seal between segments		Pos n°	Segment		Seal between segments		Pos n°	Segment		Seal between segments	
	Cond.	Action	Cond.	Action		Cond.	Action	Cond.	Action		Cond.	Action	Cond.	Action
1	I	R			13	I	R			25	I	R		
2	I	R			14	I	R			26	I	R		
3	I	R			15	I	R			27	I	R		
4	I	R			16	I	R			28	I	R		
5	I	R			17	I	R			29	I	R		
6	I	R			18	I	R			30	I	R		
7	I	R			19	I	R			31	I	R		
8	I	R			20	I	R			32	I	R		
9	I	R			21	I	R			33	I	R		
10	I	R			22	I	R			34	I	R		
11	I	R			23	I	R			35	I	R		
12	I	R			24	I	R			36	I	R		

Notes: All the spacers and seals have been found in good conditions.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TURBINE 4TH STAGE VANE HOLDER – SPACERS AND SEALS



CONDITIONS:

I = Deposits
 B = Burned
 F = Fretted
 C = Cracked

ACTIONS:

N = No action required
 R = Repaired/Cleaned
 RN = Replaced by a new one

Pos n°	Segment		Seal between segments		Pos n°	Segment		Seal between segments		Pos n°	Segment		Seal between segments	
	Cond.	Action	Cond.	Action		Cond.	Action	Cond.	Action		Cond.	Action	Cond.	Action
1	I	R			13	I	R			25	I	R		
2	I	R			14	I	R			26	I	R		
3	I	R			15	I	R			27	I	R		
4	I	R			16	I	R			28	I	R		
5	I	R			17	I	R			29	I	R		
6	I	R			18	I	R			30	I	R		
7	I	R			19	I	R			31	I	R		
8	I	R			20	I	R			32	I	R		
9	I	R			21	I	R			33	I	R		
10	I	R			22	I	R			34	I	R		
11	I	R			23	I	R			35	I	R		
12	I	R			24	I	R			36	I	R		


Notes: All the spacers and seals have been found in good conditions.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 78 of 83	

Form Ref. No.: D5TR0090

TURBINE 1ST STAGE VANE HOLDER (BLADE RING) – GENERAL INFORMATION



- 1.1 Component dismantling: **Row Vanes, Spacer Ring Segments**
- 1.2 Deposits removal: **Yes**
- 1.3 Blending
- 1.4 Threaded holes re-taping: **Yes**
- 1.5 Components check: **Yes, Visual test**
- 1.6 Washing with solvent: **NO- Cleaned With Washing Machine**
- 1.7 Component repairing: **NO**
- 1.8 Preservation: **NO**


Notes:

<i>TurboCare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 79 of 83	

Form Ref. No.: D5TR090-A

TURBINE 2ND STAGE VANE HOLDER (BLADE RING) – GENERAL INFORMATION



- 1.1 Component dismantling: **Row Vanes, Spacer Ring Segments**
- 1.2 Deposits removal: **Yes**
- 1.3 Blending
- 1.4 Threaded holes re-taping: **Yes**
- 1.5 Components check: **Yes, Visual test**
- 1.6 Washing with solvent: **NO- Cleaned With Washing Machine**
- 1.7 Component repairing: **NO**
- 1.8 Preservation: **NO**


Notes:

<i>TurboCare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 80 of 83	

Form Ref. No.: D5TR0090-B

TURBINE 3RD STAGE VANE HOLDER (BLADE RING) – GENERAL INFORMATION



- 1.9 Component dismantling: **Row Vanes**
- 1.10 Deposits removal: **Yes**
- 1.11 Blending
- 1.12 Threaded holes re-taping: **Yes**
- 1.13 Components check: **Yes, Visual test**
- 1.14 Washing with solvent: **NO- Cleaned With Washing Machine**
- 1.15 Component repairing: **NO**
- 1.16 Preservation: **NO**


Notes:

<i>TurboCare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
M. PANETTA/V. PALMIERI	<i>[Handwritten Signature]</i>	I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 81 of 83	

Form Ref. No.: D5TR0090-C

TURBINE 4TH STAGE VANE HOLDER (BLADE RING) – GENERAL INFORMATION



- 1.17 Component dismantling: **Row Vanes**
- 1.18 Deposits removal: **Yes**
- 1.19 Blending
- 1.20 Threaded holes re-taping: **Yes**
- 1.21 Components check: **Yes, Visual test**
- 1.22 Washing with solvent: **NO- Cleaned With Washing Machine**
- 1.23 Component repairing: **NO**
- 1.24 Preservation: **NO**


Notes:

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI	<i>[Handwritten Signature]</i>	I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 82 of 83	

Form Ref. No.: D5TR0091

ROTOR COOLING FLEXIBLE PIPES – INSPECTION



TUBE N°	PENETRANT TEST ON WELDED JOINTS	VISUAL CHECK	DAMAGE DESCRIPTION	REPAIRED	REPLACED
1	OK	OK			
2	OK	OK			
3	OK	OK			
4	OK	OK			


NOTES: All the rotor cooling flexible pipes have been found in good conditions.

TurboCare Representative	Signature	Report	Date
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 29/01/08	Rev.13
		Power Plant: EX TURBIGO GT S/N: 358 – GR. "E"	
Customer: I P S A	Turbine Type: TG50D5std	Sheet: 83 of 83	

Form Ref. No.: D5TR0096

TURBINE DISKS – INSPECTION



TEST CARRIED OUT	PENETRANT TEST P T	VISUAL CHECK V T	MAGNETIC TEST M T
1ST STAGE	OK	OK	
2ND STAGE	OK	OK	
3RD STAGE	OK	OK	
4TH STAGE	OK	OK	

NOTES: No indications have been detected on disks surfaces and grooves.

<i>TurboCare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
M. PANETTA/V. PALMIERI		I-TLE/TG50D5-358/TR012-08	03/09/2008