


TurboCare[®]

TG50D5 – Std
GT Serial Number 354

POWER PLANT ex Turbigio group “G”

Major Overhaul



TECHNICAL REPORT
TR014-08

TURIN 03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev. 11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 2 of 71	

Issued by
Operations – Field Service

Document
I-TLG/TG50D5-354/TR014-08

Title: TG50D5 Std S/N:354 GR “G” – MAJOR OVERHAUL

Author/s
E.FERRARA


Approved by
F.FRANCESCHINI

SUMMARY

1. FOREWORD
2. COMPRESSOR INSPECTION
3. COMBUSTOR SYSTEM INSPECTION
4. TURBINE INSPECTION
5. GT ROTOR INSPECTION
6. BEARING INSPECTION
7. AIR & OIL SEALS INSPECTION
8. DIFFUSER BODY & EXHAUST MANIFOLD FRONT END
9. CONCLUSION
10. LIST OF ATTACHMENTS FOR TG50 MAJOR OVERHAUL

Customer Distribution	Circulation List	Sign	Date
	Ing. Merola		

Circulation copy to return back to: Operations – Field Service

<i>Turbocare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 3 of 71	

1.0 - FOREWORD

The gas turbine TG50D5 S/N 354, Unit GR "G" at Turbigio Power Plant, was definitively stopped on 03/05/2006. Major overhaul was started on 01/10/2007 and finished on 05/03/2008 in Porto Marghera (VE). All the activities have been done without removal the rotor, by TurboCare employees. The turbine was running on gas fuel, and at the time of the stoppage, it had cumulated the following running data:

BHG:	Firing hours on fuel gas base	25738
PHG:	Firing hours on gas peak load	9
BHO:	Firing hours on liquid fuel base	64
PHO:	Firing hours on liquid peak load	6
NS:	Number of start	1183
ET:	Number of emergency trip	187
LR:	Number of load rejection	73
EH:	Equivalent hours	49064


2.0 COMPRESSOR INSPECTION

2.1 COMPRESSOR BODIES

The compressor bodies and the air inlet casing upper part, were removed and the relevant compressor diaphragms disassembled. Upper and lower parts of the bodies were found in good conditions, only cleaning was required. The IGV system, on the inlet casing, was checked and found in good condition too, the relevant mechanism was lubricated at the end of the overhaul.

2.2 COMPRESSOR DIAPHRAGMS

Diaphragms were thoroughly cleaned by steam, and checked according to the Field Inspection and Repair Guidelines F I 028/94e. Some of them were found with rubbing marks and air seal surface corrosion, slight dent and small limited area without coating on vane coated surface. Moreover, diaphragms from first to fifth have been ultrasonic tested on the outer shroud tenon welding, reporting no problems. The corrosion was removed by grinding and polishing, finally the diaphragms were reassembled in the same positions. See pages from 22 to 23 for assembly clearances.

<i>Turbocare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 4 of 71	

3.0 - COMBUSTION SYSTEM INSPECTION

All the components of the combustion system have been disassembled and sent to TurboCare factory for inspections and repair if any. Combustion System components ready to be reassembled, Transitions Pieces, Combustor Baskets, Cylinders, Cross-Flame Tubes etc, have been received in Marghera and consequently assembled. Assembly activities have been performed according to the procedures mentioned on the TG50D5 Instruction & Maintenance Manual. For assembly data and clearances, see pages from 37 to 44

Note: The Dual Fuel Injectors have been put in preservation, and therefore they have not been reassembled. In place of the Injectors, temporarily steel blind flanges have been installed for turbine protection and preservation.

3.1 - ROTOR COOLING FLEXIBLE PIPES

The four flexible pipes, have been removed from the inside combustor body, cleaned by steam and inspected. The coils were visually tested while the welded joints were contrast dye checked. No indications or damaged have been found, thus the components have been reassembled at the same positions.

3.2 - DIFFUSER COMPRESSOR BODY AND INTERMEDIATE SHAFT GUARD

The upper part, was removed from the inside combustor body, cleaned and inspected. No problems have been found on the remaining air seals. For assembling data see page 30.

4.0 - TURBINE INSPECTION

The Turbine Body upper part has been removed, thoroughly cleaned and visually inspected. No problems were reported.

4.1 - BLADE RINGS


The Blade Rings 1st, 2nd, 3rd and 4th stage upper and lower part have been removed, fully dismantled, cleaned and the relevant components visually inspected. The spacer ring segments, 1st and 2nd row have been found with a light corrosion, which was eliminated through sandblasting. No other particular problems were reported, thus all the components were put back in the same positions. See pages from 66 to 69

4.2 - 1st AND 2nd STAGE VANE SEGMENTS

The vanes have been removed from the blade ring and sent to TurboCare factory for inspections and repair. Two complete set of vanes ready to be assembled, were received in Marghera and consequently installed on the engine. For the general information you see page 45

4.3 – 3rd STAGE VANE SEGMENTS

The vanes have been removed, cleaned and inspected, according to prescriptions of the Field Inspection and Repair Guidelines F I 013/94e. The inspection, reported some cracks on the vane segments third row. The dimensions and positions of the defects, were falling into the acceptance criteria of the F I 013/94e, therefore no actions were taken and the vanes were put back in the same position without repairing.

<i>Turbocare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 5 of 71	

For the general information and defects location chart, see pages 46 to 61

4.4 – 4th STAGE VANE SEGMENTS

Vanes have been removed cleaned and inspected, according to prescriptions of the Field Inspection and Repair Guidelines F I 013/94e.

Vanes were free of defect, thus they were put back in the same position cleared for running.

For general information see page 45.

4.5 – TURBINE AIR LABYRINTH SEAL HOLDER

Turbine Air Labyrinth Seal Holder 2nd, 3rd and 4th stage have been removed from the blade ring and sent to TurboCare factory for inspections and repair. After repair, they have been received at Marghera and reassembled. For assembling data see page 35.

5.0 GT ROTOR INSPECTION

Before removal of any bolt, first stage compressor and fourth stage turbine blades tip clearances have been checked out. The axial and radial clearances of the spindle were registered either at the opening or at the closing of the engine. Spindle position was with the compressor side thrust pads loaded and with the diffuser and inlet casing firmly close. See pages from 18 to 34

5.1 COMPRESSOR SHAFT - DISKS AND BLADES INSPECTION

The Compressor section, was thoroughly cleaned by diesel oil and steam, the following visual inspection reported some minor damage on few blades which have been repaired according to the Field Inspection and Repair Guidelines F I 014/94e.

5.2 TURBINE ROTOR INSPECTION

5.2.1 - TURBINE ROTOR DISKS

The turbine rotor disks have been thoroughly cleaned with a steel brush and inspected by contrast dye check. No indications were reported on the four disks and the relevant fir tree.


The disk to disk air baffle seals were reporting an extensive wear all around and they have been replaced according to air baffles replacement procedure FI 001-03e.

5.2.2 - TURBINE ROTATING BLADES

5.2.2.1 - 1ST STAGE BLADES

The 1st stage turbine rotating blades have been removed from the disks and sent to TurboCare factory for inspections and repair. A complete set of blades ready to be assembled was received in Marghera and consequently installed on the rotor. Locking plates and seal pins were sandblasted and checked according to the Field Inspection and Repair Guidelines FI 007/85e. No defects were detected.

For the general information, see page 62

<i>Turbocare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 6 of 71	

5.2.2 - 2ND STAGE BLADES

The 2nd stage turbine rotating blades have been removed from the disks and sent to TurboCare factory for inspections and repair. A complete set of blades ready to be assembled was received in Marghera and consequently installed on the rotor. Locking plates inlet and exhaust side and seal pins were sandblasted and checked according to the field inspection and repair guidelines FI 007/85e.

No defects were detected.

For the general information, see page 63

5.2.2.2 - 3RD STAGE BLADES

The 3rd stage turbine rotating blades have been removed from the disks, cleaned by sandblast and contrast dye checked. No indications were found, thus the blades were put back in the same position cleared for running. For general information data see page 63.

Inlet and exhaust side locking plates and seal pins were sandblasted and checked out according to the field inspection and repair guidelines FI 007/85e. Ten locking plates outlet side were replaced because out of the acceptance criteria. All the other components have been reassembled. For the general information, see page 64

5.2.2.3 - 4TH STAGE BLADES

The 4th stage turbine rotating blades have been removed from the disks, cleaned by sandblast and contrast dye checked. As for the third stage the blades were found free of defect thus put back in the same positions cleared for running. For general information data, see page.64.

Inlet and exhaust side locking plates and seal pins were sandblasted and checked out according to the field inspection and repair guidelines FI 007/85e.

Fifty-two locking plates outlet side were replaced because out of the acceptance criteria. All the other components have been reassembled. For the general information, see page 65

6.0 - BEARINGS INSPECTION


6.1 - JOURNAL BEARING

Both compressor and turbine side bearings have been removed and completely dismantled.

Ultrasonic test and contrast dye check have been performed on the tilting pads Babbitt metal and the floating seals, the pins spherical and the relevant liners were contrast dye check too. Due to the non perfect sealing between the pads and the Babbitt metal both bearing have been replaced with new ones. For the general information, see pages17

6.2 - THRUST BEARING

Both parts turbine and generator side have been removed, completely dismantled cleaned and inspected. N.D.T. (ultrasonic test and contrast dye check) were carried out on the thrust pads and found in good condition. No problems have been found on the leveling links, pillars and retainer pads. All components have been reinstalled in the same positions. The two Oil Seal Rings left and right groove were replaced.

<i>Turbocare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 7 of 71	

7. AIR & OIL SEALS INSPECTION

All air and oil seals assembled on Inlet Casing and Diffuser Body have been removed, cleaned and inspected. The seals on Inlet Casing have been found damaged and replaced with the new ones. No other problems have been found on remain seals on Diffuser Body. For assembling data see pages 19-20-21-30.


8. DIFFUSER BODY AND EXHAUST MANIFOLD FRONT END

The diffuser casing and the exhaust manifold have been cleaned and inspected according to the Field Inspection and Repair Guidelines FI 009/85e. Dye check has been performed on the exhaust diffuser strut shield and exhaust manifold access airfoil. Some cracks were found on the welded joint and field repaired by, as per the FI above mentioned.

9. CONCLUSION

All the maintenance activities on the engine have been performed according to the field inspection and repair guidelines applicable and the TG50D5 instruction & maintenance manual. After the activities completion the complete engine was put into preservation for long term storage.

Notice that the spindle axial travel must be double checked at the time of re-location of the engine on a solid foundation block.


<i>Turbocare Representative</i>	<i>Signature</i>	<i>Report</i>	<i>Date</i>
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 8 of 71	

Form Ref. No.: D5TR0000D


12. LIST OF ATTACHMENTS FOR TG50 MAJOR OVERHAUL

Form Reference	TITLE	From page	To page
Form Ref. No.: D5TR0001	TURBINE INFORMATION		
Form Ref. No.: D5TR0002	REPLACED PARTS LIST	13	16
Form Ref. No.: D5TR0005	JOURNAL BEARINGS		
Form Ref. No.: D5TR0005A	JOURNAL BEARINGS – ULTRASONIC INSPECTION		
Form Ref. No.: D5TR0006	WHITE METAL		
Form Ref. No.: D5TR0007	JOURNAL BEARINGS – LEVELLING BLOCKS	17	
Form Ref. No.: D5TR0008	JOURNAL BEARINGS – SHAFT DIAMETER MEASUREMENT		
Form Ref. No.: D5TR0010	THRUST BEARING		
Form Ref. No.: D5TR0011	THRUST BEARING		
Form Ref. No.: D5TR0012	THRUST BEARING – AXIAL CLEARANCE		
Form Ref. No.: D5TR0013	THRUST BEARING PADS		
Form Ref. No.: D5TR0014	THRUST BEARING COMPRESSOR SIDE – ULTRASONIC INSPECTION		
Form Ref. No.: D5TR0014A	THRUST BEARING GENERATOR SIDE – ULTRASONIC INSPECTION		
Form Ref. No.: D5TR0015	ALIGNMENT CHECK - PARALLELISM		
Form Ref. No.: D5TR0016	ALIGNMENT - CONCENTRICITY		
Form Ref. No.: D5TR0020	1 st STAGE COMPRESSOR AND 4 th STAGE TURBINE BLADES CLEARANCES	18	
Form Ref. No.: D5TR0021	COMPRESSOR ROTOR CLEARANCES - BEFORE OVERHAUL	19	
Form Ref. No.: D5TR0021-A	COMPRESSOR ROTOR CLEARANCES - AFTER OVERHAUL	20	
Form Ref. No.: D5TR0022	INLET CASING LABYRINTH SEALS - DETAIL "A"	21	
Form Ref. No.: D5TR0023	COMPRESSOR ROTOR CLEARANCES - DETAIL "B" - BEFORE OVERHAUL	22	
Form Ref. No.: D5TR0023-A	COMPRESSOR ROTOR CLEARANCES - DETAIL "B" - AFTER OVERHAUL	23	

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008


TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 9 of 71	

Form Reference	TITLE	From page	To page
Form Ref. No.: D5TR0024	COMPRESSOR ROTOR CLEARANCES – DETAIL “C” – BEFORE OVERHAUL	24	
Form Ref. No.: D5TR0024-A	COMPRESSOR ROTOR CLEARANCES – DETAIL “C” – AFTER OVERHAUL	25	
Form Ref. No.: D5TR0025	COMPRESSOR VANES / RETAINING SCREWS CLEARANCES		
Form Ref. No.: D5TR0026	TURBINE ROTOR CLEARANCES – RIGHT SIDE – BEFORE OVERHAUL	26	
Form Ref. No.: D5TR0026-A	TURBINE ROTOR CLEARANCES – RIGHT SIDE – AFTER OVERHAUL	27	
Form Ref. No.: D5TR0026-B	TURBINE ROTOR CLEARANCES – LEFT SIDE – BEFORE OVERHAUL	28	
Form Ref. No.: D5TR0026-C	TURBINE ROTOR CLEARANCES – LEFT SIDE – AFTER OVERHAUL	29	
Form Ref. No.: D5TR0026-D	INTERMEDIATE SHAFT GUARD LABYRINTH SEALS – DETAIL “F”	30	
Form Ref. No.: D5TR0026-E	TURBINE ROTOR CLEARANCES – “DETAIL G” RIGHT SIDE – BEFORE OVERHAUL	31	
Form Ref. No.: D5TR0026-F	TURBINE ROTOR CLEARANCES – “DETAIL G” RIGHT SIDE – AFTER OVERHAUL	32	
Form Ref. No.: D5TR0026-G	TURBINE ROTOR CLEARANCES – “DETAIL G” LEFT SIDE – BEFORE OVERHAUL	33	
Form Ref. No.: D5TR0026-H	TURBINE ROTOR CLEARANCES – “DETAIL G” LEFT SIDE – AFTER OVERHAUL	34	
Form Ref. No.: D5TR0027	2 nd , 3 rd & 4 th STAGE AIR SEAL RING CENTERING	35	
Form Ref. No.: D5TR0028	BLADE RING CENTERING - with blade tip used only one blade		
Form Ref. No.: D5TR0030	TURBINE SUPPORTS – INSPECTION		
Form Ref. No.: D5TR0031	COMPRESSOR VANES – DEFECTS AND REPAIRS		
Form Ref. No.: D5TR0032	COMPRESSOR SEALS AND DISCS – VISUAL INSPECTION	36	
Form Ref. No.: D5TR0040	STANDARD COMBUSTOR BASKET – IDENTIFICATION OF COMPONENTS	37	
Form Ref. No.: D5TR0040-A	DLN COMBUSTOR BASKET – IDENTIFICATION OF COMPONENTS		
Form Ref. No.: D5TR0040-B	DLN COMBUSTOR BASKET		
Form Ref. No.: D5TR0041	COMBUSTOR BASKET – DISASSEMBLY		
Form Ref. No.: D5TR0041-A	COMBUSTOR BASKET – ASSEMBLY	38	
Form Ref. No.: D5TR0042	STANDARD COMBUSTOR BASKET – INSPECTION		
Form Ref. No.: D5TR0042-A	DLN COMBUSTOR BASKET – INSPECTION		

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008


TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 10 of 71	

Form Reference	TITLE	From page	To page
Form Ref. No.: D5TR0043	CYLINDERS AND COLLARS – INSPECTION		
Form Ref. No.: D5TR0045	TRANSITION PIECES – AT DISASSEMBLY		
Form Ref. No.: D5TR0045-A	TRANSITION PIECES – AT REASSEMBLY	39	
Form Ref. No.: D5TR0046-A	DLN TRANSITION PIECE – INSPECTION REPORT		
Form Ref. No.: D5TR0046-B	STANDARD TRANSITION PIECE – INSPECTION		
Form Ref. No.: D5TR0046-C	STANDARD TRANSITION PIECE – INSPECTION		
Form Ref. No.: D5TR0046-D	STANDARD TRANSITION PIECE – INSPECTION		
Form Ref. No.: D5TR0046-E	DLN TRANSITION PIECE – INSPECTION		
Form Ref. No.: D5TR0046-F	DLN TRANSITION PIECE – INSPECTION		
Form Ref. No.: D5TR0046-G	DLN TRANSITION PIECE – INSPECTION		
Form Ref. No.: D5TR0046-H	TRANSITION PIECE – INSPECTION		
Form Ref. No.: D5TR0047	TRANSITION PIECE LATERAL SEALS – CLEARANCES	40	
Form Ref. No.: D5TR0048	TRANSITION PIECES – ALIGNMENT CHECK	41	
Form Ref. No.: D5TR0049	DLN TRANSITION PIECES – BY PASS DUCT ALIGNMENT		
Form Ref. No.: D5TR0050	TRANSITION PIECES – INNER AND OUTER SEALS CLEARANCES	42	
Form Ref. No.: D5TR0051	TRANSITION PIECES – “C” SUPPORTS ASSEMBLY CLEARANCES	43	
Form Ref. No.: D5TR0055	DUAL FUEL INJECTOR – GENERAL INFORMATION		
Form Ref. No.: D5TR0055-A	DUAL FUEL INJECTOR – CLEARANCES		
Form Ref. No.: D5TR0055-B	DUAL FUEL INJECTOR – INSPECTION		
Form Ref. No.: D5TR0055-C	DLN FUEL INJECTOR – GENERAL INFORMATION		
Form Ref. No.: D5TR0060	CROSS FLAME TUBE – INSPECTION	44	
Form Ref. No.: D5TR0061	TURBINE VANES – CLEARANCES		
Form Ref. No.: D5TR0062	TURBINE VANES – SERIAL NUMBERS	45	
Form Ref. No.: D5TR0063	TURBINE 1 ST STAGE VANES – INSPECTION		

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008


TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 11 of 71	

Form Reference	TITLE	From page	To page
Form Ref. No.: D5TR0063-A	TURBINE 1 ST STAGE VANES – INSPECTION		
Form Ref. No.: D5TR0064	TURBINE 2 ND STAGE VANES – INSPECTION		
Form Ref. No.: D5TR0064-A	TURBINE 2 ND STAGE VANES – INSPECTION		
Form Ref. No.: D5TR0065	TURBINE 3 RD STAGE VANES – INSPECTION	46	61
Form Ref. No.: D5TR0065-A	TURBINE 3 RD STAGE VANES – INSPECTION		
Form Ref. No.: D5TR0066	TURBINE 4 TH STAGE VANES – INSPECTION		
Form Ref. No.: D5TR0066-A	TURBINE 4 TH STAGE VANES – INSPECTION		
Form Ref. No.: D5TR0070	TURBINE 1 ST STAGE BLADES – SEALING PLATES INSPECTION		
Form Ref. No.: D5TR0070-A	TURBINE 2 ND STAGE BLADES – SEALING PLATES INSPECTION		
Form Ref. No.: D5TR0070-B	TURBINE 3 RD STAGE BLADES – SEALING PLATES INSPECTION		
Form Ref. No.: D5TR0070-C	TURBINE 4 TH STAGE BLADES – SEALING PLATES INSPECTION		
Form Ref. No.: D5TR0075	TURBINE 1 ST STAGE BLADES – GENERAL INFORMATION	62	
Form Ref. No.: D5TR0075-A	TURBINE 2 ND STAGE BLADES – GENERAL INFORMATION	63	
Form Ref. No.: D5TR0075-B	TURBINE 3 RD STAGE BLADES – GENERAL INFORMATION	64	
Form Ref. No.: D5TR0075-C	TURBINE 4 TH STAGE BLADES – GENERAL INFORMATION	65	
Form Ref. No.: D5TR0080	TURBINE 1 ST STAGE BLADES – INSPECTION		
Form Ref. No.: D5TR0081	TURBINE 2 ND STAGE BLADES – INSPECTION		
Form Ref. No.: D5TR0082-A	TURBINE 3 RD STAGE BLADES – INSPECTION		
Form Ref. No.: D5TR0082-B	TURBINE 3 RD STAGE BLADES – INSPECTION		
Form Ref. No.: D5TR0083-A	TURBINE 4 TH STAGE BLADES – INSPECTION		
Form Ref. No.: D5TR0083-B	TURBINE 4 TH STAGE BLADES – INSPECTION		
Form Ref. No.: D5TR0085	TURBINE 1 ST STAGE VANE HOLDER – SPACERS AND SEALS	66	
Form Ref. No.: D5TR0085-A	TURBINE 2 ST STAGE VANE HOLDER – SPACERS AND SEALS	67	

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 12 of 71	

Form Reference	TITLE	From page	To page
Form Ref. No.: D5TR0085-B	TURBINE 3 ST STAGE VANE HOLDER – SPACERS AND SEALS	68	
Form Ref. No.: D5TR0085-C	TURBINE 4 ST STAGE VANE HOLDER – SPACERS AND SEALS	69	
Form Ref. No.: D5TR0090	TURBINE 1 ST STAGE VANE HOLDER (BLADE RING) – GENERAL INFORMATION		
Form Ref. No.: D5TR0090-A	TURBINE 2 ND STAGE VANE HOLDER (BLADE RING) – GENERAL INFORMATION		
Form Ref. No.: D5TR0090-B	TURBINE 3 RD STAGE VANE HOLDER (BLADE RING) – SPACERS AND SEALS		
Form Ref. No.: D5TR0090-C	TURBINE 4 TH STAGE VANE HOLDER (BLADE RING) – GENERAL INFORMATION		
Form Ref. No.: D5TR0091	ROTOR COOLING FLEXIBLE PIPES – INSPECTION	70	
Form Ref. No.: D5TR0096	TURBINE DISKS – INSPECTION	71	
Form Ref. No.: D5TR0096A	TURBINE DISKS – MAGNETIC TEST		
Form Ref. No.: D5TR0098	ROTOR BALANCING - BALANCING PLUGS POSITION		
Form Ref. No.: D5TR0100	TURBINE AND AUXILIARY MISURE		


Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 13 of 71	

Form Ref. No.: D5TR0002

REPLACED PARTS LIST

GROUP	ITEM	DESCRIPTION	QT.Y	DWG
1C	1	Oil seal ring	1	4213T45.001
1C	4	Oil seal ring	1	4213T77.001
1C	5	Oil seal ring	1	4213T61.001
1D	1	Compressor side bearing	1	4210T10.101
2A	4	Tie rod 2"- 8Nx350	1	4214T17.001
3A	1	Allen Screw M24x65	1	41T0060.565
3A	0	Rotor cooling Thermocouple	1	4217T380.001
3A	0-7	Gasket	1	4212T66.002
3A	0-8	Support for R-C thermocouple	1	4272T89.001
3A	0-2	Bracket for R-C thermocouple	40	4272T90.001
3A	0-3	Safety bracket for R-C thermocouple	1	4272T88.001
3A	0-6	Safety washer	8	4212T59.001
3A	9	Cap nut 2"1/2 8Nx130	2	4214T18.001
3A	10	Washer 2"1/2	1	4214T20.064
3A	11	Tie rod 2"1/2-8Nx380	1	4214T30.001
3A	19	Cap nut 3"-8N x 143	2	4214T25.001
3A	25	Nut 2"-8Nx111	2	4214T16.001
3A	26	Washer 2"	1	4214T20.048
3A	27	Tie rod 2" – 8Nx350	1	4214T17.001
3A	31	Special screw M 10	2	4214T63.001
3A	48	Allen screw M24x58	2	4214T61.001
3C	5	Nut M16	2	4214T82.016
3C	7	Calibrated bolt M16x50	2	4214T75.001
3C	8	Screw M16x30	3	41T0057.530


Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 14 of 71	

Form Ref. No.: D5TR0002

REPLACED PARTS LIST

GROUP	ITEM	DESCRIPTION	QT.Y	DWG
3C	10	Bushing	2	4217T24.001
3C	13	Pin diam. 4x17	18	4270T07.001
3C	15	Pin diam. 4x23	18	4270T08.001
3C	19	Special screw	72	4216T21.001
3C	20	Safety plate	36	4216T22.001
3C	22	Self locking nut M12x1,75	72	4214T43.001
3C	23	Safety plate	18	4216T49.001
3D	6	Self locking nut M10x1,5	48	4275T81.001
3D	7	Allen screw M10x45	10	41T0054.545
3D	12	Spring	3	4216T48.001
4A	56	Cap nut M52x3x120	2	4214T91.001
4A	57	Washer 2"1/4	2	4214T20.057
4A	58	Allen screw M52x3x380	2	41T0256.880
4B	14	Allen screw M20x60	2	41T0247.560
4B	22	Allen screw M12	5	4288T02.001
4B	36	Helicoil	2	4087T93.001
4D	5	Spring	12	4276T90.001
4D	29	Safety washer	8	4214T87.001
4D	30	Allen screw M10	4	4277T58.001
4D	41	Spacer ring segment retaining block	8	4088T03.001
4D	42	Allen screw M20x60	2	41T0247.560
4D	45	Countersunk head slotted screw M10	4	4088T07.001
4F	29	Safety washer	8	4214T87.001
4F	30	Special screw M10	2	4277T57.001


Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 15 of 71	

Form Ref. No.: D5TR0002


REPLACED PARTS LIST

GROUP	ITEM	DESCRIPTION	QT.Y	DWG
4F	39	Allen screw M20x60	2	41T0247.560
4G	21	Allen screw M12x30	2	41T0244.530
4G	29	Safety washer	8	4214T87.001
4G	30	Special screw	4	4277T57.001
4G	37	Straight pin diam. 6x25	4	41T0187.025
4G	38	Thermocouple guide	1	4277T03.001
5A	14	Air seal ring	1	4213T73.001
5A	16	Air seal ring	1	4213T27.001
5A	17	Oil seal ring	1	4213T70.001
5B	1	Turbine side bearing	1	4210T10.101
6	0-1	Gasket	1	4272T22.001
6	0-2	Gasket	2	4272T28.001
6	0-3	Gasket	2	4279T69.001
7D	4	Screw for plate first stage	4	4216T03.001
7D	5	Safety washer	16	4216T05.001
7D	7	Safety washer	16	4216T04.001
7D	12	Screw for plate	16	4216T01.001
7D	18	Safety washer	78	4216T06.001
7D	19	Screw for plate	78	4216T00.001
7D	25	Screw for plate	12	4216T02.001
7D	36	Sealing plate for 3 rd . stage blades	10	4223T45.001
7D	37	Sealing plate for 4 th . stage blades	52	4223T49.001
20	27	Cap nut M52x3x120	3	4214T91.001
20	28	Washer M52	3	4212T84.052

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

JOURNAL BEARINGS – LEVELLING BLOCKS

LEVELLING BLOCKS




LEVELLING BLOCKS CONDITIONS

BLOCK POSITION	1	2	3	4
COMPRESSOR SIDE	Good	Good	Good	Good
TURBINE SIDE	Good	Good	Good	Good

Notes:

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

1st STAGE COMPRESSOR AND 4th STAGE TURBINE BLADES CLEARANCES




BEFORE DISASSEMBLY				
Measuring point	1	2	3	4
Stage				
First stage compressor				
Fourth stage turbine				

AFTER REASSEMBLY				
Measuring point	1	2	3	4
Stage				
First stage compressor	2.3	2.3	2.2	2.0
Fourth stage turbine	7.5	7.1	7.0	7.6

Notes: READINGS MUST BE TAKEN ON COMPRESSOR FIRST STAGE BLADES AND TURBINE FOURTH STAGE BLADES, BETWEEN BLADES TIP AND CASINGS. THE TURBINE MUST BE COMPLETELY ASSEMBLED; ONLY THE INLET AND THE EXHAUST DUCTS UPPER PARTS, CAN BE MISSING.

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

COMPRESSOR ROTOR CLEARANCES - BEFORE OVERHAUL




LEFT											
Position		F	G	H	L	M	N	P	Q	R	S
Readings				0,2	0,19		0,95	1,0	---	7,5	
Permitted Clearances (diameter)	Min.	1,28	1,28	0,16	0,16	0,35	0,97	0,97	23,8	5,50	11,17
	Max	1,44	1,44	0,22	0,22	0,61	1,07	1,07	26,32	7,65	(Ref.)

RIGHT											
Position		F	G	H	L	M	N	P	Q	R	S
Readings				n.a	n.a.	---	n.a.	n.a.	---	7,7	
Permitted Clearances (diameter)	Min.	1,28	1,28	0,16	0,16	0,35	0,97	0,97	23,8	5,50	11,17
	Max	1,44	1,44	0,22	0,22	0,61	1,07	1,07	26,32	7,65	(Ref.)

Values different from those listed in the table, must be submitted to Turbocare for approval. All the readings must be taken with the rotor pushed against the thrust bearing (exhaust side).

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

COMPRESSOR ROTOR CLEARANCES - AFTER OVERHAUL



LEFT

Position	F	G	H	L	M	N	P	Q	R	S	
Readings			0,2	0,19					7,3		
Permitted Clearances	Min.	1,28	1,28	0,16	0,16	0,35	0,97	0,97	23,8	5,50	11,17
	Max	1,44	1,44	0,22	0,22	0,61	1,07	1,07	26,32	7,65	(Ref.)

RIGHT


Position	F	G	H	L	M	N	P	Q	R	S	
Readings			n.a.	n.a.					7,5		
Permitted Clearances	Min.	1,28	1,28	0,16	0,16	0,35	0,97	0,97	23,8	5,50	11,17
	Max	1,44	1,44	0,22	0,22	0,61	1,07	1,07	26,32	7,65	(Ref.)

Values different from those listed in the table, must be submitted to Turbocare for approval. All the readings must be taken with the rotor pushed against the thrust bearing (exhaust side).

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008


INLET CASING LABYRINTH SEALS - DETAIL "A"

1. Readings must be taken looking downstream, left and right side
2. Defects must be specified (i.e. inlet and outlet side looking downstream)
3. Values different from those listed in the table below must be submitted to Turbocare



CLEARANCES						Admitted clearances	SHAFT VISUAL INSPECTION
Detail "A"	Pos.	Before overhaul		After overhaul			
		Left	Right	Left	Right		
	A1	0,5	0,6	0,25	0,9	1,25 - 1,38	
	A2	0,8	0,8	0,4	1,0	1,55 - 1,78	
	A3					2,10 - 5,85	
	A4					2,55 - 6,05	
	A5	0,8	0,8	0,5	1,2	1,55 - 2,05	


COMPRESSOR OGV LABYRINTH SEAL - DETAIL "E"



CLEARANCES						Admitted clearances	SHAFT VISUAL INSPECTION
Detail "E"	Pos.	Before overhaul		After overhaul			
		left	right	left	right		
	E1					6,15	
	E2					6,50	
	E3					10,90	
	E4					2,05 - 4,62	
	E5					10,20	
	E6					1,00 - 3,75	
	E7	2,2	1,8	2,0	2,0	1,60 - 2,70	

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

COMPRESSOR ROTOR CLEARANCES - DETAIL "B" - BEFORE OVERHAUL




Sketches enclosed: yes no Photo enclosed: yes no

Stage	left				Right				Admitted values			
	B1	B2	B3	B4	B1	B2	B3	B4	B1	B2	B3	B4
S1	9,9	6,9	0,7	0,7	9,0	9,2	0,6	0,5	10,47 12,77	6,68 - 8,28	1,32 - 1,72	1,32 - 1,72
S2	7,9	5,0	0,9	1,2	6,3	6,3	1,1	1,2	5,55 - 7,96	6,46 - 8,06	1,32 - 1,72	1,32 - 1,72
S3	5,1	10,5	1,3	1,4	5,4	10,7	1,4	1,5	5,55 - 7,93	10,1-11,74	1,37 - 1,77	1,53 - 1,93
S4	9,0	7,1	1,4	1,4	8,6	7,5	1,5	1,6	8,5 - 10,93	7,14 - 8,74	1,38 - 1,78	1,51 - 1,91
S5	6,5	6,6	1,7	1,7	5,5	7,4	1,7	1,7	5,53 - 7,93	7,15 - 8,75	1,63 - 2,03	1,53 - 1,93
S6	6,6	6,5	1,7	1,8	6,1	7,7	1,8	1,9	5,53 - 7,93	7,16 - 8,76	1,62 - 2,02	1,54 - 1,94
S7	6,6	7,1	1,7	1,8	5,2	8,0	1,9	1,9	5,53 - 7,93	7,15 - 8,75	1,66 - 2,06	1,75 - 2,15
S8	6,1	8,4	1,5	1,5	5,2	8,9	2,0	1,9	5,53 - 7,93	8,32 - 9,92	1,70 - 2,10	1,73 - 2,13
S9	7,0	8,5	1,5	1,5	7,0	8,7	1,85	1,9	6,72 - 9,10	8,36 - 9,96	1,68 - 2,08	1,70 - 2,10
S10	7,3	7,3	1,7	1,6	6,8	7,8	1,9	2,0	6,7 - 9,08	7,19 - 8,79	1,90 - 2,30	1,90 - 2,30
S11	5,7	8,0	1,7	1,7	5,5	7,9	2,0	2,0	5,38 - 7,68	7,31 - 8,91	1,94 - 2,34	1,87 - 2,27
S12	6,1	7,8	1,5	1,6	5,4	8,7	1,1	1,1	5,47 - 7,87	8,5 - 10,11	1,90 - 2,30	1,90 - 2,30
S13	6,6	7,1	2,0	2,0	6,0	7,5	1,6	1,7	5,33 - 7,73	8,9 - 10,51	2,23 - 2,63	2,23 - 2,63
S14	6,5	8,2	2,1	2,1	6,6	9,2	1,6	1,7	5,34 - 7,74	9,2 - 10,65	2,21 - 2,61	2,23 - 2,63
S15	6,5	8,0	2,1	2,0	5,4	8,9	1,7	1,6	5,34 - 7,74	8,32 - 9,92	2,03 - 2,43	2,03 - 2,43
S16	6,1	10,5	1,9	1,9	5,2	10,5	1,7	1,7	5,33 - 7,73	10,3 - 11,9	2,03 - 2,43	2,03 - 2,43
S17	5,6	9,7	1,8	1,8	5,5	9,4	1,7	1,8	5,33 - 7,73	10,3 - 11,9	2,03 - 2,43	2,03 - 2,43
S18	6,5	10,5	1,5	1,5	6,5	9,9	1,7	1,7	5,33 - 7,73	10,3 - 11,9	2,03 - 2,43	2,03 - 2,43
S19	6,1				5,9				5,34 - 7,74	---	---	---

Values different from those listed in the above table, must be submitted to Turbocare for evaluation

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

COMPRESSOR ROTOR CLEARANCES - DETAIL "B" - AFTER OVERHAUL



Sketches enclosed: yes no Photo enclosed: yes no

Stage	left				right				Admitted values			
	B1	B2	B3	B4	B1	B2	B3	B4	B1	B2	B3	B4
S1	10,2	7,5	0,4	0,25	9,65	8,5	0,85	0,85	10,47 12,77	6,68 - 8,28	1,32 - 1,72	1,32 - 1,72
S2	7,4	5,2	0,6	0,85	7,2	5,85	1,35	1,7	5,55 - 7,96	6,46 - 8,06	1,32 - 1,72	1,32 - 1,72
S3	6,3	10,0	1,15	1,2	6,6	9,8	1,7	1,7	5,55 - 7,93	10,1-11,74	1,37 - 1,77	1,53 - 1,93
S4	9,9	6,2	1,2	1,3	9,6	6,6	1,8	1,9	8,5 - 10,93	7,14 - 8,74	1,38 - 1,78	1,51 - 1,91
S5	7,5	5,8	1,5	1,6	6,95	6,0	1,6	1,6	5,53 - 7,93	7,15 - 8,75	1,63 - 2,03	1,53 - 1,93
S6	7,0	6,0	1,5	1,75	7,1	6,3	2,0	2,3	5,53 - 7,93	7,16 - 8,76	1,62 - 2,02	1,54 - 1,94
S7	6,7	6,4	1,7	1,8	6,0	7,3	2,2	2,3	5,53 - 7,93	7,15 - 8,75	1,66 - 2,06	1,75 - 2,15
S8	7,1	7,3	1,3	1,3	6,1	7,9	2,2	2,1	5,53 - 7,93	8,32 - 9,92	1,70 - 2,10	1,73 - 2,13
S9	8,0	7,3	1,3	1,3	7,4	7,9	2,1	2,1	6,72 - 9,10	8,36 - 9,96	1,68 - 2,08	1,70 - 2,10
S10	7,6	7,2	1,5	1,65	7,4	7,0	2,1	2,2	6,7 - 9,08	7,19 - 8,79	1,90 - 2,30	1,90 - 2,30
S11	6,1	7,2	1,7	1,9	6,2	7,0	2,2	2,2	5,38 - 7,68	7,31 - 8,91	1,94 - 2,34	1,87 - 2,27
S12	6,4	7,5	1,35	1,4	5,7	8,3	1,5	1,6	5,47 - 7,87	8,5 - 10,11	1,90 - 2,30	1,90 - 2,30
S13	7,1	7,4	1,85	1,9	6,7	7,8	1,8	1,9	5,33 - 7,73	8,9 - 10,51	2,23 - 2,63	2,23 - 2,63
S14	6,9	8,3	1,9	2,0	6,0	9,0	2,0	1,9	5,34 - 7,74	9,2 - 10,65	2,21 - 2,61	2,23 - 2,63
S15	7,3	7,4	1,85	1,85	7,4	7,0	2,3	2,3	5,34 - 7,74	8,32 - 9,92	2,03 - 2,43	2,03 - 2,43
S16	6,6	9,7	1,0	1,1	6,1	9,9	1,5	1,5	5,33 - 7,73	10,3 - 11,9	2,03 - 2,43	2,03 - 2,43
S17	6,0	9,3	1,0	1,1	6,4	9,0	2,1	2,2	5,33 - 7,73	10,3 - 11,9	2,03 - 2,43	2,03 - 2,43
S18	7,1	9,8	1,4	1,4	7,2	9,7	1,8	1,7	5,33 - 7,73	10,3 - 11,9	2,03 - 2,43	2,03 - 2,43
S19	7,1	5,7	---	---	6,4	6,5	---	---	5,34 - 7,74	---	---	---


Values different from those listed in the above table, must be submitted to Turbocare for evaluation

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev. 11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 24 of 71	

Form Ref. No.: D5TR0024

COMPRESSOR ROTOR CLEARANCES – DETAIL “C” – BEFORE OVERHAUL



Stage	Right		Left		Permitted Values	
	Horinz. CL	Upper CL	Horinz. CL	Upper CL	Horinz. CL	Upper CL
S1	1,8		2,1		2,25 – 3,02	2,05
S2	2,2		2,2		2,46 – 3,22	
S3	1,9		2,2		2,62 – 3,38	
S4	1,8		2,2		2,62 – 3,38	
S5	2,1		2,1		2,62 – 3,38	
S6	2,1		2,1		2,62 – 3,38	
S7	2,1		2,3		2,89 – 3,65	
S8	2,0		2,0		2,89 – 3,65	
S9	2,1		2,3		2,89 – 3,65	
S10	2,4		2,5		3,39 – 4,15	2,90
S11	2,5		2,5		3,39 – 4,15	
S12	2,1		2,7		3,39 – 4,15	
S13	2,3		2,7		3,64 – 4,4	
S14	2,4		2,7		3,64 – 4,4	
S15	2,1		2,4		3,64 – 4,4	
S16	2,1		2,4		3,64 – 4,4	
S17	2,1		2,2		3,64 – 4,4	
S18	2,2		2,2		3,64 – 4,4	
S19	2,2		2,2		3,64 – 4,4	2,80


Values different from those listed in the table must be submitted to Turbocare for evaluation

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 25 of 71	

Form Ref. No.: D5TR0024-A

COMPRESSOR ROTOR CLEARANCES – DETAIL “C” – AFTER OVERHAUL




Stage	Right		Left		Permitted Values	
	Horinz. CL	Upper CL	Horinz. CL	Upper CL	Horinz. CL	Upper CL
S1	2,1		1,4		2,25 – 3,02	2,05
S2	2,1		1,9		2,46 – 3,22	
S3	2,3		1,7		2,62 – 3,38	
S4	2,3		1,8		2,62 – 3,38	
S5	2,4		1,9		2,62 – 3,38	
S6	2,4		1,9		2,62 – 3,38	
S7	2,3		1,9		2,89 – 3,65	
S8	2,0		1,7		2,89 – 3,65	
S9	2,3		2,0		2,89 – 3,65	
S10	2,5		2,4		3,39 – 4,15	2,90
S11	3,0		2,4		3,39 – 4,15	
S12	2,6		2,6		3,39 – 4,15	
S13	2,5		2,7		3,64 – 4,4	
S14	2,6		2,7		3,64 – 4,4	
S15	2,5		2,5		3,64 – 4,4	
S16	2,4		2,3		3,64 – 4,4	
S17	2,5		2,4		3,64 – 4,4	
S18	2,4		2,3		3,64 – 4,4	
S19	2,5		2,2		3,64 – 4,4	2,80

Values different from those listed in the table must be submitted to Turbocare for evaluation.

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE ROTOR CLEARANCES – RIGHT SIDE - BEFORE OVERHAUL




STAGE ("B" value)	1 ST	2 ND	3 RD	4 TH	POSITION	1	2	3	4	5	6	7	
Horizontal centerline readings	1,95	3,55	4,75	6,0	Readings								
Horizontal centerline permitted values	Min	3,30	4,50	6,35	Permitted values (diameter)	Min	11,4	19,4	6,60	1,0	1,0	26,0	23,6
	Max	3,80	5,35	7,20		8,70	Max	12,8	27,1	7,0	1,1	1,1	ref
Upper centerline readings					Notes:								
Upper centerline permitted values	Min	3,40	5,05	7,30		7,90							
	Max	4,00	5,90	8,15		8,75							
Lower centerline reading													
Lower centerline permitted values	Min	3,20			7,80								
	Max	3,70			8,65								

Notes: All the clearances must be taken with rotor and blade rings pushed toward the exhaust side.
Values not complying with those listed in the table, must be submitted to Turbocare for evaluation

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE ROTOR CLEARANCES – RIGHT SIDE - AFTER OVERHAUL




STAGE ("B" value)	1 ST	2 ND	3 RD	4 TH	POSITION	1	2	3	4	5	6	7	
Horizontal centerline readings	1,5	3,2	4,2	5,0	Readings								
Horizontal centerline permitted values	Min	3,30	4,50	6,35	Permitted values (diameter)	Min	11,4	19,4	6,60	1,0	1,0	26,0	23,6
	Max	3,80	5,35	7,20		8,70	Max	12,8	27,1	7,0	1,1	1,1	ref
Upper centerline readings					Notes:								
Upper centerline permitted values	Min	3,40	5,05	7,30		7,90							
	Max	4,00	5,90	8,15		8,75							
Lower centerline reading													
Lower centerline permitted values	Min	3,20			7,80								
	Max	3,70			8,65								

Notes: All the clearances must be taken with rotor and blade rings pushed toward the exhaust side.
Values not complying with those listed in the table, must be submitted to Turbocare for evaluation

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE ROTOR CLEARANCES – LEFT SIDE - BEFORE OVERHAUL




STAGE ("B" value)	1 ST	2 ND	3 RD	4 TH	POSITION	1	2	3	4	5	6	7	
Horizontal centerline readings	2,35	3,25	4,1	5,8	Readings								
Horizontal centerline permitted values	Min	3,30	4,50	6,35	Permitted values (diameter)	Min	11,4	19,4	6,60	1,0	1,0	26,0	23,6
	Max	3,80	5,35	7,20		8,70	Max	12,8	27,1	7,0	1,1	1,1	ref
Upper centerline readings					Notes:								
Upper centerline permitted values	Min	3,40	5,05	7,30		7,90							
	Max	4,00	5,90	8,15		8,75							
Lower centerline reading													
Lower centerline permitted values	Min	3,20			7,80								
	Max	3,70			8,65								

Notes: All the clearances must be taken with rotor and blade rings pushed toward the exhaust side.
Values not complying with those listed in the table, must be submitted to Turbocare for evaluation

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE ROTOR CLEARANCES – LEFT SIDE - AFTER OVERHAUL




STAGE ("B" value)	1 ST	2 ND	3 RD	4 TH	POSITION	1	2	3	4	5	6	7		
Horizontal centerline readings	1,0	3,0	4,5	4,7	Readings									
Horizontal centerline permitted values	Min	3,30	4,50	6,35	7,85	Permitted values (diameter)	Min	11,4	19,4	6,60	1,0	1,0	26,0	23,6
	Max	3,80	5,35	7,20	8,70		Max	12,8	27,1	7,0	1,1	1,1	ref	ref
Upper centerline readings					Notes:									
Upper centerline permitted values	Min	3,40	5,05	7,30		7,90								
	Max	4,00	5,90	8,15		8,75								
Lower centerline reading														
Lower centerline permitted values	Min	3,20			7,80									
	Max	3,70			8,65									

Notes: All the clearances must be taken with rotor and blade rings pushed toward the exhaust side.
 Values not complying with those listed in the table, must be submitted to Turbocare for evaluation

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008


INTERMEDIATE SHAFT GUARD LABYRINTH SEALS - DETAIL "F"

- 1 Readings must be taken looking downstream, left and right side
- 2 Defects must be specified (i.e. inlet and outlet side looking downstream)
- 3 Values different from those indicated in the table must be submitted to Turbocare for approval



DETAIL "F"	CLEARANCES					Permitted clearances	SHAFT VISUAL INSPECTION
	Pos.	Before overhaul		After overhaul			
		left	right	left	Right		
F1					12,95 – 18,90		
F2					12,85 – 18,15		
F3					2,95 – 3,95		
F4					2,95 – 3,95		
F5					3,80 – 4,35		


DIFFUSER BODY LABYRINTH SEALS - DETAIL "H"



DETAIL "H"	CLEARANCES					Permitted clearances	SHAFT VISUAL INSPECTION
	Pos.	Before overhaul		After overhaul			
		left	Right	Left	right		
H1	1,3	0,65	0,95	0,9	1,80 – 2,02		
H2	0,8	0,6	0,9	0,7	1,35 – 1,51		
H3	0,8	0,5	0,5	0,6	1,40 – 1,63		

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE ROTOR CLEARANCES – “DETAIL G” RIGHT SIDE - BEFORE OVERHAUL




Location	1	2	3	4	5	6	7	8	9	10	11	12	13	14	
Readings	---	---	---	14	---	3,6	13,7	15,5	1,6	1,6	19,5	1,3	1,3	11,7	
Permitted values	Min	11,35	11,85	0,00	14,00	18,51	3,06	10,10	12,95	2,40	2,40	17,30	2,40	2,40	8,35
	Max	15,7	ref.	0,20	18,40	23,40	3,62	17,65	19,75	2,95	2,60	22,30	2,95	2,60	15,25
Location	15	16	17	18	19	20	21	22	23	24	25	26	27		
Readings	11,1	21,5	17,6	12,8	1,3	1,3	2,03	12,85	18,5	17,5	---	---	---		
Permitted values	Min	7,85	19,65	10,50	8,75	2,40	2,40	19,50	14,82	20,30	20,55	14,30	5,30	9,00	
	Max	15,60	24,70	19,45	15,80	2,60	2,95	24,65	19,84	25,94	26,50	23,45	14,50	18,75	

Notes: All the clearances must be taken with rotor and blade rings pushed toward the exhaust side.
 Values not complying with those listed in the table, must be submitted to Turbocare for evaluation

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE ROTOR CLEARANCES – “DETAIL G” RIGHT SIDE - AFTER OVERHAUL




Location	1	2	3	4	5	6	7	8	9	10	11	12	13	14	
Readings	---	---	---	13,9	18,5	---	14,5	16,0	1,0	1,0	20,0	1,4	1,3	12,0	
Permitted values	Min	11,35	11,85	0,00	14,00	18,51	3,06	10,10	12,95	2,40	2,40	17,30	2,40	2,40	8,35
	Max	15,7	ref.	0,20	18,40	23,40	3,62	17,65	19,75	2,95	2,60	22,30	2,95	2,60	15,25
Location	15	16	17	18	19	20	21	22	23	24	25	26	27		
Readings	11,2	21,5	14,8	14,4	1,0	1,0	20,0	13,5	18,2	18,3	---	---	---		
Permitted values	Min	7,85	19,65	10,50	8,75	2,40	2,40	19,50	14,82	20,30	20,55	14,30	5,30	9,00	
	Max	15,60	24,70	19,45	15,80	2,60	2,95	24,65	19,84	25,94	26,50	23,45	14,50	18,75	

Notes: All the clearances must be taken with rotor and blade rings pushed toward the exhaust side.
Values not complying with those listed in the table, must be submitted to Turbocare for evaluation

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE ROTOR CLEARANCES – “DETAIL G” LEFT SIDE - BEFORE OVERHAUL




Location	1	2	3	4	5	6	7	8	9	10	11	12	13	14	
Readings	---	---	---	13,7	---	---	16,0	12,9	1,3	1,3	19,3	1,6	1,6	12,6	
Permitted values	Min	11,35	11,85	0,00	14,00	18,51	3,06	10,10	12,95	2,40	2,40	17,30	2,40	2,40	8,35
	Max	15,7	ref.	0,20	18,40	23,40	3,62	17,65	19,75	2,95	2,60	22,30	2,95	2,60	15,25
Location	15	16	17	18	19	20	21	22	23	24	25	26	27		
Readings	13,4	20,6	17,2	14,4	1,9	1,9	19,6	---	18	16,7	---	---	---		
Permitted values	Min	7,85	19,65	10,50	8,75	2,40	2,40	19,50	14,82	20,30	20,55	14,30	5,30	9,00	
	Max	15,60	24,70	19,45	15,80	2,60	2,95	24,65	19,84	25,94	26,50	23,45	14,50	18,75	

Notes: All the clearances must be taken with rotor and blade rings pushed toward the exhaust side.
 Values not complying with those listed in the table, must be submitted to Turbocare for evaluation

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE ROTOR CLEARANCES – “DETAIL G” LEFT SIDE - AFTER OVERHAUL




Location	1	2	3	4	5	6	7	8	9	10	11	12	13	14	
Readings	---	---	---	13,4	16,0	---	16,7	17,7	1,9	1,7	19,8	1,6	1,5	14,3	
Permitted values	Min	11,35	11,85	0,00	14,00	18,51	3,06	10,10	12,95	2,40	2,40	17,30	2,40	2,40	8,35
	Max	15,7	ref.	0,20	18,40	23,40	3,62	17,65	19,75	2,95	2,60	22,30	2,95	2,60	15,25
Location	15	16	17	18	19	20	21	22	23	24	25	26	27		
Readings	14,0	21,0	17,5	14,9	2,1	2,2	21,0	10,7	16,4	19,0	---	---	---		
Permitted values	Min	7,85	19,65	10,50	8,75	2,40	2,40	19,50	14,82	20,30	20,55	14,30	5,30	9,00	
	Max	15,60	24,70	19,45	15,80	2,60	2,95	24,65	19,84	25,94	26,50	23,45	14,50	18,75	

Notes: All the clearances must be taken with rotor and blade rings pushed toward the exhaust side.
 Values not complying with those listed in the table, must be submitted to Turbocare for evaluation

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

2nd, 3rd & 4th STAGE AIR SEAL RING CENTERING




STAGE	ANGLE POS.	0° 360°	45°	90°	135°	180°	225°	270°	315°
2 nd STAGE		-0,05		-1,5		0,00		-1,5	
3 rd STAGE		0,11		-1,1		0,00		-1,15	
4 th STAGE		0,08		-0,57		0,00		-0,65	

NOTES:

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

COMPRESSOR SEALS AND DISCS – VISUAL INSPECTION



CONDITION

ACTIONS

M = material loss
W = worn
CR = cracked

N = to be replaced with a new seal
R = repairable
RN = no action required




ROW	SEALS VISUAL INSPECTION		DISCS VISUAL INSPECTION	
	CONDITIONS	ACTIONS	CONDITIONS	ACTIONS
1	good		good	
2	good		good	
3	good		good	
4	good		good	
5	good		good	
6	good		good	
7	good		good	
8	good		good	
9	good		good	
10	good		good	
11	good		good	
12	good		good	
13	good		good	
14	good		good	
15	good		good	
16	good		good	
17	good		good	
18	good		good	
19	good		good	

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

STANDARD COMBUSTOR BASKET – IDENTIFICATION OF COMPONENTS

Enclosed sketches: yes no
Enclosed photos: yes no

NOMENCLATURE	CODE
Corrugated ring	C
Ring	R
Dome	D
Spring	S
Cross flame tube connection	TC
Cross flame tube junction	TJ
Air scoop	SC



Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008



TECHNICAL
REPORT

Rev. Date: 09/12/04 Rev.11

Power Plant:

GT S/N:354

Customer: IPSA

Turbine Type: TG50D5std

Sheet: 38 of 71

Form Ref. N°: D5TR0041-A

COMBUSTOR BASKET – ASSEMBLY

POS	BASKETS		FROM THE FIRST INSTALLATION			FROM THE LAST INSPECTION			COMING FROM		
	S/N	DRAWING	DATE	STARTS NO.	FIRING HRS.	DATE	STARTS NO.	FIRING HRS.	GR	STARTS NO.	FIRING HRS.
1	RO – 91K – 001M	4219T92									
2	ILT - 000309	4219T92									
3	ILL - 059581	4219T92									
4	ILL - 059582	4219T92									
5	ILL - 059585	4219T92									
6	ILL - 059591	4219T92									
7	ILT - 119670	4219T94									
8	ILL - 059598	4219T94									
9	ILT - 0003198	4219T92									
10	ILL - 059589	4219T92									
11	ILL - 129164	4219T92									
12	ILL - 059584	4219T92									
13	ILL - 1295145	4219T92									
14	ILL - 059593	4219T92									
15	ILL - 059592	4219T92									
16	RO – 90K175	4219T92									
17	ILT - 000317	4219T93									
18	RO – 91K015M	4219T93									

Notes: Refurbished parts

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008


TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 39 of 71	

Form Ref. N°: D5TR0045-A


TRANSITION PIECES – AT REASSEMBLY

TRANSITION PIECES	FROM THE FIRST INSTALLATION			FROM THE LAST INSPECTION			COMING FROM					
	POS	S/N	DRAWING	DATE	STARTS NO.	FIRING HRS.	DATE	STARTS NO.	FIRING HRS.	GR.	STARTS NO.	FIRING HRS.
1	345	4220T99										
2	495	4220T99										
3	067	4220T99										
4	illegible	4220T99										
5	072	4220T99										
6	645	4220T99										
7	323	4220T99										
8	illegible	4220T99										
9	066	4220T99										
10	500	4220T99										
11	504	4220T99										
12	056	4220T99										
13	068	4220T99										
14	491	4220T99										
15	507	4220T99										
16	069	4220T99										
17	496	4220T99										
18	505	4220T99										

Notes: Refurbished parts

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

TRANSITION PIECE LATERAL SEALS - CLEARANCES




TRANSITION	AT DISASSEMBLY			AT RE -ASSEMBLY	
	PRESENCE OF CRACKS ON LATERAL SEALS	VALUE “A”	VALUE “B”	VALUE “A”	VALUE “B”
1 – 2				7,8	
2 – 3				7,8	
3 – 4				8,3	
4 – 5				7,7	
5 – 6				7,5	
6 – 7				7,5	
7 – 8				7,5	
8 – 9				7,5	
9 – 10				7,5	
10 – 11				7,5	
11 – 12				8,0	
12 – 13				7,5	
13 – 14				8,0	
14 – 15				8,4	
15 – 16				7,7	
16 – 17				7,3	
17 – 18				7,5	
18 – 1				5,8	

Notes:

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TRANSITION PIECES – ALIGNMENT CHECK




NUMBERING IS REFERRED TO TURBINE CENTERLINE (i.e.: position 2 is always toward the internal support)

POSITION	GAP READING "A"				DIFFERENCE		NOTES
	A1	A2	A3	A4	A1-A2	A3-A4	
1	4,8	5,5	4,3	4,7	0,8	0,4	
2	4,5	4,5	5,8	5,5	0,0	0,3	
3	4,2	5,0	5,3	5,5	0,8	0,2	
4	4,7	4,5	5,7	6,2	0,2	0,5	
5	4,0	4,5	5,3	5,5	0,5	0,2	
6	4,3	4,6	5,3	5,3	0,3	0,0	
7	3,6	4,5	5,3	5,0	0,9	0,3	
8	4,9	5,0	4,9	5,0	0,1	0,1	
9	4,5	4,8	5,0	4,3	0,3	0,7	
10	4,3	4,5	5,6	5,0	0,2	0,6	
11	5,0	5,5	5,4	4,7	0,5	0,7	
12	5,4	4,9	4,3	4,6	0,5	0,3	
13	4,7	4,3	5,0	5,5	0,4	0,5	
14	4,0	4,3	5,2	5,8	0,3	0,6	
15	4,5	4,3	5,2	5,5	0,2	0,3	
16	4,7	4,2	4,8	5,1	0,5	0,3	
17	4,3	4,9	4,9	5,3	0,6	0,4	
18	4,3	4,7	5,8	5,2	0,4	0,6	

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008


TRANSITION PIECES – INNER AND OUTER SEALS CLEARANCES



TRANSITION PIECE	OUTER SEALS CLEARANCE	INNER SEAL CLEARANCE	NOTES
1 - 2	3,0	6,0	
2 - 3	5,0	6,5	
3 - 4	6,0	6,0	
4 - 5	5,5	5,7	
5 - 6	8,0	6,7	
6 - 7	8,0	5,0	
7 - 8	7,5	6,0	
8 - 9	6,7	5,0	
9 - 10	8,0	5,0	
10 - 11	9,0	6,5	
11 - 12	9,0	7,0	
12 - 13	6,5	5,0	
13 - 14	6,8	6,5	
14 - 15	6,5	5,9	
15 - 16	6,5	8,0	
16 - 17	5,5	5,0	
17 - 18	5,0	6,0	
18 - 1	3,0	6,0	

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

TRANSITION PIECES – “C” SUPPORTS ASSEMBLY CLEARANCES





POS N°	Clearance A		Clearance B		Clearance C		Clearance D		POS. N°	Clearance A		Clearance B		Clearance C		Clearance D	
	I	II	I	II	I	II	I	II		I	II	I	II	I	II	I	II
1	0,5	0,5					0,2	0,3	10	0,3	0,1					0,5	0,3
2	0,5	0,4					0,3	0,5	11	0,3	0,2					0,4	0,5
3	0,4	0,3					0,4	0,3	12	0,3	0,3					0,5	0,5
4	0,2	0,2					0,5	0,5	13	0,4	0,4					0,50	0,4
5	0,2	0,4					0,5	0,5	14	0,2	0,2					0,3	0,4
6	0,3	0,4					0,3	0,5	15	0,4	0,3					0,5	0,4
7	0,2	0,3					0,5	0,4	16	0,2	0,3					0,5	0,2
8	0,3	0,4					0,3	0,4	17	0,4	0,3					0,4	0,3
9	0,2	0,2					0,5	0,5	18	0,1	0,2					0,5	0,5

Notes:


Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

CROSS FLAME TUBE - INSPECTION



Cross flame tube

Flanged tube



Junction clamp

Cross flame tube position	Cross flame tube condition	Flanged tube condition	Junction clamp condition	Remarks
1 - 2	Good	Good	Good	
2 - 3	Good	Good	Good	
3 - 4	Good	Good	Good	
4 - 5	Good	Good	Good	
5 - 6	Good	Good	Good	
6 - 7	Good	Good	Good	
7 - 8	Good	Good	Good	
8 - 9	Good	Good	Good	
9 - 10	Good	Good	Good	
10 - 11	Good	Good	Good	
11 - 12	Good	Good	Good	
12 - 13	Good	Good	Good	
13 - 14	Good	Good	Good	
14 - 15	Good	Good	Good	
15 - 16	Good	Good	Good	
16 - 17	Good	Good	Good	
1 - 18	Good	Good	Good	

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev. 11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 45 of 71	


Form Ref. N°: D5TR0062

TURBINE VANES – SERIAL NUMBERS

DISASSEMBLY



ASSEMBLY

1 ST STAGE				2 ND STAGE		3 RD STAGE		4 TH STAGE	
POS.	S/N	POS.	S/N	POS.	S/N	POS.	S/N	POS.	S/N
1	U4141	31	U4038	1	945U2310	1	U3K433	1	U4T485
2	UB1835	32	U4092	2	945U2304	2	U3K434	2	U4T511
3	U1K3217	33	U4089	3	945U2305	3	U3K443	3	U4T490
4	U4480	34	U5651	4	945U2307	4	U3K435	4	U4T487
5	U4478	35	U1K2665	5	945U2313	5	U3K436	5	U4T489
6	U4706	36	UB1030	6	945U2312	6	U3K437	6	U4T486
7	U4675	37	U1K2674	7	945U2308	7	U3K438	7	U4T491
8	U4045	38	U4138	8	945U2325	8	U3K439	8	U4T483
9	U4083	39	U4067	9	945U2499	9	U3K440	9	U4126
10	U3896	40	U4154	10	945U2309	10	U3K441	10	U4118
11	U4094	41	UB1039	11	945U2295	11	U3K442	11	U4114
12	U1K2651	42	U1K3219	12	945U2314	12	U3K444	12	U4T492
13	U1K2656	43	U1K2668	13	945U2303	13	U3K445	13	U4T497
14	U1K2643	44	UB1009	14	945U2317	14	U3K446	14	U4T484
15	U4678	45	U4629	15	945U2316	15	U3K447	15	U4100
16	U1K2639	46	U4034	16	945U2315	16	U3K448	16	U4T493
17	U3965	47	UB842	17	945U2306	17	U3K449		
18	UB1046	48	U4360	18	945U2301	18	U3K450		
19	U4670	49	U4092	19	945U2296				
20	U4672	50	U1K2689	20	945U2311				
21	U4095	51	U1K4579						
22	U4070	52	UB1045						
23	U1K2345	53	U1K2665						
24	U1K2688	54	U1K2682						
25	U1K2663	55	U1K2641						
26	U1K2793	56	U1K4688						
27	U1K3178	57	U4039						
28	U1K3039	58	U1K2691						
29	U1K3186	59	U4139						
30	U1K3193	60	U1K2687						

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 3RD STAGE VANES - INSPECTION

S/N: U3K433	DWG: 4282T81	POSITION : 1	FIRING HRS : 48954	STARTS NO.: 1295	TESTED: PT <input type="checkbox"/> VT <input type="checkbox"/>
----------------	-----------------	-----------------	-----------------------	---------------------	--




Position	Damage description	Position	Damage description
1	CRICCA 5mm	10	
2	CRICCA 5mm	11	
3	CRICCA 4mm	12	
4	CRICCA 80mm	13	
5		14	
6		15	
7		16	
8			
9			

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 3RD STAGE VANES - INSPECTION

S/N: U3K434	DWG: 4282T81	POSITION : 2	FIRING HRS : 48954	STARTS NO.: 1295	TESTED: PT <input type="checkbox"/> VT <input type="checkbox"/>
----------------	-----------------	-----------------	-----------------------	---------------------	--




Position	Damage description	Position	Damage description
1	CRICCA 28mm	10	
2		11	
3		12	
4		13	
5		14	
6		15	
7		16	
8			
9			

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 3RD STAGE VANES - INSPECTION

S/N: U3K443	DWG: 4282T81	POSITION : 3	FIRING HRS : 48954	STARTS NO.: 1295	TESTED: PT <input type="checkbox"/> VT <input type="checkbox"/>
----------------	-----------------	-----------------	-----------------------	---------------------	--




Position	Damage description	Position	Damage description
1	Crack 62 mm.	10	
2		11	
3		12	
4		13	
5		14	
6		15	
7		16	
8			
9			

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 3RD STAGE VANES - INSPECTION

S/N: U3K435	DWG: 4282T81	POSITION : 4	FIRING HRS : 48954	STARTS NO.: 1295	TESTED: PT <input type="checkbox"/> VT <input type="checkbox"/>
----------------	-----------------	-----------------	-----------------------	---------------------	--




Position	Damage description	Position	Damage description
1	Crack 95mm.	10	
2	Crack 15 mm.	11	
3		12	
4		13	
5		14	
6		15	
7		16	
8			
9			

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 3RD STAGE VANES - INSPECTION

S/N: U3K436	DWG: 4282T81	POSITION : 5	FIRING HRS : 48954	STARTS NO.: 1295	TESTED: PT <input type="checkbox"/> VT <input type="checkbox"/>
----------------	-----------------	-----------------	-----------------------	---------------------	--




Position	Damage description	Position	Damage description
1	Crack 70mm.	10	
2		11	
3		12	
4		13	
5		14	
6		15	
7		16	
8			
9			

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 3RD STAGE VANES - INSPECTION

S/N: U3K437	DWG: 4282T81	POSITION : 6	FIRING HRS : 48954	STARTS NO.: 1295	TESTED: PT <input type="checkbox"/> VT <input type="checkbox"/>
----------------	-----------------	-----------------	-----------------------	---------------------	--




Position	Damage description	Position	Damage description
1	f.o. impact dia. 3 mm.	10	
2	Crack 15mm.	11	
3	Crack 22mm.	12	
4	f.o. impact dia. 7 mm.	13	
5		14	
6		15	
7		16	
8			
9			

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 3RD STAGE VANES - INSPECTION

S/N: U3K438	DWG: 4282T81	POSITION : 7	FIRING HRS : 48954	STARTS NO.: 1295	TESTED: PT <input type="checkbox"/> VT <input type="checkbox"/>
----------------	-----------------	-----------------	-----------------------	---------------------	--




Position	Damage description	Position	Damage description
1	Crack 87 mm.	10	
2	f.o. impact dia. 8 mm,	11	
3		12	
4		13	
5		14	
6		15	
7		16	
8			
9			

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 3RD STAGE VANES - INSPECTION

S/N: U3K440	DWG: 4282T81	POSITION : 9	FIRING HRS : 48954	STARTS NO.: 1295	TESTED: PT <input type="checkbox"/> VT <input type="checkbox"/>
----------------	-----------------	-----------------	-----------------------	---------------------	--




Position	Damage description	Position	Damage description
1	Crack 70 mm.	10	
2		11	
3		12	
4		13	
5		14	
6		15	
7		16	
8			
9			

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 3RD STAGE VANES - INSPECTION

S/N: U3K441	DWG: 4282T81	POSITION : 10	FIRING HRS : 48954	STARTS NO.: 1295	TESTED: PT <input type="checkbox"/> VT <input type="checkbox"/>
----------------	-----------------	------------------	-----------------------	---------------------	--




Position	Damage description	Position	Damage description
1	Crack 96 mm.	10	
2	f.o. impact dia. 3 mm.	11	
3		12	
4		13	
5		14	
6		15	
7		16	
8			
9			

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 3RD STAGE VANES - INSPECTION

S/N: U3K442	DWG: 4282T81	POSITION : 11	FIRING HRS : 48954	STARTS NO.: 1295	TESTED: PT <input type="checkbox"/> VT <input type="checkbox"/>
----------------	-----------------	------------------	-----------------------	---------------------	--




Position	Damage description	Position	Damage description
1	Crack 73 mm.	10	
2	f.o. impact dia. 5 mm.	11	
3	f.o. impact dia. 3 mm.	12	
4		13	
5		14	
6		15	
7		16	
8			
9			

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 3RD STAGE VANES - INSPECTION

S/N: U3K444	DWG: 4282T81	POSITION : 12	FIRING HRS : 48954	STARTS NO.: 1295	TESTED: PT <input type="checkbox"/> VT <input type="checkbox"/>
----------------	-----------------	------------------	-----------------------	---------------------	--




Position	Damage description	Position	Damage description
1	Crack 62 mm.	10	
2		11	
3		12	
4		13	
5		14	
6		15	
7		16	
8			
9			

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 3RD STAGE VANES - INSPECTION

S/N: U3K445	DWG: 4228T81	POSITION : 13	FIRING HRS : 48954	STARTS NO.: 1295	TESTED: PT <input type="checkbox"/> VT <input type="checkbox"/>
----------------	-----------------	------------------	-----------------------	---------------------	--





Position	Damage description	Position	Damage description
1	Crack 98 mm.	10	
2	f.o. impact dia. 3 mm.	11	
3		12	
4		13	
5		14	
6		15	
7		16	
8			
9			

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 3RD STAGE VANES - INSPECTION

S/N: U3K446	DWG: 4228T81	POSITION : 14	FIRING HRS : 48954	STARTS NO.: 1295	TESTED: PT <input type="checkbox"/> VT <input type="checkbox"/>
----------------	-----------------	------------------	-----------------------	---------------------	--




Position	Damage description	Position	Damage description
1	Crack 35 mm.	10	
2	f.o. impact dia. 8 mm.	11	
3	f.o. impact dia. 3 mm.	12	
4		13	
5		14	
6		15	
7		16	
8			
9			

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 3RD STAGE VANES - INSPECTION

S/N: U3K447	DWG: 4228T81	POSITION : 15	FIRING HRS : 48954	STARTS NO.: 1295	TESTED: PT <input type="checkbox"/> VT <input type="checkbox"/>
----------------	-----------------	------------------	-----------------------	---------------------	--




Position	Damage description	Position	Damage description
1	Crack 64 mm.	10	
2		11	
3		12	
4		13	
5		14	
6		15	
7		16	
8			
9			

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 3RD STAGE VANES - INSPECTION

S/N: U3K448	DWG: 4228T81	POSITION : 16	FIRING HRS : 48954	STARTS NO.: 1295	TESTED: PT <input type="checkbox"/> VT <input type="checkbox"/>
----------------	-----------------	------------------	-----------------------	---------------------	--




Position	Damage description	Position	Damage description
1	Crack 87 mm.	10	
2		11	
3		12	
4		13	
5		14	
6		15	
7		16	
8			
9			

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 3RD STAGE VANES - INSPECTION

S/N: U3K449	DWG: 4282T81	POSITION : 17	FIRING HRS : 48954	STARTS NO.: 1295	TESTED: PT <input type="checkbox"/> VT <input type="checkbox"/>
----------------	-----------------	------------------	-----------------------	---------------------	--



Position	Damage description	Position	Damage description
1	Crack 46 mm.	10	
2	f.o. dia 3 mm.	11	
3		12	
4		13	
5		14	
6		15	
7		16	
8			
9			

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 62 of 71	

Form Ref. N°: D5TR0075

TURBINE 1ST STAGE BLADES – GENERAL INFORMATION


DRAWING N°: 4215T76R

BLADES MATERIAL: UDIMET-520 (coated NICOCRALY)

ASSEMBLY

Pos.	moment weight	serial number	Pos.	moment weight	serial number	Pos.	moment weight	serial number	Pos.	moment weight	serial number
1	5723	KO100475	29	5679	KO100268	57	5737	KO100177	85	5768	KO100485
2	5687	KO100249	30	5726	KO100422	58	5735	KO100328	86	5773	KO100093
3	5700	KO100228	31	5727	KO100232	59	5706	KO100243	87	5767	KO100042
4	5682	KO100229	32	5738	KO100348	60	5694	KO100407	88	5747	KO100085
5	5715	KO102332	33	5725	KO100414	61	5672	KO100224	89	5614	KO100217
6	5701	KO100216	34	5704	KO100259	62	5733	KO100492	90	5740	KO100377
7	5706	KO100469	35	5721	KO100387	63	5732	KO100428	91	5744	KO100418
8	5702	KO100257	36	5722	KO100365	64	5748	KO100306	92	5675	KO100234
9	5697	KO9866	37	5715	KO100354	65	5695	KO100218	93	5707	KO100251
10	5715	KO100119	38	5772	KO100137	66	5722	KO100953	94	5707	KO100322
11	5732	KO100497	39	5746	KO100385	67	5747	KO100250	95	5733	KO100303
12	5727	KO100386	40	5739	KO100311	68	5721	KO100426	96	5710	KO100456
13	5704	KO100219	41	5748	KO100026	69	5685	KO100247	97	5740	KO100338
14	5742	KO100204	42	5773	KO100037	70	5738	KO100369	98	5768	KO100291
15	5753	KO100439	43	5746	KO100134	71	5723	KO100295	99	5746	KO100126
16	5719	KO100325	44	5748	KO100154	72	5723	KO100473	100	5761	KO100404
17	5747	KO100593	45	5696	KO100227	73	5716	KO100361	101	5752	KO100212
18	5689	KO100258	46	5713	KO100452	74	5716	KO100222	102	5747	KO100405
19	5716	KO100349	47	5693	KO100296	75	5702	KO100444	103	5726	KO100314
20	5733	KO100420	48	5717	KO09782	76	5725	KO100255			
21	5710	KO100355	49	5718	KO100297	77	5728	KO100474			
22	5719	KO100287	50	5727	KO100409	78	5707	KO100337			
23	5704	KO100226	51	5718	KO100367	79	5691	KO100240			
24	5689	KO100242	52	5717	KO100430	80	5717	KO100381			
25	5704	KO100453	53	5727	KO100436	81	5691	KO100449			
26	5716	KO100379	54	5710	KO100392	82	5699	KO9915			
27	5713	KO100464	55	5676	KO100269	83	5741	KO100370			
28	5729	KO100424	56	5716	KO100479	84	5738	KO100515			

Notes: The Moment weight is expressed in Kgmm

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 63 of 71	

Form Ref. N°: D5TR0075-A

TURBINE 2ND STAGE BLADES – GENERAL INFORMATION


DRAWING N°: 4215T77

BLADES MATERIAL: UDIMET-520 (coated NICOCRALY)

ASSEMBLY

Pos.	moment weight	serial number	Pos.	moment weight	serial number	Pos.	moment weight	serial number	Pos.	moment weight	serial number
1	5074	891U2124	29	5062	891U2184	57	5060	891U2119	85	5053	891U2109
2	5044	891U2111	30	5055	891U2188	58	5069	891U2192	86	5040	891U2135
3	5050	891U2133	31	5049	891U2131	59	5063	891U2120	87	5080	891U2163
4	5103	901U2499	32	5096	891U2182	60	5092	891U2197	88	5103	901U2471
5	5047	891U2110	33	5073	901U2407	61	5085	891U2191	89	5066	891U2128
6	5070	891U2168	34	5066	891U2103	62	5091	891U2137	90	5114	901U2478
7	5052	891U2122	35	5075	891U2145	63	5047	891U2153	91	5070	891U2117
8	5044	891U2156	36	5050	891U2178	64	5069	891U2138	92	5092	KO9398
9	5057	891U2176	37	5063	891U2125	65	5085	891U2106	93	5049	891U2154
10	5057	891U2134	38	5067	891U2173	66	5071	891U2130			
11	5077	891U2143	39	5090	891U2139	67	5047	891U2165			
12	5092	891U2152	40	5087	891U2127	68	5067	891U2114			
13	5061	891U2116	41	5065	891U2123	69	5063	891U2181			
14	5046	891U2187	42	5046	891U2141	70	5068	891U2157			
15	5096	900U2681	43	5058	891U2150	71	5074	891U2177			
16	5051	891U2186	44	5054	891U2199	72	5080	891U2113			
17	5087	891U2115	45	5053	891U2121	73	5095	891U2136			
18	5075	901U2462	46	5071	891U2105	74	5074	901U2419			
19	5050	891U2196	47	5041	891U2148	75	5056	891U2146			
20	5118	891U2162	48	5120	901U2505	76	5060	891U2126			
21	5183	891U2154	49	5061	891U2107	77	5051	891U2183			
22	5096	891U2132	50	5105	901U2423	78	5085	891U2166			
23	5070	891U2189	51	5049	891U2194	79	5110	901U2498			
24	5082	891U2193	52	5123	901U2457	80	5100	891U2170			
25	5069	891U2179	53	5084	901U2493	81	5092	901U2503			
26	5049	891U217T	54	5072	891U2140	82	5046	891U2185			
27	5055	901U2451	55	5077	891U2160	83	5076	891U2144			
28	5097	891U2159	56	5065	891U2172	84	5081	891U2158			

Notes: The Moment weight is expressed in Kgmm

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 64 of 71	

Form Ref. N°: D5TR0075-B

TURBINE 3RD STAGE BLADES – GENERAL INFORMATION


DRAWING N°: 4215T78

BLADES MATERIAL: UDIMET 520 (not coated)

ASSEMBLY

Pos.	moment weight	serial number	Pos.	moment weight	serial number	Pos.	moment weight	serial number
1		900T3613	26		900T3629	51		KO5225
2		900T3608	27		900T3584	52		900T3647
3		900T3610	28		KO5246	53		900T3632
4		900T3646	29		900T3588	54		900T3591
5		900T3621	30		900T3626	55		900T3635
6		900T3645	31		900T3600	56		900T3622
7		900T3579	32		900T3636	57		900T3638
8		900T3585	33		900T3648	58		900T3653
9		900T3606	34		900T3631	59		900T3633
10		900T3650	35		900T3580	60		900T3649
11		900T3582	36		900T3586	61		900T3616
12		900T3609	37		900T3615	62		900T3596
13		900T3590	38		900T3640	63		900T3617
14		900T3599	39		900T3627	64		900T3625
15		900T3628	40		900T3619	65		900T3643
16		900T3612	41		900T3623	66		900T3578
17		900T3614	42		900T3581	67		900T3604
18		900T3595	43		900T3651	68		900T3602
19		900T3644	44		900T3607	69		900T3589
20		900T3634	45		900T3601	70		900T3652
21		900T3592	46		900T3639	71		900T3637
22		900T3641	47		900T3603			
23		900T3583	48		900T3593			
24		900T3594	49		900T3598			
25		900T3630	50		900T3587			

Notes: The Moment weight is expressed in Kgmm

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 65 of 71	

Form Ref. N°: D5TR0075-C

TURBINE 4TH STAGE BLADES – GENERAL INFORMATION


DRAWING N°: 4217T25

BLADES MATERIAL: INCONEL-X



ASSEMBLY

Pos.	moment weight	serial number	Pos.	moment Weight	serial number	Pos.	moment weight	serial number
1		910UA4619	26		910UA4588	51		910UA4630
2		910UA4592	27		910UA4605	52		910UA4646
3		910UA4622	28		910UA4650	53		910UA4623
4		910UA4625	29		910UA4608	54		910UA4627
5		910UA4654	30		910UA4599	55		910UA4639
6		910UA4628	31		910UA4656	56		910UA4635
7		910UA4636	32		910UA4653	57		910UA4651
8		910UA4618	33		910UA4615	58		910UA4602
9		910UA4609	34		910UA4621	59		910UA4614
10		910UA4631	35		910UA4648	60		910UA4594
11		910UA4589	36		910UA4634	61		910UA4655
12		910UA4632	37		910UA4629	62		910UA4597
13		910UA4606	38		910UA4585	63		910UA4598
14		910UA4638	39		910UA4633	64		910UA4600
15		910UA4617	40		910UA4610	65		910UA4637
16		910UA4644	41		910UA4590	66		910UA4613
17		910UA4603	42		910UA4640	67		910UA4626
18		910UA4616	43		910UA4596	68		910UA4593
19		910UA4604	44		910UA4649			
20		910UA4647	45		910UA4591			
21		910UA4624	46		910UA4620			
22		910UA4643	47		910UA4587			
23		910UA4601	48		910UA4611			
24		910UA4645	49		910UA4595			
25		910UA4612	50		910UA4607			

Notes: The Moment weight is expressed in Kgmm

Turbocare Representative	Signature	Report	Date
Enrico Ferrara		I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 1ST STAGE VANE HOLDER – SPACERS AND SEALS



CONDITIONS:

- I = Deposits
- B = Burned
- R = Rubbing
- C = Crack/corrosion

ACTIONS:



- N = No action required
- R = Repaired/Cleaned
- RN = Replaced by a new one

Pos n°	Segment		Seal between segments		Pos n°	Segment		Seal between segments		Pos n°	Segment		Seal between segments	
	Cond.	Action	Cond.	Action		Cond.	Action	Cond.	Action		Cond.	Action	Cond.	Action
1	I	R			21	I	R			41	I	R		
2	I	R			22	I	R			42	I	R		
3	I	R			23	I	R			43	I	R		
4	B	R			24	I	R			44	I	R		
5	I	R			25	I	R			45	I	R		
6	I	R			26	I	R			46	I	R		
7	I	R			27	I	R			47	I	R		
8	I	R			28	I	R			48	I	R		
9	I	R			29	I	R			49	I	R		
10	I	R			30	I	R			50	I	R		
11	I	R			31	I	R			51	I	R		
12	I	R			32	I	R			52	I	R		
13	I	R			33	I	R			53	I	R		
14	I	R			34	I	R			54	I	R		
15	I	R			35	I	R			55	I	R		
16	I	R			36	I	R			56	I	R		
17	I	R			37	I	R			57	I	R		
18	I	R			38	I	R			58	I	R		
19	I	R			39	I	R			59	I	R		
20	I	R			40	I	R			60	I	R		

Notes:

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 2ND STAGE VANE HOLDER – SPACERS AND SEALS



CONDITIONS:

- I = Deposits
- B = Burned
- R = Rubbing
- C = Crack/Corrosion

ACTIONS:



- N = No action required
- R = Repaired/Cleaned
- RN = Replaced by a new one

Pos n°	Segment		Seal between segments		Pos n°	Segment		Seal between segments		Pos n°	Segment		Seal between segments	
	Cond.	Action	Cond.	Action		Cond.	Action	Cond.	Action		Cond.	Action	Cond.	Action
1	I	R			21	C	R			41	I	R		
2	C	R			22	C	R			42	C	R		
3	C	R			23	C	R			43	C	R		
4	C	R			24	I	R			44	I	R		
5	I	R			25	I	R			45	C	R		
6	C	R			26	C	R			46	C	R		
7	C	R			27	C	R			47	C	R		
8	C	R			28	C	R			48	C	R		
9	C	R			29	C	R			49	C	R		
10	C	R			30	C	R			50	C	R		
11	I	R			31	I	R			51	C	R		
12	C	R			32	C	R			52	C	R		
13	C	R			33	C	R			53	C	R		
14	I	R			34	C	R			54	C	R		
15	C	R			35	C	R			55	C	R		
16	C	R			36	C	R			56	C	R		
17	C	R			37	C	R			57	C	R		
18	C	R			38	C	R			58	C	R		
19	C	R			39	C	R			59	C	R		
20	C	R			40	C	R			60	C	R		

Notes:

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 3RD STAGE VANE HOLDER – SPACERS AND SEALS



CONDITIONS:

I = Deposits
 B = Burned
 R = Rubbing
 C = Crack/Corrosion

ACTIONS:



N = No action required
 R = Repaired/Cleaned
 RN = Replaced by a new one

Pos n°	Segment		Seal between segments		Pos n°	Segment		Seal between segments		Pos n°	Segment		Seal between segments	
	Cond.	Action	Cond.	Action		Cond.	Action	Cond.	Action		Cond.	Action	Cond.	Action
1	I	R			13	I	R			25	I	R		
2	I	R			14	I	R			26	I	R		
3	I	R			15	I	R			27	I	R		
4	I	R			16	I	R			28	I	R		
5	I	R			17	I	R			29	I	R		
6	I	R			18	I	R			30	I	R		
7	I	R			19	I	R			31	I	R		
8	I	R			20	I	R			32	I	R		
9	I	R			21	I	R			33	I	R		
10	I	R			22	I	R			34	I	R		
11	I	R			23	I	R			35	I	R		
12	I	R			24	I	R			36	I	R		

Notes:

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE 4TH STAGE VANE HOLDER – SPACERS AND SEALS



CONDITIONS:

I = Deposits
 B = Burned
 R = Rubbing
 C = Crack/Corrosion

ACTIONS:

N = No action required
 R = Repaired/Cleaned
 RN = Replaced by a new one


Pos n°	Segment		Seal between segments		Pos n°	Segment		Seal between segments		Pos n°	Segment		Seal between segments	
	Cond.	Action	Cond.	Action		Cond.	Action	Cond.	Action		Cond.	Action	Cond.	Action
1	I	R			13	I	R			25	I	R		
2	I	R			14	I	R			26	I	R		
3	I	R			15	I	R			27	I	R		
4	I	R			16	I	R			28	I	R		
5	I	R			17	I	R			29	I	R		
6	I	R			18	I	R			30	I	R		
7	I	R			19	I	R			31	I	R		
8	I	R			20	I	R			32	I	R		
9	I	R			21	I	R			33	I	R		
10	I	R			22	I	R			34	I	R		
11	I	R			23	I	R			35	I	R		
12	I	R			24	I	R			36	I	R		

Notes:

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TurboCare [®]	TECHNICAL REPORT	Rev. Date: 09/12/04	Rev.11
		Power Plant: GT S/N:354	
Customer: IPSA	Turbine Type: TG50D5std	Sheet: 70 of 71	
Form Ref. No.: D5TR0091			

ROTOR COOLING FLEXIBLE PIPES – INSPECTION




TUBE N°	VISUAL CHECK	DAMAGE DESCRIPTION	REPAIRED	REPLACED
1	Good			
2	Good			
3	Good			
4	Good			

NOTES: Contrast dye check were performed on the welding, no indications found

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008

TURBINE DISKS – INSPECTION



TEST CARRIED OUT	DYE TEST	VISUAL CHECK	MAGNETIC CHECK
1ST STAGE	Good	Good	
2ND STAGE	Good	Good	
3RD STAGE	Good	Good	
4TH STAGE	Good	Good	

NOTES:

Turbocare Representative	Signature	Report	Date
Enrico Ferrara	<i>Enrico Ferrara</i>	I-TLG/TG50D5-354/TR014-08	03/09/2008